

PAT Report Passes For all Sites and Locations

| CLIENT DETAILS | |
|----------------|---|
| Company Name: | Hi-Lights Theatre Services |
| Address: | 18E White Rose Way Gateshead NE10 8YX |



| DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING | |
|--|---|
| Company Name: | Hi-Lights Theatre Services Ltd |
| Address: | 18e White Rose Way Gateshead NE10 8YX |
| Telephone: | 0191 4950608 |
| Mobile: | |
| Email: | martin@hi-lights.tv |
| Cert Number: | |
| Order Number: | |
| File Name: | MASTER.April.23.4132.PAT |
| Signature: | |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| HI-LIGHTS - AUDIO | | | | | | | | | |
| 03169 | QSC PLX1202 | 06/03/23 | P | S | P 0.12 | P >99.9 | P 0.09 | P 0.33 | PASS |
| 06969 | M7 | 06/03/23 | P | S | P 0.13 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 08783 | LS9 | 06/03/23 | P | S | P 0.13 | P >99.9 | P 0.09 | P 0.19 | PASS |
| 12685 | 13A IEC | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 12685 | 13A IEC | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 13743 | YAMAHA SB168-ES | 06/03/23 | P | S | P 0.25 | P >99.9 | P 0.10 | P 0.44 | PASS |
| 14350 | 13A IEC | 21/02/23 | P | P | P 0.39 | S | S | P 0.10 | PASS |
| 14350 | 13A IEC | 21/02/23 | P | P | P 0.39 | S | S | P 0.10 | PASS |
| 14560 | 13A 4WAY | 17/01/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 14560 | 13A 4WAY | 17/01/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 16503 | 13A IEC | 06/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 16504 | SOUNDCRAFT STAGE BOX | 06/03/23 | P | S | P 0.18 | P >99.9 | P <0.05 | P 0.36 | PASS |
| Total Appliances > | | | | | | | | | 12 |

HI-LIGHTS - CABLES

| | | | | | | | | | |
|--------|--|----------|---|---|--------|---------|---|--------|------|
| 13826A | THRU ELEMENT OF 63 1P DB | 09/05/22 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 13800A | THRU ELEMENT OF DISTRO 13800 | 13/05/22 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 13802A | THRU ELEMENT OF DISTRO 13802 | 18/05/22 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 15783A | THRU ELEMENT OF DISTRO 15783 | 18/05/22 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 03006C | CONTINUITY AND POLARITY FUNCTIONS OF DISTRO 03006 - 100MA RCD'S TESTED SEPERATELY WITH MFT | 19/05/22 | P | P | P 0.30 | S | S | P 0.14 | PASS |
| 03006B | 16A RCBO ELEMENT OF DISTRO 03006 | 19/05/22 | P | P | P 0.27 | S | S | P 0.16 | PASS |
| 04715A | THRU ELEMENT OF DISTRO 04715 | 18/05/22 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

| Key P = PASS / F = FAIL / S = SKIP (or test not applicable) | | | | | | | | | | |
|---|--|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|--|
| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status | |
| 03006C | CONTINUITY AND POLARITY FUNCTIONS OF DISTRO 03006 - 100MA RCD'S TESTED SEPERATELY WITH MFT | 19/05/22 | P | P | P 0.36 | S | S | P 0.14 | PASS | |
| 04717A | THRU ELEMENT OF DISTRO 04717 | 18/05/22 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS | |
| 12391A | 125 3P - 4X 32/3 MCB + 3 X 32 / 1RCBO + 1 X 16 RCBO | 09/05/22 | P | P | P 0.24 | S | S | P 0.40 | PASS | |
| 03006A | 125A / 3 - 2 X 63 / 3 RCBO + 1X 16 RCBO | 09/05/22 | P | P | P 0.18 | S | S | P 0.23 | PASS | |
| 12391A | 125 3P - 4X 32/3 MCB + 3 X 32 / 1RCBO + 1 X 16 RCBO | 09/05/22 | P | P | P 0.25 | S | S | P 0.10 | PASS | |
| 13824A | THRU ELEMENT OF DISTRO 13824 | 13/05/22 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS | |
| 12391A | 125 3P - 4X 32/3 MCB + 3 X 32 / 1RCBO + 1 X 16 RCBO | 09/05/22 | P | P | P 0.22 | S | S | P 0.17 | PASS | |
| 12391A | 125 3P - 4X 32/3 MCB + 3 X 32 / 1RCBO + 1 X 16 RCBO | 09/05/22 | P | P | P 0.29 | S | S | P 0.18 | PASS | |
| 07980A | THRU ELEMENT OF DISTRO 07980 | 13/05/22 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS | |
| 00576 | PA 12 | 06/03/23 | P | S | P 0.10 | P >99.9 | P <0.05 | P 0.37 | PASS | |
| 00847 | 15A GRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS | |
| 00847 | 15A GRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS | |
| 00854 | 15A GRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 00854 | 15A GRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 00857 | 15A GRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 00857 | 15A GRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 00858 | 15A GRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 00858 | 15A GRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 00973 | 63 1P - 2 X 32 & 6 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.26 | S | S | P 0.10 | PASS | |
| 00973 | 63 1P - 2 X 32 & 6 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.17 | S | S | P 0.10 | PASS | |
| 00973 | 63 1P - 2 X 32 & 6 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.16 | S | S | P 0.10 | PASS | |
| 00973 | 63 1P - 2 X 32 & 6 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.21 | S | S | P 0.10 | PASS | |
| 00973 | 63 1P - 2 X 32 & 6 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.25 | S | S | P 0.10 | PASS | |
| 00973 | 63 1P - 2 X 32 & 6 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.25 | S | S | P 0.10 | PASS | |
| 00973 | 63 1P - 2 X 32 & 6 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.18 | S | S | P 0.10 | PASS | |
| 00973 | 63 1P - 2 X 32 & 6 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.18 | S | S | P 0.10 | PASS | |
| 01307 | 32 / 1P - 32 / 1P THROUGH 100MA RCD + 32A MCB | 19/05/22 | P | P | P 0.16 | S | S | P 0.10 | PASS | |
| 01334 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1 X13 (100MA RCD) | 19/05/22 | P | P | P 0.35 | S | S | P 0.10 | PASS | |
| 01334 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1 X13 (100MA RCD) | 19/05/22 | P | P | P 0.22 | S | S | P 0.10 | PASS | |
| 01334 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1 X13 (100MA RCD) | 19/05/22 | P | P | P 0.26 | S | S | P 0.10 | PASS | |
| 01334 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1 X13 (100MA RCD) | 19/05/22 | P | P | P 0.34 | S | S | P 0.10 | PASS | |
| 01334 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1 X13 (100MA RCD) | 19/05/22 | P | P | P 0.27 | S | S | P 0.10 | PASS | |
| 01334 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1 X13 (100MA RCD) | 19/05/22 | P | P | P 0.32 | S | S | P 0.10 | PASS | |
| 01334 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1 X13 (100MA RCD) | 19/05/22 | P | P | P 0.27 | S | S | P 0.10 | PASS | |
| 01334 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1 X13 (100MA RCD) | 19/05/22 | P | P | P 0.28 | S | S | P 0.10 | PASS | |

APPLIANCE DETAILS AND TEST RESULTS

| Key P = PASS / F = FAIL / S = SKIP (or test not applicable) | | | | | | | | | | |
|---|---|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|--|
| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status | |
| 01334 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1 X13 (100MA RCD) | 19/05/22 | P | P | P 0.32 | S | S | P 0.10 | PASS | |
| 01335 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS | |
| 01335 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS | |
| 01335 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.26 | S | S | P 0.10 | PASS | |
| 01335 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS | |
| 01335 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS | |
| 01335 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.51 | S | S | P 0.10 | PASS | |
| 01335 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS | |
| 01335 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.25 | S | S | P 0.10 | PASS | |
| 01335 | 63 / 3P - 6 X 63 / 1P + 1 X 16 + 1 X 15 + 1X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.42 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.38 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.57 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.27 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.51 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.24 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.21 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.22 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.30 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.45 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.26 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.22 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.39 | S | S | P 0.10 | PASS | |
| 01336 | 63 / 3P - 12 X 16 + 2 X 15 + 2 X 13 MCB (100MA RCD) | 19/05/22 | P | P | P 0.33 | S | S | P 0.10 | PASS | |
| 01474 | 15A GRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS | |
| 01474 | 15A GRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS | |
| 01474 | 15A GRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS | |
| 01474 | 15A GRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS | |
| 01475 | 15A GRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 01475 | 15A GRELCO | 01/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 01475 | 15A GRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 01475 | 15A GRELCO | 01/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS | |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 01476 | 15A GRELCO | 01/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 01476 | 15A GRELCO | 01/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 01476 | 15A GRELCO | 01/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 01476 | 15A GRELCO | 01/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 01479 | 15A GRELCO | 01/03/23 | P | P | P 0.73 | S | S | P 0.10 | PASS |
| 01479 | 15A GRELCO | 01/03/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 01479 | 15A GRELCO | 01/03/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 01479 | 15A GRELCO | 01/03/23 | P | P | P 0.73 | S | S | P 0.10 | PASS |
| 01480 | 15A GRELCO | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 01480 | 15A GRELCO | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 01480 | 15A GRELCO | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 01480 | 15A GRELCO | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 01482 | 15A GRELCO | 01/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 01482 | 15A GRELCO | 01/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 01484 | 15A GRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01484 | 15A GRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01484 | 15A GRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01484 | 15A GRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01487 | 15A GRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 01487 | 15A GRELCO | 01/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 01487 | 15A GRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 01487 | 15A GRELCO | 01/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 01491 | 15A GRELCO | 01/03/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 01491 | 15A GRELCO | 01/03/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 01492 | 15A GRLECO | 01/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 01492 | 15A GRLECO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 01492 | 15A GRLECO | 01/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 01492 | 15A GRLECO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 01503 | 15A GRELCO | 01/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 01503 | 15A GRELCO | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 01503 | 15A GRELCO | 01/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 01503 | 15A GRELCO | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 01507 | 15A GRELCO | 01/03/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 01507 | 15A GRELCO | 01/03/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 01507 | 15A GRELCO | 01/03/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 01507 | 15A GRELCO | 01/03/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 01509 | 15A GRELCO | 01/03/23 | P | P | P 0.59 | S | S | P 0.10 | PASS |
| 01509 | 15A GRELCO | 01/03/23 | P | P | P 0.59 | S | S | P 0.10 | PASS |
| 01511 | 15A GRELCO | 01/03/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 01511 | 15A GRELCO | 01/03/23 | P | P | P 0.42 | S | S | P 0.10 | PASS |
| 01511 | 15A GRELCO | 01/03/23 | P | P | P 0.42 | S | S | P 0.10 | PASS |
| 01511 | 15A GRELCO | 01/03/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 01514 | 15A GRELCO | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 01514 | 15A GRELCO | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 01514 | 15A GRELCO | 01/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 01514 | 15A GRELCO | 01/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 01517 | 15A GRELCO | 01/03/23 | P | P | P 1.10 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 01517 | 15A GRELCO | 01/03/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 01517 | 15A GRELCO | 01/03/23 | P | P | P 1.10 | S | S | P 0.10 | PASS |
| 01517 | 15A GRELCO | 01/03/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 01583 | RMX 1850 | 06/03/23 | P | S | P 0.16 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 1594 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.18 | PASS |
| 1594 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.18 | PASS |
| 01900 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01900 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01900 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01900 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01900 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01900 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01900 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01901 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01901 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01901 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01901 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01902 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01902 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01902 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01902 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01902 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01902 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01902 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01902 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01902 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01902 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01902 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01902 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01908 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01908 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01908 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01908 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01908 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01908 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01911 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01911 | 16A TRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 01911 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01911 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01911 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01911 | 16A TRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 01914 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01914 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01914 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01914 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01914 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01914 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01914 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01914 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01914 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01914 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01914 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01915 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01915 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01915 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 01932 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01932 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01932 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01932 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01935 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01935 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01935 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01935 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01935 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01935 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01936 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01936 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01936 | 16A TRLECO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01936 | 16A TRLECO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01936 | 16A TRLECO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01936 | 16A TRLECO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01942 | 16A TRELCO | 01/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 01942 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01942 | 16A TRELCO | 01/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 01942 | 16A TRELCO | 01/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 01942 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01942 | 16A TRELCO | 01/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 01944 | 16A TRELCO | 02/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 01944 | 16A TRELCO | 02/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 01944 | 16A TRELCO | 02/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 01944 | 16A TRELCO | 02/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 01944 | 16A TRELCO | 02/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 01944 | 16A TRELCO | 02/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 01944 | 16A TRELCO | 02/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 01945 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01945 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01945 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01945 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01945 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01945 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01949 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01949 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01949 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01949 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01949 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01949 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01951 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01951 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01951 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01951 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01951 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01952 | 16A TRELCO | 01/03/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 01952 | 16A TRELCO | 01/03/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 01953 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01953 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01953 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01953 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01953 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01953 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01953 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01953 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01954 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01954 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01954 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01954 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01954 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01954 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01956 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01956 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01956 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01956 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01956 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01956 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01957 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01957 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01957 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01957 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01957 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01957 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01959 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01959 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01959 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01959 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01959 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01959 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01959 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01960 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01960 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01960 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01960 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01960 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01960 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01960 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01960 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01960 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01961 | 16A TRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 01961 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01961 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01961 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01961 | 16A TRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 01961 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 01962 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 01962 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 01962 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 01962 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 01962 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 01962 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 01962 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 01962 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 01963 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01963 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01963 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01963 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01965 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01965 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01965 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01965 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01967 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01967 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01967 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01967 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01968 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01968 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01970 | 16A TRLECO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01970 | 16A TRLECO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01970 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01970 | 16A TRLECO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01970 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01970 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01971 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 01971 | 16A TRELCO | 02/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 01971 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 01971 | 16A TRELCO | 02/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 01971 | 16A TRELCO | 02/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 01971 | 16A TRELCO | 02/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 01971 | 16A TRELCO | 02/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 01971 | 16A TRELCO | 02/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 01973 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01973 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01973 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01973 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01973 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01973 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01980 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01980 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01980 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01980 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01982 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS
Key

P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 01982 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01982 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01982 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01982 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01982 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01983 | 16A TRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 01983 | 16A TRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 01983 | 16A TRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 01983 | 16A TRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 01983 | 16A TRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 01983 | 16A TRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 01984 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01984 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01984 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01984 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01984 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01984 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01985 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01985 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01985 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01985 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01985 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01985 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01985 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01987 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01987 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01987 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01987 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01987 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01987 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 01990 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01990 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01990 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01990 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01990 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01992 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01992 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 01992 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01992 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01992 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01993 | 16A TRELCO | 02/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 01993 | 16A TRELCO | 02/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 01993 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 01993 | 16A TRELCO | 02/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 01993 | 16A TRELCO | 02/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 01993 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 01994 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01994 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01994 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01994 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01994 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01994 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01995 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01995 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01995 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01995 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 01996 | 16A TRELCO | 01/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 01996 | 16A TRELCO | 01/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 01996 | 16A TRELCO | 01/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 01996 | 16A TRELCO | 01/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 01996 | 16A TRELCO | 01/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 01996 | 16A TRELCO | 01/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 01998 | 16A TRELCO | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 01998 | 16A TRELCO | 01/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 01998 | 16A TRELCO | 01/03/23 | P | P | P 0.32 | S | S | P 0.10 | PASS |
| 01998 | 16A TRELCO | 01/03/23 | P | P | P 0.32 | S | S | P 0.10 | PASS |
| 01998 | 16A TRELCO | 01/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 01998 | 16A TRELCO | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 02002 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 02002 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 02002 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 02002 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 02002 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 02002 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 02002 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 02004 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 02004 | 16A TRELCO | 02/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 02004 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 02004 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 02004 | 16A TRELCO | 02/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 02004 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 02011 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 02011 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 02011 | 16A TRELCO | 02/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 02011 | 16A TRELCO | 02/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 02011 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 02011 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 02036 | 15A GRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 02036 | 15A GRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 02040 | 15A GRELCO | 01/03/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 02040 | 15A GRELCO | 01/03/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 02372 | 15A GRELCO | 01/03/23 | P | P | P 0.36 | S | S | P 0.10 | PASS |
| 02372 | 15A GRELCO | 01/03/23 | P | P | P 0.50 | S | S | P 0.10 | PASS |
| 02372 | 15A GRELCO | 01/03/23 | P | P | P 0.36 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 02372 | 15A GRELCO | 01/03/23 | P | P | P 0.50 | S | S | P 0.10 | PASS |
| 02373 | 15A GRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 02373 | 15A GRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 02373 | 15A GRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 02373 | 15A GRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 02379 | 16A GRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 02379 | 15A GRLECO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 02379 | 15A GRLECO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 02379 | 15A GRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 02464 | 15A GRELCO | 01/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 02464 | 15A GRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 02464 | 15A GRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 02464 | 15A GRELCO | 01/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 02513 | PA 12 | 06/03/23 | P | S | P 0.17 | P >99.9 | P <0.05 | P 0.38 | PASS |
| 02516 | 15A GRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 02516 | 15A GRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 02531 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02531 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02531 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02531 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02677 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02677 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02678 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02678 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02679 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02679 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02680 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02680 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02681 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02681 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02682 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02682 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02683 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02683 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02684 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02684 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02685 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02685 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02686 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02686 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02687 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02687 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02688 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02688 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02689 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02689 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02690 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS
Key

P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|--|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 02690 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02691 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02691 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02700 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02700 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02701 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02701 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02702 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02702 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02703 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02703 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02704 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02704 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02706 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 02706 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 03049 | 63 / 3P - 6 X 32 / 1P RCBO PLASTIC BOX | 19/05/22 | P | P | P 0.29 | S | S | P 0.10 | PASS |
| 03049 | 63 / 3P - 6 X 32 / 1P RCBO PLASTIC BOX | 19/05/22 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 03049 | 63 / 3P - 6 X 32 / 1P RCBO PLASTIC BOX | 19/05/22 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 03049 | 63 / 3P - 6 X 32 / 1P RCBO PLASTIC BOX | 19/05/22 | P | P | P 0.33 | S | S | P 0.10 | PASS |
| 03049 | 63 / 3P - 6 X 32 / 1P RCBO PLASTIC BOX | 19/05/22 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 03049 | 63 / 3P - 6 X 32 / 1P RCBO PLASTIC BOX | 19/05/22 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 03940 | 16A TRELCO | 02/03/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 03940 | 16A TRELCO | 02/03/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 03941 | 15A TRELCO | 02/03/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 03941 | 15A TRELCO | 02/03/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 03943 | 15A TRELCO | 02/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 03943 | 15A TRELCO | 02/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 04399 | 15A GRELCO | 01/03/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 04399 | 15A GRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 04399 | 15A GRELCO | 01/03/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 04399 | 15A GRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 04441 | DBX GRPHIC EQ | 06/03/23 | P | S | P 0.22 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 04715 | 16A (THRU) - 14 X 13A RCD TOBLERONE | 18/05/22 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 04715 | 16A (THRU) - 14 X 13A RCD TOBLERONE | 18/05/22 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 04715 | 16A (THRU) - 14 X 13A RCD TOBLERONE | 18/05/22 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 04715 | 16A (THRU) - 14 X 13A RCD TOBLERONE | 18/05/22 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 04715 | 16A (THRU) - 14 X 13A RCD TOBLERONE | 18/05/22 | P | P | P 0.39 | P >99.9 | S | P 0.10 | PASS |
| 04715 | 16A (THRU) - 14 X 13A RCD TOBLERONE | 18/05/22 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 04715 | 16A (THRU) - 14 X 13A RCD TOBLERONE | 18/05/22 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 04715 | 16A (THRU) - 14 X 13A RCD TOBLERONE | 18/05/22 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 04724 | 16A THRU - 14 X 13A RCD | 09/05/22 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 04760 | 13A TO 16A | 22/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 04805 | QSC RMX 1850 HDX1 | 06/03/23 | P | S | P 0.09 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 04888 | NEXUS 4X4 | 01/03/23 | P | S | P 0.16 | P >99.9 | P <0.05 | P 0.22 | PASS |
| 04888 | NEXUS 4X4 | 01/03/23 | P | S | P 0.16 | P >99.9 | P <0.05 | P 0.22 | PASS |
| 04896 | NEXUS 4X4 | 01/03/23 | P | S | P 0.10 | P >99.9 | P <0.05 | P 0.26 | PASS |
| 04896 | NEXUS 4X4 | 01/03/23 | P | S | P 0.10 | P >99.9 | P <0.05 | P 0.26 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 04931 | CHAUVET QWASH | 07/03/23 | P | S | P 0.15 | P >99.9 | P 0.06 | P 0.30 | PASS |
| 04942 | ROBE POINTE | 28/02/23 | P | S | P 0.16 | P >99.9 | P 0.14 | P 0.24 | PASS |
| 04942 | ROBE POINTE | 28/02/23 | P | S | P 0.16 | P >99.9 | P 0.14 | P 0.24 | PASS |
| 04946 | ROBE POINTE | 28/02/23 | P | S | P 0.14 | P >99.9 | P 0.13 | P 0.24 | PASS |
| 04946 | ROBE POINTE | 28/02/23 | P | S | P 0.14 | P >99.9 | P 0.13 | P 0.24 | PASS |
| 04947 | ROBE POINTE | 28/02/23 | P | S | P 0.16 | P >99.9 | P 0.14 | P 0.24 | PASS |
| 04947 | ROBE POINTE | 28/02/23 | P | S | P 0.16 | P >99.9 | P 0.14 | P 0.24 | PASS |
| 04980 | ROBE POINTE | 28/02/23 | P | S | P 0.13 | P >99.9 | P 0.13 | P 0.25 | PASS |
| 04980 | ROBE POINTE | 28/02/23 | P | S | P 0.13 | P >99.9 | P 0.13 | P 0.25 | PASS |
| 05047 | 13A CABLE 10M | 17/01/23 | P | P | P 0.59 | P >99.9 | S | P 0.10 | PASS |
| 05047 | 13A CABLE 10M | 17/01/23 | P | P | P 0.59 | P >99.9 | S | P 0.10 | PASS |
| 05078 | 15A TO 13A | 01/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 05078 | 15A TO 13A | 01/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 05096 | 16A IEC | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 05096 | 16A IEC | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 05097 | 15A IEC | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 05097 | 15A IEC | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 05099 | 15A IEC | 20/02/23 | P | P | P 0.53 | S | S | P 0.10 | PASS |
| 05099 | 15A IEC | 20/02/23 | P | P | P 0.53 | S | S | P 0.10 | PASS |
| 05100 | 15A IEC | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 05100 | 15A IEC | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 05179 | 15A CABLE 10M | 24/03/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 05196 | 13A IEC | 28/02/23 | P | P | P 0.31 | S | S | P 0.10 | PASS |
| 05196 | 13A IEC | 28/02/23 | P | P | P 0.31 | S | S | P 0.10 | PASS |
| 05233 | 13A TO 15A | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 05233 | 13A TO 15A | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 05308 | 13A IEC | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 05308 | 13A IEC | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 05342 | 13A IEC | 21/02/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 05342 | 13A IEC | 21/02/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 05365 | 16A TO 15A | 20/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 05365 | 16A TO 15A | 20/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 05401 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.53 | S | S | P 0.10 | PASS |
| 05401 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.53 | S | S | P 0.10 | PASS |
| 05434 | 13A IEC | 21/02/23 | P | P | P 0.37 | S | S | P 0.10 | PASS |
| 05434 | 13A IEC | 21/02/23 | P | P | P 0.37 | S | S | P 0.10 | PASS |
| 05477 | 13A TO 16A | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 05477 | 13A TO 16A | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 05543 | 13A IEC | 21/02/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 05543 | 13A IEC | 21/02/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 05550 | 15A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 05550 | 15A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 05553 | 15A TO 16A | 28/02/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 05553 | 15A TO 16A | 28/02/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 05555 | 15A TO 16A | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 05555 | 15A TO 16A | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 05556 | 15A TO 16A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 05556 | 15A TO 16A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 05557 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 05557 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 05558 | 13A TO 15A | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 05558 | 13A TO 15A | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 05560 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 05560 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 05561 | 15A TO 16A | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 05561 | 15A TO 16A | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 05563 | 15A TO 16A | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 05563 | 15A TO 16A | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 05565 | 15A TO 16A | 20/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 05565 | 15A TO 16A | 20/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 05569 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 05569 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 05636 | 16A IEC | 21/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 05636 | 16A IEC | 21/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 05639 | 13A IEC | 21/02/23 | P | P | P 0.68 | S | S | P 0.10 | PASS |
| 05639 | 13A IEC | 21/02/23 | P | P | P 0.68 | S | S | P 0.10 | PASS |
| 05659 | 16A TO 13A 2WAY BLCK | 28/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 05659 | 16A TO 13A 2WAY | 28/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 05734 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 05734 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 05847 | 13A CABLE 3M | 19/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 05847 | 13A CABLE 3M | 19/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 05855 | 15A 13A | 07/03/23 | P | P | P 0.38 | S | S | P 0.10 | PASS |
| 05866 | 13A 6WAY | 28/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 05866 | 13A 6WAY | 28/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 05879 | 15A IEC | 20/02/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 05879 | 15A IEC | 20/02/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 05880 | 15A IEC | 20/02/23 | P | P | P 0.31 | S | S | P 0.10 | PASS |
| 05880 | 15A IEC | 20/02/23 | P | P | P 0.31 | S | S | P 0.10 | PASS |
| 05891 | 13A TO 15A | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 05891 | 13A TO 15A | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 05922 | 15A IEC | 07/03/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 05923 | 15A IEC | 20/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 05923 | 15A IEC | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 05923 | 15A IEC | 20/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 05923 | 15A IEC | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 05924 | 15A IEC | 20/02/23 | P | P | P 0.63 | S | S | P 0.10 | PASS |
| 05924 | 15A IEC | 20/02/23 | P | P | P 0.63 | S | S | P 0.10 | PASS |
| 05935 | 16A IEC | 21/02/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 05935 | 16A IEC | 21/02/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 05962 | 16A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 05962 | 16A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 06001 | 13A TO 16A | 01/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 06001 | 13A TO 16A | 01/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 06001 | 13A TO 16A | 22/03/23 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 06026 | DBX GRAPHIC EQ | 06/03/23 | P | S | P 0.14 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 06122 | 13A IEC | 28/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 06122 | 13A IEC | 28/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 06190 | 16A TO TRUCON | 16/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 06195 | 13A CABLE 10M | 17/01/23 | P | P | P 0.60 | P >99.9 | S | P 0.10 | PASS |
| 06195 | 13A CABLE 10M | 17/01/23 | P | P | P 0.60 | P >99.9 | S | P 0.10 | PASS |
| 06249 | 15A TRELCO | 02/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 06249 | 15A TRELCO | 02/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 06783 | 16A TO 13A 1WAY | 26/01/23 | P | P | P 0.43 | S | S | P 0.10 | PASS |
| 06783 | 16A TO 13A 1WAY | 26/01/23 | P | P | P 0.43 | S | S | P 0.10 | PASS |
| 06801 | 16A TO 15A | 20/02/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 06801 | 16A TO 15A | 20/02/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 06804 | 13A TO 15A | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 06804 | 13A - 15A ADAPTOR | 18/05/22 | P | P | P 0.47 | S | S | P 0.10 | PASS |
| 06804 | 13A TO 15A | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 06807 | 13A TO 15A | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 06807 | 13A TO 15A | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 06937 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 06937 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 06944 | IEC 15A | 07/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 06948 | 13A IEC | 06/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 06949 | 15A IEC | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 06949 | 15A IEC | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 06999 | 13A - 16A | 18/05/22 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 07010 | 13A 4WAY | 18/01/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 07010 | 13A 4WAY | 18/01/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 07037 | 13A 6WAY | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 07037 | 13A 6WAY | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 07097 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 07097 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 07100 | 13A TO 15A | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 07100 | 13A TO 15A | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 07101 | 13A TO 15A | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 07101 | 13A TO 15A | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 07136 | 13A TO 15A | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 07136 | 13A TO 15A | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 07304 | 16A 3PH CABLE 10M | 03/03/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 07308 | 16A 3PH CABLE 10M | 06/03/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 07311 | 16A 3PH CABLE 10M | 03/03/23 | P | P | P 0.55 | P >99.9 | S | P 0.10 | PASS |
| 07380 | 13A CABLE REEL 15M BLUE | 02/03/23 | P | P | P 0.33 | S | S | P 0.10 | PASS |
| 07380 | 13A CABLE REEL 15M BLUE | 02/03/23 | P | P | P 0.33 | S | S | P 0.10 | PASS |
| 07381 | 13A CABLE REEL 10M | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 07381 | 13A CABLE REEL 10M | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 07382 | 13A CABLE REEL 25M RED | 02/03/23 | P | P | P 0.44 | S | S | P 0.17 | PASS |
| 07382 | 13A CABLE REEL 25M RED | 02/03/23 | P | P | P 0.44 | S | S | P 0.17 | PASS |
| 07396 | 15A IEC | 20/02/23 | P | P | P 0.63 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 07396 | 15A IEC | 20/02/23 | P | P | P 0.63 | S | S | P 0.10 | PASS |
| 07399 | 15A IEC | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 07399 | 15A IEC | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 07400 | 15A IEC | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 07400 | 15A IEC | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 07403 | 15A IEC | 28/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 07403 | 15A IEC | 28/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 07406 | 15A IEC | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 07406 | 15A IEC | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 07407 | 15A IEC | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 07407 | 15A IEC | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 07408 | 15A IEC | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 07408 | 15A IEC | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 07413 | 15A IEC | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 07413 | 15A IEC | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 07475 | IEC 15A | 07/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 07481 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 07481 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 07516 | 13A TO 16A | 21/02/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 07516 | 13A TO 16A | 21/02/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 07523 | 13A TO 16A | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 07523 | 13A TO 16A | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 07629 | 16A TO 15A | 20/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 07629 | 16A TO 15A | 20/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 07630 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 07630 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 07636 | 16A TO 15A | 20/02/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 07636 | 16A TO 15A | 20/02/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 07714 | 16A TO 15A | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 07714 | 16A TO 15A | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 07723 | POWERCON LOOM 2M | 22/03/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 07805 | 13A CABLE 1M | 17/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 07805 | 13A CABLE 1M | 17/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 07810 | 15A TO 13A | 28/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 07810 | 15A TO 13A | 28/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 07825 | 13A CABLE 3M | 28/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 07825 | 13A CABLE 3M | 28/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 07864 | 15A TO 16A | 20/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 07864 | 15A TO 16A | 20/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 07865 | 15A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 07865 | 15A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 07866 | 15A TO 16A | 28/02/23 | P | P | P 0.31 | S | S | P 0.10 | PASS |
| 07866 | 15A TO 16A | 28/02/23 | P | P | P 0.31 | S | S | P 0.10 | PASS |
| 07867 | 15A TO 16A | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 07867 | 15A TO 16A | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 07872 | 13A TO 15A | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 07872 | 13A TO 15A | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS
Key

P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-------------------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 07873 | 13A TO 5A | 20/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 07873 | 13A TO 5A | 20/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 07874 | 13A TO 15A | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 07874 | 13A TO 15A | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 07875 | 13A TO 15A | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 07875 | 13A TO 15A | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 07877 | 13A TO 15A | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 07877 | 13A TO 15A | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 07880 | 13A TO 15A | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 07880 | 13A TO 15A | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 07980 | 16A - 14 X 13A RCD TOBLERONE DISTRO | 13/05/22 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 07980 | 16A - 14 X 13A RCD TOBLERONE DISTRO | 13/05/22 | P | P | P 0.39 | P >99.9 | S | P 0.10 | PASS |
| 07980 | 16A - 14 X 13A RCD TOBLERONE DISTRO | 13/05/22 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 07980 | 16A - 14 X 13A RCD TOBLERONE DISTRO | 13/05/22 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 07980 | 16A - 14 X 13A RCD TOBLERONE DISTRO | 13/05/22 | P | P | P 0.33 | P >99.9 | S | P 0.10 | PASS |
| 07980 | 16A - 14 X 13A RCD TOBLERONE DISTRO | 13/05/22 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 07980 | 16A - 14 X 13A RCD TOBLERONE DISTRO | 13/05/22 | P | P | P 0.33 | P >99.9 | S | P 0.10 | PASS |
| 07980 | 16A - 14 X 13A RCD TOBLERONE DISTRO | 13/05/22 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 07980 | 16A - 14 X 13A RCD TOBLERONE DISTRO | 13/05/22 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 07980 | 16A - 14 X 13A RCD TOBLERONE DISTRO | 13/05/22 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 07980 | 16A - 14 X 13A RCD TOBLERONE DISTRO | 13/05/22 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 07980 | 16A - 14 X 13A RCD TOBLERONE DISTRO | 13/05/22 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 07980 | 16A - 14 X 13A RCD TOBLERONE DISTRO | 13/05/22 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 07980 | 16A - 14 X 13A RCD TOBLERONE DISTRO | 13/05/22 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 07999 | 13A CABLE REEL 25M RED | 02/03/23 | P | P | P 0.44 | S | S | P 0.13 | PASS |
| 07999 | 13A CABLE REEL 25M RED | 02/03/23 | P | P | P 0.44 | S | S | P 0.13 | PASS |
| 08009 | 32 1PH TO 16A | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 08009 | 32 1PH TO 16A | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 08014 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 08014 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 08223 | 13A IEC | 22/03/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 08235 | 13A CABLE REEL BLUE 45M | 02/03/23 | P | P | P 0.71 | S | S | P 0.24 | PASS |
| 08235 | 13A CABLE REEL BLUE 45M | 02/03/23 | P | P | P 0.71 | S | S | P 0.24 | PASS |
| 08250 | 13A CABLE 10M | 17/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 08250 | 13A CABLE 10M | 17/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 08383 | 13A CABLE 1M | 17/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 08383 | 13A CABLE 1M | 17/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 08396 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 08396 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 08398 | 15A TO 13A | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 08398 | 15A TO 13A | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 08399 | 15A TO 13A | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 08399 | 15A TO 13A | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 08401 | 16A TO 15A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 08401 | 16A TO 15A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 08654 | | 07/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 08684 | | 07/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 08689 | | 07/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 08750 | 15A GRELCO | 01/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 08750 | 15A GRELCO | 01/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 08797 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 08797 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 08819 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 08819 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 08843 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 08843 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 08846 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 08846 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 08852 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 08852 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 08856 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 08856 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 08864 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 08864 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 08867 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 08867 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 08868 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 08868 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 08873 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 08873 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 08876 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 08876 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 08886 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 08886 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 08887 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 08887 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 08902 | 13A CABLE 10M | 17/01/23 | P | P | P 0.39 | P >99.9 | S | P 0.10 | PASS |
| 08902 | 13A CABLE 10M | 17/01/23 | P | P | P 0.39 | P >99.9 | S | P 0.10 | PASS |
| 08903 | 13A CABLE 10M | 28/02/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 08903 | 13A CABLE 10M | 28/02/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 08905 | 13A CABLE 10M | 17/01/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 08905 | 13A CABLE 10M | 17/01/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 08910 | 13A CABLE 10M | 17/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 08910 | 13A CABLE 10M | 17/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 08981 | 13A IEC | 06/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 08998 | 15A GRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 08998 | 15A GRELCO | 01/03/23 | P | P | P 0.41 | S | S | P 0.10 | PASS |
| 08998 | 15A GRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 08998 | 15A GRELCO | 01/03/23 | P | P | P 0.41 | S | S | P 0.10 | PASS |
| 08999 | 32 1P TAIL - 4 X 16 RCBO DB | 09/05/22 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 08999 | 32 1P TAIL - 4 X 16 RCBO DB | 09/05/22 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 08999 | 32 1P TAIL - 4 X 16 RCBO DB | 09/05/22 | P | P | P 0.32 | S | S | P 0.10 | PASS |
| 08999 | 32 1P TAIL - 4 X 16 RCBO DB | 09/05/22 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 09144 | POWERCON TO 16A | 13/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS
Key
 P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|--------------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 09147 | POWERCON TO 16A | 16/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 09251 | POWERLOCKS TO 125A | 03/03/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 09251 | POWER LOCK - 125 (35MM TAILS) | 13/05/22 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 09254 | 13A 6WAY | 17/01/23 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 09254 | 13A 6WAY | 17/01/23 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 09261 | 32A 1PH CABLE 10M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 09261 | 32A 1PH 10M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 09382 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 09382 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 09386 | TAILS TO 63A 1PH | 03/03/23 | P | S | S | S | S | S | PASS |
| 09386 | TAILS TO 63A 1PH | 03/03/23 | P | S | S | S | S | S | PASS |
| 09391 | 125A - POWERLOCKS (35MM TAILS) | 13/05/22 | P | P | P 0.32 | S | S | P 0.10 | PASS |
| 09395 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 09395 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 09405 | 63A 1PH TO 2X 32A 1PH | 03/03/23 | P | P | P 0.33 | S | S | P 0.10 | PASS |
| 09405 | 63A 1PH TO 2X 32A 1PH | 03/03/23 | P | P | P 0.34 | S | S | P 0.10 | PASS |
| 09405 | 63A 1PH TO 2X 32A 1PH | 03/03/23 | P | P | P 0.34 | S | S | P 0.10 | PASS |
| 09405 | 63A 1PH TO 2X 32A 1PH | 03/03/23 | P | P | P 0.33 | S | S | P 0.10 | PASS |
| 09456 | 125A 3PH TO 63A 3PH | 03/03/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 09467 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 09467 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 09477 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 09477 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 09480 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 09480 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 09539 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 09539 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 09569 | 16A / 3P - 32A / 3P ADAPTOR | 19/05/22 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 09626 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 09626 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 09630 | 16A CABLE 10M | 20/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 09630 | 16A CABLE 10M | 20/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 09782 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 09782 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 09789 | 16A CABLE 10M | 20/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 09789 | 16A CABLE 10M | 20/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 09815 | 32A1PH W/TWIN 13A 5M CABLE | 23/02/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 09815 | 32A 1PH CABLE 5M | 23/02/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 09837 | TAILS TO 32A 1PH | 03/03/23 | P | S | S | S | S | S | PASS |
| 09837 | TAILS TO 32A 1PH | 03/03/23 | P | S | S | S | S | S | PASS |
| 09847 | 13A IEC | 21/02/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 09847 | 13A IEC | 21/02/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 09857 | 63A 1PH TO 2X 63A 1PH | 03/03/23 | P | P | P 0.31 | S | S | P 0.10 | PASS |
| 09857 | 63A 1PH TO 2X 63A 1PH | 03/03/23 | P | P | P 0.31 | S | S | P 0.10 | PASS |
| 09857 | 63A 1PH TO 2X 63A 1PH | 03/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 09857 | 63A 1PH TO 2X 63A 1PH | 03/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 09901 | 13A CABLE 10M | 17/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 09901 | 13A CABLE 10M | 17/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 09903 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 09903 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 09908 | 13A CABLE 10M | 19/01/23 | P | P | P 0.50 | P >99.9 | S | P 0.10 | PASS |
| 09908 | 13A CABLE 10M | 19/01/23 | P | P | P 0.50 | P >99.9 | S | P 0.10 | PASS |
| 09909 | 13A CABLE 10M | 17/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 09909 | 13A CABLE 10M | 17/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 09929 | 63A 1PH TO 32A 1PH | 03/03/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 09929 | 63A 1PH TO 32A 1PH | 03/03/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 09937 | 13A CABLE 5M | 17/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 09937 | 13A CABLE 5M | 17/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 09941 | 13A IEC | 21/02/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 09941 | 13A IEC | 21/02/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 10003 | 16A CABLE 1M | 28/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 10003 | 16A CABLE 1M | 28/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 10004 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 10004 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 10015 | 32A 3PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 10015 | 32A 3PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 10032 | 63A 1PH TO 32A 1PH | 03/03/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 10032 | 63A 1PH TO 32A 1PH | 03/03/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 10043 | 32A 3PH TO 63A 3PH | 03/03/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 10043 | 32A 3PH TO 63A 3PH | 03/03/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 10044 | TAILS TO 63A 20M | 03/03/23 | P | S | S | S | S | S | PASS |
| 10044 | TAILS TO 63A 3PH 20M | 03/03/23 | P | S | S | S | S | S | PASS |
| 10048 | 13A TO 15A | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 10048 | 13A TO 15A | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 10206 | 15A TO 13A | 28/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10206 | 15A TO 13A | 28/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10208 | 15A TO 13A | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10208 | 15A TO 13A | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10210 | 15A TO 16A | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 10210 | 15A TO 16A | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 10212 | 15A TO 16A | 20/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 10212 | 15A TO 16A | 20/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 10213 | 15A TO 16A | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 10213 | 15A TO 16A | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 10214 | 15A TO 16A | 20/02/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 10214 | 15A TO 16A | 20/02/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 10215 | 15A TO 16A | 20/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 10215 | 15A TO 16A | 20/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 10216 | 15A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 10216 | 15A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 10217 | 15A TO 16A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10217 | 15A TO 16A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10218 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10218 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 10219 | 15A TO 16A | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 10219 | 15A TO 16A | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 10220 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10220 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10221 | 15A TO 16A | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 10221 | 15A TO 16A | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 10222 | 15A TO 16A | 20/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 10222 | 15A TO 16A | 20/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 10225 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10225 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10226 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10226 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10227 | 15A TO 16A | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 10227 | 15A TO 16A | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 10228 | 15A TO 16A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10228 | 15A TO 16A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10229 | 15A TO 16A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10229 | 15A TO 16A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10230 | 15A TO 16A | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 10230 | 15A TO 16A | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 10232 | 16A IEC | 21/02/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 10232 | 16A IEC | 21/02/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 10235 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10235 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10243 | 16A IEC | 21/02/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 10243 | 16A IEC | 21/02/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 10244 | 16A TO 15A | 20/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 10244 | 16A TO 15A | 20/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 10245 | 16A TO 15A | 20/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 10245 | 16A TO 15A | 20/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 10246 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10246 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10247 | 15A IEC | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 10247 | 15A IEC | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 10249 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10249 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10250 | 16A IEC | 21/02/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 10250 | 16A IEC | 21/02/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 10251 | 16A IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10251 | 16A IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10298 | 16A IEC | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10298 | 16A IEC | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10316 | 15A IEC | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 10316 | 15A IEC | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 10337 | 15A IEC | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 10337 | 15A IEC | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 10340 | 15A IEC | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 10340 | 15A IEC | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 10341 | 15A TO 16A | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 10341 | 15A TO 16A | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 10345 | 16A TO 15A | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 10345 | 16A TO 15A | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 10348 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10348 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 10351 | 16A TO 13A | 28/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10351 | 15A TO 13A 2WAY | 28/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10352 | 15A TO 16A | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 10352 | 15A TO 16A | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 10353 | 16A TO 15A | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 10353 | 16A TO 15A | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 10354 | 16A TO 13A 1WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 10354 | 16A TO 13A 1WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 10357 | 15A IEC | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10357 | 15A IEC | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10359 | 15A IEC | 20/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 10359 | 15A IEC | 20/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 10360 | 16A TO 15A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10360 | 16A TO 15A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10361 | 13A TO 15A | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10361 | 13A TO 15A | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10363 | 13A TO 15A | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10363 | 13A TO 15A | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10366 | 15A IEC | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 10366 | 15A IEC | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 10367 | 15A TO 16A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10367 | 15A TO 16A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10368 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10368 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10368 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10368 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10381 | 16A TO 13A 4WAU | 28/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 10381 | 16A TO 13A 4WAY | 28/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 10382 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 10382 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 10391 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 10391 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 10392 | 16A TO 13A 3WAY | 26/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10392 | 16A TO 13A 3WAY | 26/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10393 | 16A TO 13A 3WAY | 26/01/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 10393 | 16A TO 13A 3WAY | 26/01/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 10403 | 15A TO 13A | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 10403 | 15A -13A ADAPTOR | 18/05/22 | P | P | P 0.35 | S | S | P 0.10 | PASS |
| 10403 | 15A TO 13A | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 10429 | 15A 3M | 07/03/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|--------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 10455 | 63A 1PH TO 2X 32A 1PH | 03/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 10455 | 63A 1PH TO 2X 32A 1PH | 03/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 10455 | 63A 1PH TO 2X 32A 1PH | 03/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 10455 | 63A 1PH TO 2X 32A 1PH | 03/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 10559 | 13A CABLE REEL 30M BLUE | 02/03/23 | P | P | P 0.45 | S | S | P 0.14 | PASS |
| 10559 | 13A CABLE REEL 30M BLUE | 02/03/23 | P | P | P 0.45 | S | S | P 0.14 | PASS |
| 10562 | 13A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 10562 | 13A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 10568 | 13A IEC | 21/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 10568 | 13A IEC | 21/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 10592 | 15A 5M | 07/03/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 10602 | 15A 5M | 07/03/23 | P | P | P 0.48 | P >99.9 | S | P 0.10 | PASS |
| 10622 | 16A CABLE 3M | 28/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 10622 | 16A CABLE 3M | 28/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 10656 | 15A 1M | 07/03/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 10657 | 15A 1M | 07/03/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 10721 | 13A IEC | 21/02/23 | P | P | P 1.20 | S | S | P 0.10 | PASS |
| 10721 | 13A IEC | 21/02/23 | P | P | P 1.20 | S | S | P 0.10 | PASS |
| 10802 | 16A CABLE 10M | 23/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 10802 | 16A CABLE 10M | 23/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 10816 | 13A CABLE 10M | 17/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 10816 | 13A CABLE 10M | 17/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 10821 | 16A 1PH 32A 1PH CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10821 | 16A 1PH - 32A 1PH | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 10829 | 13A TO 15A | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 10829 | 13A TO 15A | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 10845 | 13A CABLE 10M | 23/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 10845 | 13A CABLE 10M | 23/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 10852 | 32A 1PH 16A 1PH CAB GREL | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10852 | 32A 1PH 16A 1PH CAB GREL | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10852 | 32A 1PH 16A 1PH CAB GREL | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10852 | 32A 1PH 16A 1PH CAB GREL | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 10862 | 13A IEC | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 10862 | 13A IEC | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 10884 | 15A TO 16A | 20/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 10884 | 15A TO 16A | 20/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 10937 | 16A IEC | 28/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 10937 | 16A IEC | 28/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 10940 | 16A CABLE 5M | 18/01/23 | P | P | P 0.26 | P 15.14 | S | P 0.10 | PASS |
| 10940 | 16A CABLE 5M | 18/01/23 | P | P | P 0.26 | P 15.14 | S | P 0.10 | PASS |
| 10945 | 16A TO 13A 4WAU | 20/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 10945 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 10951 | 32A 3PH TO 63A 3PH | 03/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 10951 | 32A 3PH TO 63A 3PH | 03/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 10960 | 13A TO 16A | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 10960 | 13A TO 16A | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 10968 | 13A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 10968 | 13A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 10989 | 16A TO 15A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 10989 | 16A TO 15A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 11005 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 11005 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 11015 | 16A CABLE 5M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 11015 | 16A CABLE 5M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 11016 | 16A TO 13A 1WAY | 26/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 11016 | 16A TO 13A | 26/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 11020 | 13A 6WAY | 18/01/23 | P | P | P 0.37 | S | S | P 0.10 | PASS |
| 11020 | 13A 6WAY | 18/01/23 | P | P | P 0.37 | S | S | P 0.10 | PASS |
| 11027 | 13A TO 16A | 28/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 11027 | 13A TO 16A | 28/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 11041 | 16A 3PH CABLE 10M | 06/03/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 11052 | | 07/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 11057 | 13A TO PC | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 11065 | 32 / 3P 40M CABLE | 19/05/22 | P | P | P 0.36 | P >99.9 | S | P 0.46 | PASS |
| 11093 | 15A CABLE 10M | 22/03/23 | P | P | P 0.42 | P >99.9 | S | P 0.10 | PASS |
| 11152 | 13A 4WAY | 23/01/23 | P | P | P 0.32 | S | S | P 0.10 | PASS |
| 11152 | 13A 4WAY | 23/01/23 | P | P | P 0.32 | S | S | P 0.10 | PASS |
| 11160 | 13A - IEC | 18/05/22 | P | P | P 0.34 | S | S | P 0.10 | PASS |
| 11163 | 16A TO 13A 1WAY | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 11163 | 16A TO 13A 1WAY | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 11174 | 13A 6WAY | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 11174 | 13A 6WAY | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 11176 | 13A CABLE 5M | 17/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 11176 | 13A CABLE 5M | 17/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 11265 | 15A TO 13A | 28/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 11265 | 15A TO 13A | 28/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 11269 | 15A 10M CABLE | 18/05/22 | P | P | P 0.79 | P >99.9 | S | P 0.10 | PASS |
| 11269 | 15A CABLE 10M | 24/03/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 11309 | POWERCON TO 13A | 22/03/23 | P | P | P 0.33 | S | S | P 0.10 | PASS |
| 11321 | 13A IEC | 21/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 11321 | 13A IEC | 21/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 11322 | | 07/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 11323 | POWERCON LOOM 2M | 22/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 11327 | POWERCON LOOM 2M | 22/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 11357 | 13A IEC | 21/02/23 | P | P | P 0.38 | S | S | P 0.10 | PASS |
| 11357 | 13A IEC | 21/02/23 | P | P | P 0.38 | S | S | P 0.10 | PASS |
| 11363 | 13A IEC | 28/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 11363 | 13A IEC | 28/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 11365 | 13A IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 11365 | 13A IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 11371 | 13A 4WAY | 18/01/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 11371 | 13A 4WAY | 18/01/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 11463 | 13A 2 WAY | 22/03/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |
| 11468 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|----------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 11468 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 11469 | 32A 1PH - 16A 1PH CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 11469 | 32A 1PH - 16A 1PH CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 11476 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 11476 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 11566 | 16A CABLE 10M | 20/02/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 11566 | 16A CABLE 10M | 20/02/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 11599 | 13A IEC | 21/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 11599 | 13A IEC | 21/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 11701 | 13A 6WAY | 28/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 11701 | 13A 6WAY | 28/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 11702 | 13A 6WAY | 17/01/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 11702 | 13A 6WAY | 17/01/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 11706 | 13A 6WAY | 18/01/23 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 11706 | 13A 6WAY | 18/01/23 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 11711 | 13A 6WAY | 18/01/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 11711 | 13A 6WAY | 18/01/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 11714 | 13A 6WAY | 18/01/23 | P | P | P 0.33 | S | S | P 0.10 | PASS |
| 11714 | 13A 6WAY | 18/01/23 | P | P | P 0.33 | S | S | P 0.10 | PASS |
| 11717 | 13A 6WAY | 18/01/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 11717 | 13A 6WAY | 18/01/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 11721 | 13A 6WAY | 18/01/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 11721 | 13A 6WAY | 18/01/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 11727 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 11727 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 11745 | 13A TO 16A | 22/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 11747 | 13A CABLE 10M | 17/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 11747 | 13A CABLE 10M | 17/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 11749 | 13A CABLE 10M | 17/01/23 | P | P | P 0.41 | P >99.9 | S | P 0.10 | PASS |
| 11749 | 13A CABLE 10M | 17/01/23 | P | P | P 0.41 | P >99.9 | S | P 0.10 | PASS |
| 11795 | 13A CABLE 10M | 17/01/23 | P | P | P 0.39 | P >99.9 | S | P 0.10 | PASS |
| 11795 | 13A CABLE 10M | 17/01/23 | P | P | P 0.39 | P >99.9 | S | P 0.10 | PASS |
| 11812 | POWERCON LINK 5M | 22/03/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 11813 | POWERCON LINK 5M | 22/03/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 11816 | POWERCON LINK 5M | 22/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 11817 | POWERCON LINK 5M | 22/03/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 11818 | POWERCON LINK 5M | 22/03/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 11830 | 13A 32A 1P | 07/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 11860 | 13A CABLE REEL 10M | 02/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 11860 | 13A CABLE REEL 10M | 02/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 11873 | 32A1PH W/TWIN 13A 5M CABLE | 23/02/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 11873 | 32A 1PH CABLE 5M | 23/02/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 11909 | 13A CABLE 10M | 17/01/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 11909 | 13A CABLE 10M | 17/01/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 11912 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 11912 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 11946 | | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 11949 | | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 11953 | 16A TO 15A | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 11953 | 16A TO 15A | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 11955 | 32A 3PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 11955 | 32A 3PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 12033 | 16A TO 15A | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 12033 | 16A TO 15A | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 12035 | 13A TO 15A | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 12035 | 13A TO 15A | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 12102 | 16A CABLE 10M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 12102 | 16A CABLE 10M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 12125 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 12125 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 12129 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 12129 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 12130 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 12130 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 12136 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 12136 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 12137 | 13A CABLE 10M | 28/02/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 12137 | 13A CABLE 10M | 28/02/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 12144 | 13A TO 16A | 20/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 12144 | 13A TO 16A | 20/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 12146 | 13A TO 15A | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 12146 | 13A TO 15A | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 12155 | 32A1PH 16A1PH CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 12155 | 32A1PH 16A1PH | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 12158 | 16A 1PH 32A 1PH CABLE | 21/02/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 12158 | 16A 1PH - 32A 1PH | 21/02/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 12162 | 16A TO 15A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 12162 | 16A TO 15A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 12188 | 13A IEC | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 12188 | 13A IEC | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 12248 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 12248 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 12249 | 16A IEC | 21/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 12249 | 16A IEC | 21/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 12258 | 13A 10M CABLE | 24/02/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 12258 | 13A CABLE 10M | 24/02/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 12259 | 16A T LINE TO POWERCON | 16/03/23 | P | P | P 0.34 | S | S | P 0.10 | PASS |
| 12263 | 16A TLINE PC | 01/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 12263 | 16A TLINE PC | 01/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 12264 | 16A T LINE TO POWERCON | 16/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 12267 | 13A IEC | 28/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 12267 | 13A IEC | 28/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 12269 | 32 / 3P ISOLATOR SWITCH | 18/05/22 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 12271 | 13A 4WAY | 17/01/23 | P | P | P 0.52 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 12271 | 13A 4WAY | 17/01/23 | P | P | P 0.52 | S | S | P 0.10 | PASS |
| 12277 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 12277 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 12278 | | 07/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 12280 | 13A CABLE 3M | 19/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 12280 | 13A CABLE 3M | 19/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 12284 | 13A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 12284 | 13A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 12285 | 15A GRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 12285 | 15A GRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 12287 | | 07/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 12289 | POWERCON LINK 5M | 22/03/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 12304 | M7 STAGE RACKK | 06/03/23 | P | S | P 0.21 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 12305 | 15A GRELCO | 01/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 12305 | 15A GRELCO | 01/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 12305 | 15A GRELCO | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 12305 | 15A GRELCO | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 12306 | 15A IEC | 20/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 12306 | 15A IEC | 20/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 12357 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 12357 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 12382 | 16A T LINE TO POWERCON | 16/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 12384 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 12384 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 12385 | 13A CABLE 20M | 17/01/23 | P | P | P 0.51 | P >99.9 | S | P 0.10 | PASS |
| 12385 | 13A CABLE 20M | 17/01/23 | P | P | P 0.51 | P >99.9 | S | P 0.10 | PASS |
| 12387 | 13A 6WAY | 17/01/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 12387 | 13A 6WAY | 17/01/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 12417 | 15A GRLECO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 12417 | 15A GRLECO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 12417 | 15A GRLECO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 12417 | 15A GRLECO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 12484 | 16A T LINE TO POWERCON | 16/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 12485 | 16A TLINE PC | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 12485 | 16A TLINE PC | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 12512 | ROBE POINTE | 28/02/23 | P | S | P 0.14 | P >99.9 | P 0.14 | P 0.26 | PASS |
| 12512 | ROBE POINTE | 28/02/23 | P | S | P 0.14 | P >99.9 | P 0.14 | P 0.26 | PASS |
| 12544 | 13A TO 15A | 01/03/23 | P | P | P 0.52 | S | S | P 0.10 | PASS |
| 12544 | 13A TO 15A | 01/03/23 | P | P | P 0.52 | S | S | P 0.10 | PASS |
| 12554 | 16A TRELCO | 02/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 12554 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 12554 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 12554 | 16A TRELCO | 02/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 12554 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 12554 | 16A TRELCO | 02/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 12554 | 16A TRELCO | 02/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 12554 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 12622 | 63A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 12622 | 63A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 12625 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 12625 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 12627 | POWERCON LOOM 2M | 24/03/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 12628 | POWERCON LOOM 2M | 24/03/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 12629 | POWERCON LOOM 2M | 24/03/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 12630 | POWERCON LOOM 2M | 24/03/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 12661 | 15A IEC | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 12661 | 15A IEC | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 12662 | 15A IEC | 20/02/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 12662 | 15A IEC | 20/02/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 12663 | 13A TO 15A | 20/02/23 | P | P | P 0.61 | S | S | P 0.10 | PASS |
| 12663 | 13A TO 15A | 20/02/23 | P | P | P 0.61 | S | S | P 0.10 | PASS |
| 12671 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 12671 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 12718 | 13A IEC | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 12718 | 13A IEC | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 12720 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 12720 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 12723 | 13A IEC | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 12723 | 13A IEC | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 12724 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 12724 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 12724 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 12724 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 12724 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 12724 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 12724 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 12735 | | 07/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 12738 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 12738 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 12743 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 12743 | 16A CABLE 5M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 12743 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 12743 | 16A CABLE 5M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 12745 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 12745 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 12747 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 12747 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 12749 | 16A TO 32A 1PH | 01/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 12749 | 16A TO 32A 1PH | 01/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 12753 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 12753 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 12754 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 12754 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 12756 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 12756 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-------------------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 12758 | 15A CABLE 5M | 22/03/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 12761 | 15A GRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 12761 | 15A GRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 12761 | 15A GRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 12761 | 15A GRELCO | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 12800 | 16A IEC | 28/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 12800 | 16A IEC | 28/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 12809 | 13A IEC | 21/02/23 | P | P | P 0.34 | S | S | P 0.10 | PASS |
| 12809 | 13A IEC | 21/02/23 | P | P | P 0.34 | S | S | P 0.10 | PASS |
| 12832 | 13A TO 16A | 25/01/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 12832 | 13A TO 16A | 25/01/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 12834 | 13A CABLE 10M | 17/01/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 12834 | 13A CABLE 10M | 17/01/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 12835 | 13A TO 16A | 22/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 12838 | 16A CABLE 3M | 19/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 12838 | 16A CABLE 3M | 19/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 12859 | 13A IEC | 28/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 12859 | 13A IEC | 28/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 12886 | 15A GRELCO | 01/03/23 | P | P | P 0.70 | S | S | P 0.10 | PASS |
| 12886 | 15A GRELCO | 01/03/23 | P | P | P 0.70 | S | S | P 0.10 | PASS |
| 12895 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 12895 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 12928 | 13A IEC | 21/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 12928 | 13A IEC | 21/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 12929 | 13A IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 12929 | 13A IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 12939 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 12939 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 12962 | 16A CABLE 5M | 24/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 12962 | 16A CABLE 5M | 24/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 12963 | 13A 4WAY | 17/01/23 | P | P | P 0.29 | S | S | P 0.10 | PASS |
| 12963 | 13A 4WAY | 17/01/23 | P | P | P 0.29 | S | S | P 0.10 | PASS |
| 12975 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 12975 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 12984 | 13A IEC | 21/02/23 | P | P | P 0.29 | S | S | P 0.10 | PASS |
| 12984 | 13A IEC | 21/02/23 | P | P | P 0.29 | S | S | P 0.10 | PASS |
| 12988 | 13A IEC | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 12988 | 13A IEC | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 13001 | 15A 5M | 07/03/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 13105 | 13A CABLE REEL 25M RED | 03/03/23 | P | P | P 0.46 | S | S | P 0.14 | PASS |
| 13105 | 13A CABLE REEL 25M RED | 03/03/23 | P | P | P 0.46 | S | S | P 0.14 | PASS |
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.32 | S | S | P 2.77 | PASS |
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.27 | S | S | P 2.76 | PASS |
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.29 | S | S | P 2.77 | PASS |
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.26 | S | S | P 2.77 | PASS |
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.26 | S | S | P 2.76 | PASS |
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.25 | S | S | P 2.77 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-------------------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.25 | S | S | P 2.77 | PASS |
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.26 | S | S | P 2.77 | PASS |
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.30 | S | S | P 2.75 | PASS |
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.37 | S | S | P 2.76 | PASS |
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.20 | S | S | P 2.77 | PASS |
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.26 | S | S | P 2.76 | PASS |
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.28 | S | S | P 2.76 | PASS |
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.21 | S | S | P 2.76 | PASS |
| 13133 | 63 / 3P - 9 X 32 / 1P + 9 X 16 RCBO | 18/05/22 | P | P | P 0.23 | S | S | P 2.75 | PASS |
| 13233 | 13A 6WAY | 28/02/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 13233 | 13A 6WAY | 28/02/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 13234 | 16A TO 13A 4WAY | 22/08/22 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 13234 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 13234 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 13237 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 13237 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 13238 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 13238 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 13254 | NEXUS 4X4 | 01/03/23 | P | S | P 0.11 | P >99.9 | P <0.05 | P 0.24 | PASS |
| 13254 | NEXUS 4X4 | 01/03/23 | P | S | P 0.11 | P >99.9 | P <0.05 | P 0.24 | PASS |
| 13257 | NEXUS 4X4 | 01/03/23 | P | S | P 0.14 | P >99.9 | P <0.05 | P 0.22 | PASS |
| 13257 | NEXUS 4X4 | 01/03/23 | P | S | P 0.14 | P >99.9 | P <0.05 | P 0.22 | PASS |
| 13324 | 13A CABLE 10M | 28/02/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 13324 | 13A CABLE 10M | 28/02/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 13331 | AVOLITES QUARTZ | 01/03/23 | P | S | P 0.18 | P >99.9 | P <0.05 | P 0.17 | PASS |
| 13331 | AVOLITES QUARTZ | 01/03/23 | P | S | P 0.18 | P >99.9 | P <0.05 | P 0.17 | PASS |
| 13382 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 13382 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 13401 | 13A 6WAY | 18/01/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 13401 | 13A 6WAY | 18/01/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 13408 | 13A CABLE REEL 50M GREY | 02/03/23 | P | P | P 0.82 | S | S | P 0.22 | PASS |
| 13408 | 13A CABLE REEL 50M GREY | 02/03/23 | P | P | P 0.82 | S | S | P 0.22 | PASS |
| 13410 | 13A CABLE REEL GREY 50M | 02/03/23 | P | P | P 1.08 | S | S | P 0.22 | PASS |
| 13410 | 13A CABLE REEL GREY 50M | 02/03/23 | P | P | P 1.08 | S | S | P 0.22 | PASS |
| 13438 | 13A 4WAY | 28/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 13438 | 13A 4WAY | 28/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 13441 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 13441 | 16A TO 13A 4WAU | 20/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 13443 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 13443 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 13445 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 13445 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 13445 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 13445 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 13445 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 13445 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 13456 | 13A 2 WAY 10M | 22/03/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

| Key P = PASS / F = FAIL / S = SKIP (or test not applicable) | | | | | | | | | | |
|---|--|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|--|
| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status | |
| 13457 | 13A CABLE REEL 25M BLUE | 02/03/23 | P | P | P 0.41 | S | S | P 0.11 | PASS | |
| 13457 | 13A CABLE REEL 25M BLUE | 02/03/23 | P | P | P 0.41 | S | S | P 0.11 | PASS | |
| 13460 | 16A TLINE TO 13A 2WAY | 26/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS | |
| 13460 | 16A TLINE TO 13A 2WAY BLACK | 26/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS | |
| 13513 | YAMAHA MG124CX PSU | 06/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS | |
| 13785 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS | |
| 13785 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS | |
| 13785 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS | |
| 13785 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS | |
| 13785 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS | |
| 13785 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS | |
| 13795 | DBX GRAPHIC EQ | 06/03/23 | P | S | P 0.16 | P >99.9 | P <0.05 | P 0.10 | PASS | |
| 13796 | DBX GRAPHIC EQ | 06/03/23 | P | S | P 0.24 | P >99.9 | P <0.05 | P 0.10 | PASS | |
| 13824 | 63A /1P THRU - 2 X 32A + 4 X 16A MCB | 13/05/22 | P | P | P 0.20 | S | S | P 0.10 | PASS | |
| 13824 | 63A /1P THRU - 2 X 32A + 4 X 16A MCB | 13/05/22 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 13824 | 63A /1P THRU - 2 X 32A + 4 X 16A MCB | 13/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS | |
| 13824 | 63A /1P THRU - 2 X 32A + 4 X 16A MCB | 13/05/22 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 13824 | 63A /1P THRU - 2 X 32A + 4 X 16A MCB | 13/05/22 | P | P | P 0.21 | S | S | P 0.10 | PASS | |
| 13824 | 63A /1P THRU - 2 X 32A + 4 X 16A MCB | 13/05/22 | P | P | P 0.20 | S | S | P 0.10 | PASS | |
| 13825 | 63 / 1P RCD - 3 X 32 /1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS | |
| 13825 | 63 / 1P RCD - 3 X 32 /1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS | |
| 13825 | 63 / 1P RCD - 3 X 32 /1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS | |
| 13825 | 63 / 1P RCD - 3 X 32 /1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS | |
| 13825 | 63 / 1P RCD - 3 X 32 /1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS | |
| 13825 | 63 / 1P RCD - 3 X 32 /1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS | |
| 13825 | 63 / 1P RCD - 3 X 32 /1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS | |
| 13825 | 63 / 1P RCD - 3 X 32 /1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS | |
| 13825 | 63 / 1P RCD - 3 X 32 /1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS | |
| 13825 | 63 / 1P RCD - 3 X 32 /1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS | |
| 13826 | 63 / 1P THRU - 2 X 32 / 1P RCBO + 4 X 16 RCBO | 09/05/22 | P | P | P 0.21 | S | S | P 0.10 | PASS | |
| 13826 | 63 / 1P THRU - 2 X 32 / 1P RCBO + 4 X 16 RCBO | 09/05/22 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 13826 | 63 / 1P THRU - 2 X 32 / 1P RCBO + 4 X 16 RCBO | 09/05/22 | P | P | P 0.18 | S | S | P 0.10 | PASS | |
| 13826 | 63 / 1P THRU - 2 X 32 / 1P RCBO + 4 X 16 RCBO | 09/05/22 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 13826 | 63 / 1P THRU - 2 X 32 / 1P RCBO + 4 X 16 RCBO | 09/05/22 | P | P | P 0.18 | S | S | P 0.10 | PASS | |
| 13826 | 63 / 1P THRU - 2 X 32 / 1P RCBO + 4 X 16 RCBO | 09/05/22 | P | P | P 0.26 | S | S | P 0.10 | PASS | |
| 13827 | 63 / 1P RCD - 3 X 32 / 1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS | |
| 13827 | 63 / 1P RCD - 3 X 32 / 1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS | |
| 13827 | 63 / 1P RCD - 3 X 32 / 1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS | |

APPLIANCE DETAILS AND TEST RESULTS

| Key P = PASS / F = FAIL / S = SKIP (or test not applicable) | | | | | | | | | | |
|---|--|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|--|
| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (KVA) | Leakage (mA) | Overall Status | |
| 13827 | 63 / 1P RCD - 3 X 32 / 1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS | |
| 13827 | 63 / 1P RCD - 3 X 32 / 1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS | |
| 13827 | 63 / 1P RCD - 3 X 32 / 1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS | |
| 13827 | 63 / 1P RCD - 3 X 32 / 1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS | |
| 13827 | 63 / 1P RCD - 3 X 32 / 1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS | |
| 13827 | 63 / 1P RCD - 3 X 32 / 1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS | |
| 13827 | 63 / 1P RCD - 3 X 32 / 1P (MCB) + 7 X 16 (MCB) | 09/05/22 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS | |
| 13954 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS | |
| 13954 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS | |
| 13954 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS | |
| 13954 | DOUGHTY MUSIC STAND | 03/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS | |
| 13957 | W-DMX | 01/03/23 | P | S | P 0.18 | P >99.9 | P <0.05 | P 0.10 | PASS | |
| 13957 | W-DMX | 01/03/23 | P | S | P 0.18 | P >99.9 | P <0.05 | P 0.10 | PASS | |
| 13970 | W-DMX | 01/03/23 | P | S | P 0.15 | P 62.81 | P <0.05 | P 0.10 | PASS | |
| 13970 | W-DMX | 01/03/23 | P | S | P 0.15 | P 62.81 | P <0.05 | P 0.10 | PASS | |
| 13971 | W-DMX | 01/03/23 | P | S | P 0.17 | P >99.9 | P <0.05 | P 0.10 | PASS | |
| 13971 | W-DMX | 01/03/23 | P | S | P 0.17 | P >99.9 | P <0.05 | P 0.10 | PASS | |
| 14069 | 15A 5M | 07/03/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS | |
| 14104 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 14104 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 14106 | 13A IEC | 06/03/23 | P | P | P 0.07 | S | S | P 0.10 | PASS | |
| 14109 | 13A IEC | 21/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS | |
| 14109 | 13A IEC | 21/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS | |
| 14112 | 13A IEC | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS | |
| 14112 | 13A IEC | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS | |
| 14114 | 13A IEC | 21/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS | |
| 14114 | 13A IEC | 21/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS | |
| 14150 | 32A 3PH L1/L2 REVERSE | 24/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS | |
| 14150 | 32A 3PH L1/L2 REVERSE | 24/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS | |
| 14151 | 16A TO 32A | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS | |
| 14153 | 16A 3PH CABLE 10M | 06/03/23 | P | P | P 0.39 | P >99.9 | S | P 0.10 | PASS | |
| 14167 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS | |
| 14167 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS | |
| 14174 | | 07/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS | |
| 14184 | 13A PC | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 14184 | 13A PC | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 14187 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS | |
| 14187 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS | |
| 14187 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS | |
| 14187 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS | |
| 14188 | 16A CABLE 3M | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS | |
| 14188 | 16A CABLE 3M | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS | |
| 14189 | 13A IEC | 06/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS | |
| 14193 | 16A T LINE TO POWERCON | 16/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS | |

APPLIANCE DETAILS AND TEST RESULTS

| Key P = PASS / F = FAIL / S = SKIP (or test not applicable) | | | | | | | | | | |
|---|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|--|
| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status | |
| 14201 | 16A CABLE 3M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS | |
| 14201 | 16A CABLE 3M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS | |
| 14209 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 14209 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS | |
| 14209 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 14209 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS | |
| 14229 | 13A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS | |
| 14229 | 13A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS | |
| 14236 | TAILS TO 63A 1PH | 03/03/23 | P | S | S | S | S | S | PASS | |
| 14236 | TAILS TO 63A1PH | 03/03/23 | P | S | S | S | S | S | PASS | |
| 14255 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS | |
| 14255 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS | |
| 14259 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 14259 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 14261 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.20 | S | S | P 0.10 | PASS | |
| 14261 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.20 | S | S | P 0.10 | PASS | |
| 14263 | | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS | |
| 14264 | 13A IEC | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS | |
| 14264 | 13A IEC | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS | |
| 14265 | 16A TLINE IEC | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS | |
| 14265 | 16A TLINE IEC | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS | |
| 14266 | TAILS TO 32A 1PH | 03/03/23 | P | S | S | S | S | S | PASS | |
| 14266 | TAILS TO 32A 1PH | 03/03/23 | P | S | S | S | S | S | PASS | |
| 14269 | 13A IEC | 06/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS | |
| 14286 | 13A CABLE 10M | 17/01/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS | |
| 14286 | 13A CABLE 10M | 17/01/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS | |
| 14289 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS | |
| 14289 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS | |
| 14292 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS | |
| 14292 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS | |
| 14293 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS | |
| 14293 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS | |
| 14294 | 16A CABLE 10M | 19/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS | |
| 14294 | 16A CABLE 10M | 19/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS | |
| 14295 | 16A CABLE 10M | 19/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS | |
| 14295 | 16A CABLE 10M | 19/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS | |
| 14296 | 16A CABLE 10M | 19/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS | |
| 14296 | 16A CABLE 10M | 19/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS | |
| 14297 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS | |
| 14297 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS | |
| 14299 | 16A CABLE 5M | 19/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS | |
| 14299 | 16A CABLE 5M | 19/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS | |
| 14300 | 16A CABLE 10M | 23/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS | |
| 14300 | 16A CABLE 10M | 23/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS | |
| 14301 | 15A 5M | 07/03/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS | |
| 14302 | 13A CABLE 10M | 17/01/23 | P | P | P 0.49 | P >99.9 | S | P 0.10 | PASS | |
| 14302 | 13A CABLE 10M | 17/01/23 | P | P | P 0.49 | P >99.9 | S | P 0.10 | PASS | |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 14305 | 15A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 14305 | 15A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 14307 | 16A CABLE 5M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 14307 | 16A CABLE 5M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 14310 | 13A IEC | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 14310 | 13A IEC | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 14313 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14313 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14314 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14314 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14316 | 16A CABLE 10M | 19/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14316 | 16A CABLE 10M | 19/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14317 | 16A CABLE 10M | 19/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |
| 14317 | 16A CABLE 10M | 19/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |
| 14322 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 14322 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 14330 | 16A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 14330 | 16A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 14348 | 13A - 16A BLACK | 24/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 14348 | 13A - 16A BLACK | 24/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 14349 | 13A IEC | 06/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 14353 | 13A IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 14353 | 13A IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 14354 | 13A IEC | 06/03/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 14355 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 14355 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 14384 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 14384 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 14385 | 15A 3M | 07/03/23 | P | P | P 0.40 | P >99.9 | S | P 0.10 | PASS |
| 14387 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.33 | PASS |
| 14387 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.33 | PASS |
| 14388 | 13A CABLE 10M | 17/01/23 | P | P | P 0.44 | P >99.9 | S | P 0.10 | PASS |
| 14388 | 13A CABLE 10M | 17/01/23 | P | P | P 0.44 | P >99.9 | S | P 0.10 | PASS |
| 14391 | 16A TLINE PC | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 14391 | 16A TLINE PC | 01/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 14403 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 14403 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 14404 | 16A TLINE TO PC | 28/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 14404 | 16A TLINE TO PC | 28/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 14405 | 16A TLINE TO PC | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 14405 | 16A TLINE TO PC | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 14411 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 14411 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 14419 | POWERCON LOOM 2M | 22/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 14423 | 15A CABLE 5M | 22/03/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 14425 | 16A CABLE 10M | 23/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 14425 | 16A CABLE 10M | 23/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 14426 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 14426 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 14428 | 15A CABLE 20M | 22/03/23 | P | P | P 0.44 | P >99.9 | S | P 0.10 | PASS |
| 14429 | 15A CABLE 20M | 22/03/23 | P | P | P 0.54 | P >99.9 | S | P 0.10 | PASS |
| 14430 | 15A CABLE 20M | 22/03/23 | P | P | P 0.40 | P >99.9 | S | P 0.10 | PASS |
| 14437 | 32 / 3P CABLE 10M | 19/05/22 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 14449 | 13A 6WAY | 18/01/23 | P | P | P 0.33 | S | S | P 0.11 | PASS |
| 14449 | 13A 6WAY | 18/01/23 | P | P | P 0.33 | S | S | P 0.11 | PASS |
| 14466 | 13A IEC | 06/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 14467 | | 07/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 14468 | 16A CABLE 3M | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 14468 | 16A CABLE 3M | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 14469 | 16A PLUG SOCA SPIDER | 28/06/22 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 14469 | 16A PLUG SOCA SPIDER | 28/06/22 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 14469 | 16A PLUG SOCA SPIDER | 28/06/22 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 14469 | 16A PLUG SOCA SPIDER | 28/06/22 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 14469 | 16A PLUG SOCA SPIDER | 28/06/22 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 14469 | 16A PLUG SOCA SPIDER | 28/06/22 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 14471 | 16A CABLE 5M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 14471 | 16A CABLE 5M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 14479 | 16A TLINE TO PC | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 14479 | 16A TLINE TO PC | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 14486 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 14486 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 14490 | | 07/03/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 14492 | | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 14494 | | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 14513 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 14513 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 14514 | 13A IEC | 21/02/23 | P | P | P 0.41 | S | S | P 0.10 | PASS |
| 14514 | 13A IEC | 21/02/23 | P | P | P 0.41 | S | S | P 0.10 | PASS |
| 14515 | 13A IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 14515 | 13A IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 14516 | 16A CABLE 10M | 19/01/23 | P | P | P 0.39 | P >99.9 | S | P 0.10 | PASS |
| 14516 | 16A CABLE 10M | 19/01/23 | P | P | P 0.39 | P >99.9 | S | P 0.10 | PASS |
| 14518 | 16A CABLE 3M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 14518 | 16A CABLE 3M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 14519 | 16A CABLE 5M | 18/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14519 | 16A CABLE 5M | 18/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14520 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.12 | PASS |
| 14520 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.12 | PASS |
| 14555 | 13A IEC | 07/03/23 | P | P | P 0.10 | P >99.9 | S | P 0.10 | PASS |
| 14558 | 13A PC | 01/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 14558 | 13A PC | 01/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 14575 | 16A CABLE 20M | 24/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.18 | PASS |
| 14575 | 16A CABLE 20M | 24/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.18 | PASS |
| 14576 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.17 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (KVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 14576 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.17 | PASS |
| 14577 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.17 | PASS |
| 14577 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.17 | PASS |
| 14578 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.17 | PASS |
| 14578 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.17 | PASS |
| 14579 | 16A CABLE 20M | 24/01/23 | P | P | P 0.32 | P 47.45 | S | P 0.17 | PASS |
| 14579 | 16A CABLE 20M | 24/01/23 | P | P | P 0.32 | P 47.45 | S | P 0.17 | PASS |
| 14581 | 16A CABLE 20M | 22/03/23 | P | P | P 0.28 | P >99.9 | S | P 0.15 | PASS |
| 14582 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.18 | PASS |
| 14582 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.18 | PASS |
| 14584 | 16A CABLE 20M | 24/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.19 | PASS |
| 14584 | 16A CABLE 20M | 24/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.19 | PASS |
| 14589 | 16A CABLE 20M | 24/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.17 | PASS |
| 14589 | 16A CABLE 20M | 24/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.17 | PASS |
| 14590 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.17 | PASS |
| 14590 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.17 | PASS |
| 14591 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.17 | PASS |
| 14591 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.17 | PASS |
| 14592 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.17 | PASS |
| 14592 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.17 | PASS |
| 14593 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.18 | PASS |
| 14593 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.18 | PASS |
| 14596 | 16A CABLE 20M | 23/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.18 | PASS |
| 14596 | 16A CABLE 20M | 23/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.18 | PASS |
| 14597 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.17 | PASS |
| 14597 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.17 | PASS |
| 14598 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.18 | PASS |
| 14598 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.18 | PASS |
| 14600 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.17 | PASS |
| 14600 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.17 | PASS |
| 14601 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.17 | PASS |
| 14601 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.17 | PASS |
| 14602 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.17 | PASS |
| 14602 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.17 | PASS |
| 14603 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.17 | PASS |
| 14603 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.17 | PASS |
| 14605 | 16A CABLE 20M | 28/02/23 | P | P | P 0.25 | P >99.9 | S | P 0.17 | PASS |
| 14605 | 16A CABLE 20M | 28/02/23 | P | P | P 0.25 | P >99.9 | S | P 0.17 | PASS |
| 14606 | 16A CABLE 20M | 28/02/23 | P | P | P 0.25 | P >99.9 | S | P 0.16 | PASS |
| 14606 | 16A CABLE 20M | 28/02/23 | P | P | P 0.25 | P >99.9 | S | P 0.16 | PASS |
| 14608 | 16A CABLE 20M | 24/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.18 | PASS |
| 14608 | 16A CABLE 20M | 24/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.18 | PASS |
| 14611 | 16A CABLE 20M | 24/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.17 | PASS |
| 14611 | 16A CABLE 20M | 24/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.17 | PASS |
| 14612 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.17 | PASS |
| 14612 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.17 | PASS |
| 14614 | 16A CABLE 10M | 19/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (KVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 14614 | 16A CABLE 10M | 19/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14615 | 16A CABLE 10M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 14615 | 16A CABLE 10M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 14616 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14616 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14618 | 16A CABLE 5M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 14618 | 16A CABLE 5M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 14619 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14619 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14620 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 14620 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 14621 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 14621 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 14622 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14622 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14624 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 14624 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 14626 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14626 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14627 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14627 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14628 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14628 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14629 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14629 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14630 | 16A CABLE 10M | 19/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |
| 14630 | 16A CABLE 10M | 19/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |
| 14631 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14631 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14645 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14645 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14646 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14646 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14647 | 16A CABLE 10M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14647 | 16A CABLE 10M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14648 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14648 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14649 | 16A CABLE 10M | 20/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14649 | 16A CABLE 10M | 20/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14650 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14650 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14651 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14651 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14652 | 16A CABLE 10M | 19/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14652 | 16A CABLE 10M | 19/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14653 | 16A CABLE 10M | 19/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |
| 14653 | 16A CABLE 10M | 19/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (KVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 14655 | 16A CABLE 10M | 19/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14655 | 16A CABLE 10M | 19/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14656 | 16A CABLE 10M | 20/02/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 14656 | 16A CABLE 10M | 20/02/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 14657 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14657 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14658 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14658 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14660 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14660 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14662 | 16A CABLE 10M | 20/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14662 | 16A CABLE 10M | 20/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14664 | 16A CABLE 10M | 19/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |
| 14664 | 16A CABLE 10M | 19/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |
| 14665 | 16A CABLE 10M | 19/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14665 | 16A CABLE 10M | 19/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14666 | 16A CABLE 10M | 20/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14666 | 16A CABLE 10M | 20/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14667 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14667 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14668 | 16A CABLE 10M | 19/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14668 | 16A CABLE 10M | 19/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14673 | | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14673 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14674 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14674 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14675 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14675 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14677 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14677 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14678 | 16A CABLE 10M | 19/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14678 | 16A CABLE 10M | 19/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14679 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14679 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14680 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14680 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 14682 | 16A CABLE 10M | 20/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14682 | 16A CABLE 10M | 20/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14683 | 16A CABLE 10M | 20/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14683 | 16A CABLE 10M | 20/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14685 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14685 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14722 | 15A CABLE 10M | 24/03/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 14723 | 15A CABLE 5M | 22/03/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 14724 | 15A CABLE 5M | 22/03/23 | P | P | P 0.39 | P >99.9 | S | P 0.10 | PASS |
| 14725 | 15A 5M | 07/03/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 14727 | 15A 5M | 07/03/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|--------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 14728 | 15A 5M | 07/03/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 14731 | 13A CABLE 20M | 17/01/23 | P | P | P 0.49 | P >99.9 | S | P 0.10 | PASS |
| 14731 | 13A CABLE 20M | 17/01/23 | P | P | P 0.49 | P >99.9 | S | P 0.10 | PASS |
| 14748 | 13A IEC | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 14748 | 13A IEC | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 14750 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 14750 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 14759 | 13A CABLE 10M | 17/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 14759 | 13A CABLE 10M | 17/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 14761 | 16A CABLE 3M | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 14761 | 16A CABLE 3M | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 14766 | 16A CABLE 10M | 23/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 14766 | 16A CABLE 10M | 23/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 14776 | TAILS TO 125A 3PH | 03/03/23 | P | S | S | S | S | S | PASS |
| 14776 | TAILS TO 125A 3PH | 03/03/23 | P | S | S | S | S | S | PASS |
| 14777 | LV MOTOR CABLE 20M | 06/03/23 | P | P | P 0.51 | P >99.9 | S | P 0.19 | PASS |
| 14794 | 32A 1PH 16A 1PH CAB GREL | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 14794 | 32A 1PH 16A 1PH CAB GREL | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 14794 | 32A 1PH 16A 1PH CAB GREL | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 14794 | 32A 1PH 16A 1PH CAB GREL | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 14795 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 14795 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 14798 | 13A IEC | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 14798 | 13A IEC | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 14799 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 14799 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 14800 | 16A 3PH CABLE 20M | 03/03/23 | P | P | P 0.56 | P >99.9 | S | P 0.11 | PASS |
| 14801 | 16A TO 13A 2WAY | 25/01/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 14801 | 16A TO 13A 2WAY BLACK | 25/01/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 14802 | 13A 16A | 07/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 14803 | 16A CABLE 3M | 20/01/23 | P | P | P 0.48 | P >99.9 | S | P 0.10 | PASS |
| 14803 | 16A CABLE 3M | 20/01/23 | P | P | P 0.48 | P >99.9 | S | P 0.10 | PASS |
| 14804 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 14804 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 14809 | 16A IEC | 28/02/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 14809 | 16A IEC | 28/02/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 14810 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 14810 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 14811 | 13A IEC | 21/02/23 | P | P | P 0.29 | S | S | P 0.10 | PASS |
| 14811 | 13A IEC | 21/02/23 | P | P | P 0.29 | S | S | P 0.10 | PASS |
| 14814 | 13A TO 15A | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 14814 | 13A TO 15A | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 14817 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 14817 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 14818 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 14818 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 14819 | 13A 6 WAY | 22/03/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 14821 | IEC 13A | 07/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 14834 | 16A IEC | 21/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 14834 | 16A IEC | 21/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 14835 | 16A CABLE 20M | 20/02/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 14835 | 16A CABLE 20M | 20/02/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 14836 | 15A CABLE 5M | 22/03/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 14837 | 15A GRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 14837 | 15A GRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 14837 | 15A GRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 14837 | 15A GRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 14850 | 13A IEC | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 14850 | 13A IEC | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 14851 | | 07/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 14852 | | 07/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 14855 | | 07/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 14856 | | 07/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 14873 | 16A T LINE TO POWERCON | 16/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 14876 | | 07/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 14877 | | 07/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 14878 | | 07/03/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 14880 | POWERCON TO 16A | 16/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 14884 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 14884 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 14885 | 16A TLINE TO PC | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 14885 | 16A TLINE TO PC | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 14887 | 16A TLINE PC | 01/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 14887 | 16A TLINE PC | 01/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 14899 | POWERCON LOOM 2M | 22/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 14900 | POWERCON LOOM 2M | 22/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 14901 | POWERCON LOOM 2M | 22/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 14902 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 14902 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 14906 | POWERCON LOOM 2M | 22/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 14907 | POWERCON LOOM 2M | 24/03/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 14917 | | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 14918 | | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 14919 | 16A TLINE TO PC | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 14919 | 16A TLINE TO PC | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15045 | POWERCON LOOMS 2M | 22/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15053 | POWERCON LOOM 2M | 22/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15054 | POWERCON LOOM 2M | 22/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15065 | 13A TO 16A | 25/01/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 15065 | 13A TO 16A | 25/01/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 15067 | 15A 5M | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15068 | 15A CABLE 20M | 22/03/23 | P | P | P 0.51 | P >99.9 | S | P 0.10 | PASS |
| 15069 | 15A CABLE 10M | 24/03/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 15070 | 15A CABLE 5M | 22/03/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 15071 | 15A 5M | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15072 | | 07/03/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 15072 | 15A 5M | 07/03/23 | P | S | S | S | S | S | PASS |
| 15076 | 15A 5M | 07/03/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15094 | 13A TO 16A | 20/02/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 15094 | 13A TO 16A | 20/02/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 15097 | 13A CABLE 1M | 17/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15097 | 13A CABLE 1M | 17/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15099 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 15099 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 15106 | 32A 3PH TO 2X 16A 3PH | 03/03/23 | P | S | S | S | S | S | PASS |
| 15107 | 13A 4WAY | 18/01/23 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 15107 | 13A 4WAY | 18/01/23 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 15108 | | 07/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15112 | LV MOTOR CABLE 20M | 06/03/23 | P | P | P 0.42 | P >99.9 | S | P 0.18 | PASS |
| 15115 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 15115 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 15116 | 16A CABLE 5M | 18/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 15116 | 16A CABLE 5M | 18/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 15121 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 15121 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 15122 | 16A CABLE 5M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15122 | 16A CABLE 5M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15123 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 15123 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 15124 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 15124 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 15126 | 15A IEC | 20/02/23 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 15126 | 15A IEC | 20/02/23 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 15128 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15128 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15129 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 15129 | 16A CABLE 5M | 18/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 15131 | 16A CABLE 10M | 20/02/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 15131 | 16A CABLE 10M | 20/02/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 15136 | 15A 3M | 07/03/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 15138 | 16A CABLE 3M | 19/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 15138 | 16A CABLE 3M | 19/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 15139 | 15A 3M | 07/03/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 15144 | 15A 3M | 07/03/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15147 | 15A 3M | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15154 | 15A 3M | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15155 | 16A TO 13A 4WAY | 06/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15162 | 16A CABLE 3M | 19/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 15162 | 16A CABLE 3M | 19/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 15164 | 15A 3M | 07/03/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 15168 | 15A 3M | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 15169 | 16A CABLE 3M | 19/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 15169 | 16A CABLE 3M | 19/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 15177 | 16A CABLE 3M | 03/03/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 15178 | 16A CABLE 3M | 23/01/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 15178 | 16A CABLE 3M | 23/01/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 15181 | 15A 3M | 07/03/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15182 | 15A 3M | 07/03/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15184 | 15A 3M | 07/03/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 15187 | 15A 3M | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15189 | 15A 1M | 07/03/23 | P | P | P 0.33 | P >99.9 | S | P 0.10 | PASS |
| 15193 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 15193 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 15194 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P 17.37 | S | P 0.10 | PASS |
| 15194 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P 17.37 | S | P 0.10 | PASS |
| 15195 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 15195 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 15206 | 15A 1M | 07/03/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 15207 | 15A 1M | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15208 | 15A 1M | 07/03/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 15209 | 15A 1M | 07/03/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15210 | 15A 1M | 07/03/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 15211 | 15A 1M | 07/03/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 15217 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 15217 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 15218 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15218 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15219 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15219 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15220 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15220 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15221 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15221 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15223 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15223 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15225 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 15225 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 15227 | 16A CABLE 3M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 15227 | 16A CABLE 3M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 15230 | 15A 1M | 07/03/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 15231 | 15A 1M | 07/03/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 15233 | 15A 1M | 07/03/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 15234 | 15A 1M | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15235 | 15A CABLE 20M | 22/03/23 | P | P | P 0.67 | P >99.9 | S | P 0.10 | PASS |
| 15236 | 15A CABLE 20M | 22/03/23 | P | P | P 0.50 | P >99.9 | S | P 0.11 | PASS |
| 15236 | 15A CABLE 20M | 24/03/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 15237 | 15A 20M | 07/03/23 | P | P | P 0.58 | P >99.9 | S | P 0.10 | PASS |
| 15240 | 15A CABLE 10M | 24/03/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 15244 | 15A CABLE 10M | 24/03/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 15248 | 13A TO 16A | 25/01/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 15248 | 13A TO 16A | 25/01/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 15249 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15249 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15255 | 15A CABLE 10M | 22/03/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 15255 | 15A CABLE 10M | 24/03/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 15258 | 15A CABLE 10M | 24/03/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 15261 | 15A CABLE 10M | 24/03/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 15269 | 15A CABLE 10M | 24/03/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 15279 | 15A CABLE 10M | 24/03/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 15285 | 15A CABLE 10M | 24/03/23 | P | P | P 0.95 | P >99.9 | S | P 0.10 | PASS |
| 15286 | 13A CABLE 5M | 17/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 15286 | 13A CABLE 5M | 17/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 15297 | 15A CABLE 10M | 22/03/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 15311 | 15A CABLE 10M | 24/03/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 15312 | 15A CABLE 10M | 24/03/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 15315 | 15A CABLE 10M | 24/03/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 15319 | 15A CABLE 10M | 24/03/23 | P | P | P 0.53 | P >99.9 | S | P 0.10 | PASS |
| 15320 | 15A CABLE 10M | 24/03/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 15322 | 15A CABLE 10M | 24/03/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15330 | 15A CABLE 10M | 24/03/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 15349 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 15349 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 15350 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15350 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 15350 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15350 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15350 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 15350 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15351 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15351 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15353 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 15353 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 15356 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15356 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15356 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15356 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15357 | 16A CABLE GRELCO | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15357 | 16A CABLE GRELCO | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15357 | 16A CABLE GRELCO | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15357 | 16A CABLE GRELCO | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15358 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15358 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 15358 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 15358 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15359 | 32A 1PH GRELCO | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS
Key
 P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|--------------------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 15359 | 32A 1PH GRELCO CABLE | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 15360 | 32 1PH TO 2X 16A | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 15360 | 32 1PH TO 2X 16A | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 15360 | 32 1PH TO 2X 16A | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 15360 | 32 1PH TO 2X 16A | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 15361 | 16A1PH 32A1PH CABLE | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 15361 | 16A1PH 32A1PH CABLE | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 15362 | 32A 1PH 16A 1PH CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15362 | 32A 1PH 16A 1PH CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15363 | 32A 1PH - 16A 1PH 32A 1PH THRU CABLE | 23/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15363 | 32A 1PH - 16A 1PH 32A 1PH THRU CABLE | 23/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15363 | 32A 1PH - 16A 1PH 32A 1PH THRU CABLE | 23/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15363 | 32A 1PH - 16A 1PH 32A 1PH THRU CABLE | 23/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15364 | 32A 1P GRELCO CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 15364 | 32A 1P GRELCO CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 15364 | 32A 1P GRELCO CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 15364 | 32A 1P GRELCO CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 15365 | 32A 1PH - 16A 1PH CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15365 | 32A 1PH - 16A 1PH CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15365 | 32A 1PH - 16A 1PH CABLE GRELCO | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15365 | 32A 1PH - 16A 1PH CABLE GRELCO | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15366 | 32 1PH TO 2X 16A | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15366 | 32 1PH TO 2X 16A | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15366 | 32 1PH TO 2X 16A | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15366 | 32 1PH TO 2X 16A | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15368 | 32A1PH 16A1PH | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 15368 | 32A1PH 16A1PH CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 15369 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 15369 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 15371 | 16A CABLE 20M | 24/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |
| 15371 | 16A CABLE 20M | 24/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |
| 15373 | 13A IEC | 21/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 15373 | 13A IEC | 21/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 15422 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15422 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15423 | 16A TO 13A | 06/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 15496 | 13A CABLE 10M | 28/02/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15496 | 13A CABLE 10M | 28/02/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15498 | 13A CABLE 10M | 17/01/23 | P | P | P 0.45 | P >99.9 | S | P 0.10 | PASS |
| 15498 | 13A CABLE 10M | 17/01/23 | P | P | P 0.45 | P >99.9 | S | P 0.10 | PASS |
| 15499 | 13A CABLE 10M | 17/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 15499 | 13A CABLE 10M | 17/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 15514 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15514 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15520 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15520 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15520 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 15520 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 15521 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15521 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15523 | 15A 5M | 07/03/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 15525 | 13A CABLE 5M | 28/02/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15525 | 13A CABLE 5M | 28/02/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15526 | 13A 4WAY | 17/01/23 | P | P | P 0.32 | S | S | P 0.10 | PASS |
| 15526 | 13A 4AY | 17/01/23 | P | P | P 0.32 | S | S | P 0.10 | PASS |
| 15528 | 16A TO 15A | 20/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 15528 | 16A TO 15A | 20/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 15529 | 16A CABLE 3M | 19/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 15529 | 16A CABLE 3M | 19/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 15530 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15530 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15531 | 16A - 32A 1PH | 07/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15533 | 13A CABLE 10M | 17/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 15533 | 13A CABLE 10M | 17/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 15534 | 13A CABLE 10M | 17/01/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 15534 | 13A CABLE 10M | 17/01/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 15542 | 32A 1PH CABLE 10M | 24/02/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 15542 | 32A 1PH 10M | 24/02/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 15543 | 32A 1PH CABLE 10M | 28/02/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15543 | 32A 1PH 10M | 28/02/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15546 | 16A CABLE 10M | 20/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 15546 | 16A CABLE 10M | 20/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 15549 | 16A CABLE 10M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 15549 | 16A CABLE 10M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 15550 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 15550 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 15551 | 16A CABLE 10M | 23/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 15551 | 16A CABLE 10M | 23/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 15552 | 63A 1PH TO 2X 32A 1PH | 03/03/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 15552 | 63A 1PH TO 2X 32A 1PH | 03/03/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 15552 | 63A 1PH TO 2X 32A 1PH | 03/03/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 15552 | 63A 1PH TO 2X 32A 1PH | 03/03/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 15576 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15576 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15576 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15576 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15577 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15577 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15577 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15577 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15578 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15578 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15578 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15578 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS
Key

P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|--------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 15579 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15579 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15579 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15579 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15580 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 15580 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 15582 | 16A GRLECO CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15582 | 16A GRLECO CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15582 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15582 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15583 | 32A 1PH 16A 1PH CAB GREL | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15583 | 32A 1PH 16A 1PH CAB GREL | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15583 | 32A 1PH 16A 1PH CAB GREL | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15583 | 32A 1PH 16A 1PH CAB GREL | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15584 | 16A CABLE GRELCO | 24/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15584 | 16A CABLE GRELCO | 24/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15584 | 16A CABLE GRELCO | 28/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15584 | 16A CABLE GRELCO | 28/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15623 | 13A IEC | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15623 | 13A IEC | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15625 | 13A IEC | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 15625 | 13A IEC | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 15630 | 63A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 15630 | 63A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 15636 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15636 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15636 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15636 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15637 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15637 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15637 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15637 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15638 | 16A TO 13A 4WAY | 28/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15638 | 16A TO 13A 4WAY BLACK | 28/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15639 | 16A TO 13A 4WAY BLACK | 25/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15639 | 16A TO 13A 4WAY | 25/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15670 | 32A 1PH CABLE 10M | 24/02/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 15670 | 32A 1PH 10M | 24/02/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 15671 | LV MOTOR CABLE 10M | 06/03/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15671 | LV MOTOR CABLE 10M | 06/03/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 15672 | LV MOTOR CABLE 10M | 06/03/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 15672 | LV MOTOR CABLE 10M | 03/03/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15673 | LV MOTOR CABLE 10M | 06/03/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 15673 | LV MOTOR CABLE 10M | 06/03/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 15674 | LV MOTOR CABLE 10M | 06/03/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 15674 | LV MOTOR CABLE 10M | 03/03/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 15676 | LV MOTOR CABLE 5M | 06/03/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

| Key P = PASS / F = FAIL / S = SKIP (or test not applicable) | | | | | | | | | | |
|---|--|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|--|
| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status | |
| 15676 | LV MOTOR CABLE 5M | 06/03/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS | |
| 15677 | LV MOTOR CABLE 5M | 06/03/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS | |
| 15677 | LV MOTOR CABLE 5M | 06/03/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS | |
| 15678 | LV MOTOR CABLE 5M | 06/03/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS | |
| 15678 | LV MOTOR CABLE 5M | 03/03/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS | |
| 15690 | 13A IEC 5M | 07/03/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS | |
| 15698 | 13A IEC 5M | 07/03/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS | |
| 15700 | 16A 3PH CABLE 10M | 06/03/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS | |
| 15701 | 16A 3PH CABLE 10M | 03/03/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS | |
| 15706 | IEC - POWERCON LOOM | 06/03/23 | P | P | P 0.26 | S | S | P 0.10 | PASS | |
| 15707 | IEC - POWERCON LOOM | 06/03/23 | P | P | P 0.30 | S | S | P 0.10 | PASS | |
| 15708 | IEC - POWERCON LOOM | 06/03/23 | P | P | P 0.25 | S | S | P 0.10 | PASS | |
| 15709 | IEC - POWERCON LOOM | 06/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS | |
| 15739 | 13A IEC | 21/02/23 | P | P | P 0.26 | S | S | P 0.10 | PASS | |
| 15739 | 13A IEC | 21/02/23 | P | P | P 0.26 | S | S | P 0.10 | PASS | |
| 15757 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS | |
| 15757 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS | |
| 15759 | 13A IEC | 06/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS | |
| 15770 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 15770 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 15774 | 16A 1PH 32A 1PH CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS | |
| 15774 | 16A 1PH - 32A 1PH | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS | |
| 15776 | 32A 1PH AND DUAL XLR LOOM | 06/03/23 | P | P | P 0.26 | P >99.9 | S | P 0.18 | PASS | |
| 15779 | TAILS TO 63A 3PH | 03/03/23 | P | S | S | S | S | S | PASS | |
| 15779 | TAILS TO 63A 3PH | 03/03/23 | P | S | S | S | S | S | PASS | |
| 15781 | 63 / 3P (THRU 100MA RCD) - 1 X 32 / 3P (30MA RCD) + 3 X 63 / 1P (30MA RCD) | 19/05/22 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS | |
| 15781 | 63 / 3P (THRU 100MA RCD) - 1 X 32 / 3P (30MA RCD) + 3 X 63 / 1P (30MA RCD) | 19/05/22 | P | P | P 0.41 | P >99.9 | S | P 0.10 | PASS | |
| 15781 | 63 / 3P (THRU 100MA RCD) - 1 X 32 / 3P (30MA RCD) + 3 X 63 / 1P (30MA RCD) | 19/05/22 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS | |
| 15781 | 63 / 3P (THRU 100MA RCD) - 1 X 32 / 3P (30MA RCD) + 3 X 63 / 1P (30MA RCD) | 19/05/22 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS | |
| 15785 | LV MOTOR CABLE 20M | 06/03/23 | P | P | P 0.42 | P >99.9 | S | P 0.20 | PASS | |
| 15786 | LV MOTOR CABLE 20M | 06/03/23 | P | P | P 0.48 | P >99.9 | S | P 0.20 | PASS | |
| 15789 | 63A 1PH TO 63A 3PH | 03/03/23 | P | P | P 0.30 | S | S | P 0.10 | PASS | |
| 15789 | 63A 1PH TO 63A 3PH | 03/03/23 | P | P | P 0.30 | S | S | P 0.10 | PASS | |
| 15791 | 63A 3PH TO 125A 3PH | 03/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS | |
| 15792 | 63A 3PH TO 125A 3PH | 03/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS | |
| 15794 | 63A 3PH TO 125A 3PH | 03/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS | |
| 15807 | 32A 1PH CABLE 3M | 23/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS | |
| 15807 | 32A 1PH 3M CABLE | 23/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS | |
| 15810 | TAILS TO 63A 3PH | 03/03/23 | P | S | S | S | S | S | PASS | |
| 15810 | TAILS TO 63A 3PH | 03/03/23 | P | S | S | S | S | S | PASS | |
| 15811 | TAILS TO 63A 3PH | 03/03/23 | P | S | S | S | S | S | PASS | |
| 15813 | 63A / 1P - 1 X 32A + 4 X 16A RCBO | 13/05/22 | P | P | P 0.11 | S | S | P 0.38 | PASS | |
| 15813 | 63A / 1P - 1 X 32A + 4 X 16A RCBO | 13/05/22 | P | P | P 0.21 | S | S | P 0.36 | PASS | |
| 15813 | 63A / 1P - 1 X 32A + 4 X 16A RCBO | 13/05/22 | P | P | P 0.16 | S | S | P 0.10 | PASS | |
| 15813 | 63A / 1P - 1 X 32A + 4 X 16A RCBO | 13/05/22 | P | P | P 0.18 | S | S | P 0.36 | PASS | |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (KVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 15813 | 63A / 1P - 1 X 32A + 4 X 16A RCBO | 13/05/22 | P | P | P 0.20 | S | S | P 0.34 | PASS |
| 15818 | 16A ISOLATOR SWITCH | 13/05/22 | P | P | P 0.36 | S | S | P 0.10 | PASS |
| 15820 | 16A ISOLATOR SWITCH | 13/05/22 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 15829 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15829 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15832 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 15832 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 15838 | 16A CABLE 30M | 24/01/23 | P | P | P 0.42 | P >99.9 | S | P 0.21 | PASS |
| 15838 | 16A CABLE 30M | 24/01/23 | P | P | P 0.42 | P >99.9 | S | P 0.21 | PASS |
| 15842 | 16A CABLE 30M | 24/01/23 | P | P | P 0.41 | P >99.9 | S | P 0.19 | PASS |
| 15842 | 16A CABLE 30M | 24/01/23 | P | P | P 0.41 | P >99.9 | S | P 0.19 | PASS |
| 15846 | 16A CABLE 30M | 24/01/23 | P | P | P 0.41 | P >99.9 | S | P 0.21 | PASS |
| 15846 | 16A CABLE 30M | 24/01/23 | P | P | P 0.41 | P >99.9 | S | P 0.21 | PASS |
| 15847 | 16A CABLE 30M | 24/01/23 | P | P | P 0.42 | P >99.9 | S | P 0.21 | PASS |
| 15847 | 16A CABLE 30M | 24/01/23 | P | P | P 0.42 | P >99.9 | S | P 0.21 | PASS |
| 15848 | 16A CABLE 20M | 20/02/23 | P | P | P 0.24 | P >99.9 | S | P 0.11 | PASS |
| 15848 | 16A CABLE 20M | 20/02/23 | P | P | P 0.24 | P >99.9 | S | P 0.11 | PASS |
| 15849 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 15849 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 15851 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.11 | PASS |
| 15851 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.11 | PASS |
| 15852 | 16A CABLE 20M | 24/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |
| 15852 | 16A CABLE 20M | 24/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |
| 15853 | 16A CABLE 20M | 24/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 15853 | 16A CABLE 20M | 24/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 15854 | 16A CABLE 20M | 28/02/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 15854 | 16A CABLE 20M | 28/02/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 15855 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.12 | PASS |
| 15855 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.12 | PASS |
| 15856 | 32A 1PH 10M | 24/02/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15856 | 32A 1PH CABLE 10M | 24/02/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15857 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.12 | PASS |
| 15857 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.12 | PASS |
| 15858 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.11 | PASS |
| 15858 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.11 | PASS |
| 15869 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15869 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15869 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15869 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15870 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15870 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15870 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15870 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15870 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15870 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15870 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15871 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15871 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 15880 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15880 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15880 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15882 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15882 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15883 | 16A TRELCO | 02/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 15883 | 16A TRELCO | 02/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 15883 | 16A TRELCO | 02/03/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 15883 | 16A TRELCO | 02/03/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 15883 | 16A TRELCO | 02/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 15883 | 16A TRELCO | 02/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 15884 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15884 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15884 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15884 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15884 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15884 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15885 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15885 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15885 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15885 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15885 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15885 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15885 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15886 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15886 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15886 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15886 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15886 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15886 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15886 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15886 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15886 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15887 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15887 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15887 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15887 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15888 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15888 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15888 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15888 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15888 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15888 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15888 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15889 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15889 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15889 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15889 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15889 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15890 | 13A CABLE 10M | 28/02/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 15890 | 13A CABLE 10M | 28/02/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 15904 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15904 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15904 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15904 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15904 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15904 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15906 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15906 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15906 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15906 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15906 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15906 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15906 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15906 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15906 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15908 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15908 | 16A TRELCO | 01/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 15908 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15908 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15908 | 16A TRELCO | 01/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 15908 | 16A TRELCO | 01/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 15908 | 16A TRELCO | 01/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 15908 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15911 | 16A IEC | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15911 | 16A IEC | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 15916 | 13A IEC | 01/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 15916 | 13A IEC | 01/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 15922 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15922 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15922 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15922 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15922 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15922 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15922 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15926 | 13A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 15926 | 13A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 15928 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15928 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15928 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15928 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15929 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15929 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15929 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15929 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15929 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15929 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15929 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15929 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 15930 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 15930 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15930 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15930 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15932 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15932 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15932 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15932 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15932 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15933 | 16A TRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15933 | 16A TRELCO | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 15934 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15934 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15934 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15934 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15934 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15934 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15935 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15935 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15935 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15935 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 15935 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15964 | 16A TLINE TO 16A | 25/01/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 15964 | 16A TLINE TO 16A | 25/01/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 15965 | 16A TLINE TO 16A | 25/01/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 15965 | 16A TLINE TO 16A | 25/01/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 15966 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15966 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15966 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15966 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15966 | 16A TRELCO | 02/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 15975 | 32A 3PH 1M | 24/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 15975 | 32A 3PH CABLE 1M | 24/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 15976 | 32A 3PH 3M | 24/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 15976 | 32A 1PH CABLE 3M | 24/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 15977 | 32A 3PH 5M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 15977 | 32A 1PH CABLE 5M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 15978 | 32A 3PH 5M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 15978 | 32A 1PH CABLE 5M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 15979 | 32A 3PH 5M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 15979 | 32A 1PH CABLE 5M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 15980 | 32A 3PH 5M | 22/03/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 15980 | 32 / 3P CABLE 5M | 19/05/22 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 15981 | 32A 3PH 5M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15981 | 32A 1PH CABLE 5M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15982 | 32A 3PH 5M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 15982 | 32A 1PH CABLE 5M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 15983 | 32A 1PH CABLE 5M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 15983 | 32A 3PH 5M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 15983 | 32A 3PH 5M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 15983 | 32A 1PH CABLE 5M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 15984 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15984 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 15984 | 32A1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15984 | 32A1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 15985 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 15985 | 32A1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 15986 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 15986 | 32A 1PH W/TWIN 13A 5M CABLE | 24/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 15986 | 32A 1PH W/TWIN 13A 5M CABLE | 24/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 15986 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 15987 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 15987 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.11 | P >99.9 | S | P 0.10 | PASS |
| 15987 | 32A1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15987 | 32A1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.11 | P >99.9 | S | P 0.10 | PASS |
| 15987 | 32A1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 15987 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15988 | 32A1PH W/TWIN 13A 5M CABLE | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15988 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15989 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 15989 | 32A 1PH W/TWIN 13A 5M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 15989 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15989 | 32A 1PH W/TWIN 13A 5M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15989 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 15989 | 32A 1PH W/TWIN 13A 5M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 15990 | 32A 1PH TWIN 13A CABLE 10M | 01/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15990 | 32A 1PH W/TWIN 13A | 01/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15991 | 32A 1PH W/TWIN 13A | 24/02/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 15991 | 32A 1PH W/TWIN 13A | 24/02/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 15991 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 15991 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 15991 | 32A 1PH W/TWIN 13A | 24/02/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 15991 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 15992 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 15992 | 32A 1PH W/TWIN 13A 5M CABLE | 24/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 15992 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 15992 | 32A 1PH W/TWIN 13A 5M CABLE | 24/02/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 15993 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.11 | P >99.9 | S | P 0.10 | PASS |
| 15993 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 15993 | 32A1PH W/TWIN 13A 5M CABLE | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 15993 | 32A1PH W/TWIN 13A 5M CABLE | 24/02/23 | P | P | P 0.11 | P >99.9 | S | P 0.10 | PASS |
| 15993 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.11 | P >99.9 | S | P 0.10 | PASS |
| 15993 | 32A1PH W/TWIN 13A 5M CABLE | 24/02/23 | P | P | P 0.11 | P >99.9 | S | P 0.10 | PASS |
| 15994 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|------------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 15994 | 32A1PH W/TWIN 13A 5M CABLE | 24/02/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15994 | 32A1PH W/TWIN 13A 5M CABLE | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 15994 | 32A1PH W/TWIN 13A 5M CABLE | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15994 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15994 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15995 | 32A 1PH W/TWIN 13A | 24/02/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15995 | 32A 1PH W/TWIN 13A | 24/02/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 15995 | 32A 1PH W/TWIN 13A | 24/02/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15995 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15995 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 15995 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 15996 | 32A 1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 15996 | 32A 1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 15996 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 15996 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 15996 | 32A 1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 15996 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 15997 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 15997 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 15997 | 32A1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 15997 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15997 | 32A1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15997 | 32A1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 15998 | 32A 1PH W/TWIN 13A 5M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15998 | 32A 1PH W/TWIN 13A 5M | 24/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 15998 | 32A 1PH W/TWIN 13A 5M | 24/02/23 | P | P | P 0.11 | P >99.9 | S | P 0.10 | PASS |
| 15998 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 15998 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.11 | P >99.9 | S | P 0.10 | PASS |
| 15998 | 32A 1PH TWIN 13A CABLE 5M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15999 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 15999 | 32A 1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 15999 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 15999 | 32A 1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16000 | 32A 1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 16000 | 32A 1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 16000 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 16000 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 16001 | 32A 1PH W/TWIN 13A10M | 24/02/23 | P | P | P 0.11 | P >99.9 | S | P 0.10 | PASS |
| 16001 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16001 | 32A 1PH W/TWIN 13A10M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16001 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16001 | 32A 1PH W/TWIN 13A10M | 24/02/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16001 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.11 | P >99.9 | S | P 0.10 | PASS |
| 16002 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16002 | 32A 1PH TWIN 13A CABLE 10M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 16002 | 32A1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16002 | 32A1PH W/TWIN 13A 10M CABLE | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|----------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 16007 | 16A IEC | 21/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16007 | 16A IEC | 21/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16009 | 16A TLINE TO 13A 4WAY | 25/01/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16009 | 16A TLINE TO 13AWAY | 25/01/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16011 | 16A TLINE TO 13A 4WAY | 25/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16011 | 16A TLINE TO 13A 4WAY | 25/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16012 | 16A TLINE TO 13A 4WAY | 25/01/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16012 | 16A TLINE TO 13A 4WAY | 25/01/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16013 | 32A 1PH CABLE 10M | 24/02/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 16013 | 32A 1PH 10M | 24/02/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 16014 | 32A 1PH CABLE 10M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 16014 | 32A 1PH 10M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 16015 | 32A 1PH 10M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16015 | 32A 1PH CABLE 10M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16016 | 32A 1PH 10M | 24/02/23 | P | P | P 0.42 | P >99.9 | S | P 0.10 | PASS |
| 16016 | 32A 1PH CABLE 10M | 24/02/23 | P | P | P 0.42 | P >99.9 | S | P 0.10 | PASS |
| 16017 | 32A 1PH CABLE 10M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 16017 | 32A 1PH 10M | 24/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 16018 | 32A 1PH 10M | 24/02/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16018 | 32A 1PH CABLE 10M | 24/02/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16019 | 32A 1PH 10M | 24/02/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16019 | 32A 1PH CABLE 10M | 24/02/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16020 | 32A 1PH CABLE 10M | 24/02/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 16020 | 32A 1PH 10M | 24/02/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 16021 | 32A 1PH CABLE 10M | 24/02/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 16021 | 32A 1PH 10M | 24/02/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 16022 | 32A 1PH 10M | 24/02/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 16022 | 32A 1PH CABLE 10M | 24/02/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 16023 | 32A 1PH CABLE 3M | 23/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 16023 | 32A1PH W/TWIN 13A 5M CABLE | 23/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 16024 | 32A 1PH 3M | 28/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16024 | 32A 1PH CABLE 3M | 28/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16025 | 32A 1PH CABLE 3M | 23/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 16025 | 32A1PH W/TWIN 13A 5M CABLE | 23/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 16026 | 32A 1PH CABLE 3M | 23/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 16026 | 32A1PH W/TWIN 13A 5M CABLE | 23/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 16027 | 32A 1PH CABLE 5M | 24/02/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 16027 | 32A 1PH 5M | 24/02/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 16028 | 32A 1PH CABLE 5M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 16028 | 32A 1PH 5M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 16029 | 32A 1PH 5M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 16029 | 32A 1PH CABLE 5M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 16030 | 32A 1PH CABLE 5M | 23/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 16030 | 32A1PH W/TWIN 13A 5M CABLE | 23/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 16031 | 32A 1PH 5M CABLE | 23/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16031 | 32A 1PH CABLE 5M | 23/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16032 | 32A 1PH CABLE 5M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 16032 | 32A 1PH 5M | 24/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16033 | 32A 1PH CABLE 5M | 24/02/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 16033 | 32A 1PH 5M | 24/02/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 16034 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 16034 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 16035 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 16035 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 16036 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 16036 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 16037 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 16037 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 16038 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 16038 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 16039 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 16039 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 16040 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 16040 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 16041 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 16041 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 16042 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 16042 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 16043 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 16043 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 16044 | 13A TO 16A | 25/01/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 16044 | 13A TO 16A | 25/01/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 16045 | 13A TO 16A | 25/01/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 16045 | 13A TO 16A | 25/01/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 16047 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.10 | PASS |
| 16047 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.10 | PASS |
| 16049 | 13A TO 16A | 25/01/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 16049 | 13A TO 16A | 25/01/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 16051 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 16051 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 16052 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 16052 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 16053 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 16053 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 16054 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 16054 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 16055 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 16055 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 16056 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 16056 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 16057 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 16057 | 32A 1PH TO TAILS | 03/03/23 | P | S | S | S | S | S | PASS |
| 16058 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 16058 | 16A CABLE 5M | 18/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 16059 | 16A TO 13A 2WAY BLACK | 25/01/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 16059 | 16A TO 13A 2WAY | 25/01/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 16062 | 16A TO 13A 2WAY BLACK | 25/01/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 16062 | 16A TO 13A 2WAY | 25/01/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 16063 | 16A TO 13A 2WAY | 25/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16063 | 16A TO 13A 2WAY BLACK | 25/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16064 | 16A TO 13A 2WAY BLACK | 25/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16064 | 16A TO 13A 2WAY | 25/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16065 | 16A TO 13A 2WAY BLCK | 28/02/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 16065 | 16A TO 13A 2WAY | 28/02/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 16066 | 16A TO 13A 4WAY BLACK | 28/02/23 | P | P | P 0.01 | S | S | P 0.10 | PASS |
| 16066 | 16A TO 13A 4WAY | 28/02/23 | P | P | P 0.01 | S | S | P 0.10 | PASS |
| 16067 | 16A TO 13A 1WAY | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16067 | 16A TO 13A 1WAY BLACK | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16068 | 16A TO 13A 1WAY BLACK | 25/01/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16068 | 16A TO 13A 1WAY | 25/01/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16069 | 16A TO 13A 1WAY BLACK | 25/01/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16069 | 16A TO 13A 1WAY | 25/01/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16070 | 16A TO 13A 1WAY | 25/01/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16070 | 16A TO 13A 1WAY BLACK | 25/01/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16071 | 16A TO 13A 1WAY BLACK | 25/01/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 16071 | 16A TO 13A 1WAY | 25/01/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 16072 | 16A TO 13A 1WAY | 25/01/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16072 | 16A TO 13A 1WAY BLACK | 25/01/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16073 | 16A TO 13A 1WAY | 25/01/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16073 | 16A TO 13A 1WAY BLACK | 25/01/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16074 | 16A TO 13A 1WAY | 25/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16074 | 16A TO 13A 1WAY BLACK | 25/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16076 | TAILS TO 63A 3PH 20M | 03/03/23 | P | S | S | S | S | S | PASS |
| 16077 | 13A IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16077 | 13A IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16078 | 13A IEC | 06/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16079 | 16A CABLE 30M | 24/01/23 | P | P | P 0.42 | P >99.9 | S | P 0.21 | PASS |
| 16079 | 16A CABLE 30M | 24/01/23 | P | P | P 0.42 | P >99.9 | S | P 0.21 | PASS |
| 16080 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16080 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16080 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16080 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16080 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16080 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16082 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16082 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16083 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16083 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16083 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16083 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16083 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 16083 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16085 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16085 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16085 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16085 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16085 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16085 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16085 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16087 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16087 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16088 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16088 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16088 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16088 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16088 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16088 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16089 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16089 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16089 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16089 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16089 | 16A TRELCO | 01/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16090 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16090 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16090 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16090 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16090 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16090 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16090 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16091 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16091 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16091 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16091 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16091 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16091 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16091 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16091 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16091 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16091 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16091 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16092 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16092 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16092 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16092 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16092 | 16A TRELCO | 02/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16094 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 16094 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 16095 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 16095 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 16104 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16104 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|--|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 16105 | 16A CABLE 10M | 23/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 16105 | 16A CABLE 10M | 23/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 16106 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 16106 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 16107 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16107 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16108 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 16108 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 16109 | 16A CABLE 10M | 23/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16109 | 16A CABLE 10M | 23/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16110 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16110 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16111 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 16111 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 16112 | 32A 3PH TO 63A 3PH | 03/03/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 16112 | 32A 3PH TO 63A 3PH | 03/03/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 16113 | 32A 3PH TO 63A 3PH | 03/03/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 16113 | 32A 3PH TO 63A 3PH | 03/03/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 16132 | 16A CABLE 5M | 18/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 16132 | 16A CABLE 5M | 18/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 16140 | 16A IEC | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16140 | 16A IEC | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16150 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16150 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16152 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16152 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16154 | 13A CABLE REEL 10M | 02/03/23 | P | P | P 0.39 | S | S | P 0.10 | PASS |
| 16154 | 13A CABLE REEL 10M | 02/03/23 | P | P | P 0.39 | S | S | P 0.10 | PASS |
| 16155 | 13A CABLE REEL 25M BLUE | 02/03/23 | P | P | P 0.46 | S | S | P 0.10 | PASS |
| 16155 | 13A CABLE REEL 25M BLUE | 02/03/23 | P | P | P 0.46 | S | S | P 0.10 | PASS |
| 16156 | 13A CABLE REEL RED 25M | 02/03/23 | P | P | P 0.41 | S | S | P 0.14 | PASS |
| 16156 | 13A CABLE REEL RED 25M | 02/03/23 | P | P | P 0.41 | S | S | P 0.14 | PASS |
| 16161 | 16A CABLE 5M | 18/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16161 | 16A CABLE 5M | 18/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16162 | 16A CABLE 5M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16162 | 16A CABLE 5M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16164 | 16A CABLE 5M | 18/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 16164 | 16A CABLE 5M | 18/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 16168 | 16A CABLE 5M | 18/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16168 | 16A CABLE 5M | 18/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16169 | 16A CABLE 40M | 25/01/23 | P | P | P 0.47 | P >99.9 | S | P 0.32 | PASS |
| 16169 | 16A CABLE 40M | 25/01/23 | P | P | P 0.47 | P >99.9 | S | P 0.32 | PASS |
| 16182 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 16182 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 16183 | 13A CABLE 10M | 17/01/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 16183 | 13A CABLE 10M | 17/01/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 16186 | 32 / 3P - 3 X 32 / 1P + 6 X 16 RCBO RUBBER BOX | 13/05/22 | P | P | P 0.17 | S | S | P 0.38 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

| Key P = PASS / F = FAIL / S = SKIP (or test not applicable) | | | | | | | | | | |
|---|--|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|--|
| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status | |
| 16186 | 32 / 3P - 3 X 32 / 1P + 6 X 16 RCBO RUBBER BOX | 13/05/22 | P | P | P 0.24 | S | S | P 0.10 | PASS | |
| 16186 | 32 / 3P - 3 X 32 / 1P + 6 X 16 RCBO RUBBER BOX | 13/05/22 | P | P | P 0.17 | S | S | P 0.37 | PASS | |
| 16186 | 32 / 3P - 3 X 32 / 1P + 6 X 16 RCBO RUBBER BOX | 13/05/22 | P | P | P 0.20 | S | S | P 0.37 | PASS | |
| 16186 | 32 / 3P - 3 X 32 / 1P + 6 X 16 RCBO RUBBER BOX | 13/05/22 | P | P | P 0.20 | S | S | P 0.37 | PASS | |
| 16186 | 32 / 3P - 3 X 32 / 1P + 6 X 16 RCBO RUBBER BOX | 13/05/22 | P | P | P 0.16 | S | S | P 0.37 | PASS | |
| 16186 | 32 / 3P - 3 X 32 / 1P + 6 X 16 RCBO RUBBER BOX | 13/05/22 | P | P | P 0.18 | S | S | P 0.10 | PASS | |
| 16186 | 32 / 3P - 3 X 32 / 1P + 6 X 16 RCBO RUBBER BOX | 13/05/22 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 16192 | 13A 4WAY | 23/01/23 | P | P | P 0.30 | S | S | P 0.10 | PASS | |
| 16192 | 13A 4WAY | 23/01/23 | P | P | P 0.30 | S | S | P 0.10 | PASS | |
| 16194 | 13A 4WAY | 28/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS | |
| 16194 | 13A 4WAY | 28/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS | |
| 16215 | 16A - POWERCON | 06/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS | |
| 16216 | 13A CABLE 10M | 17/01/23 | P | P | P 0.40 | P >99.9 | S | P 0.10 | PASS | |
| 16216 | 13A CABLE 10M | 17/01/23 | P | P | P 0.40 | P >99.9 | S | P 0.10 | PASS | |
| 16217 | 13A CABLE 10M | 17/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS | |
| 16217 | 13A CABLE 10M | 17/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS | |
| 16218 | 13A TO 16A | 22/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS | |
| 16219 | 13A CABLE 10M | 17/01/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS | |
| 16219 | 13A CABLE 10M | 17/01/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS | |
| 16232 | 15A 1M | 07/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS | |
| 16239 | BEHRINGER EUROLIVE B205D | 06/03/23 | P | S | P 0.13 | P >99.9 | P <0.05 | P 0.50 | PASS | |
| 16245 | 32A 1PH CABLE 50M | 24/02/23 | P | P | P 0.26 | P >99.9 | S | P 0.42 | PASS | |
| 16245 | 32A 1PH 50M | 24/02/23 | P | P | P 0.26 | P >99.9 | S | P 0.42 | PASS | |
| 16278 | 16A CABLE 10M | 23/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS | |
| 16278 | 16A CABLE 10M | 23/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS | |
| 16284 | 63A 3PH TO 2X 32A 3PH | 03/03/23 | P | P | P 0.21 | S | S | P 0.10 | PASS | |
| 16284 | 63A 3PH TO 2X 32A 3PH | 03/03/23 | P | P | P 0.20 | S | S | P 0.10 | PASS | |
| 16293 | 13A CABLE 10M | 17/01/23 | P | P | P 0.58 | P >99.9 | S | P 0.10 | PASS | |
| 16293 | 13A CABLE 10M | 17/01/23 | P | P | P 0.58 | P >99.9 | S | P 0.10 | PASS | |
| 16294 | 16A CABLE 20M | 24/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.11 | PASS | |
| 16294 | 16A CABLE 20M | 24/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.11 | PASS | |
| 16295 | 16A CABLE 10M | 23/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS | |
| 16295 | 16A CABLE 10M | 23/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS | |
| 16296 | 16A CABLE 10M | 19/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS | |
| 16296 | 16A CABLE 10M | 19/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS | |
| 16299 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS | |
| 16299 | 16A CABLE 10M | 23/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS | |
| 16300 | 16A CABLE 10M | 20/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS | |
| 16300 | 16A CABLE 10M | 20/01/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS | |
| 16301 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS | |
| 16301 | 16A CABLE 10M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS | |
| 16304 | 16A CABLE 10M | 20/02/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS | |
| 16304 | 16A CABLE 10M | 20/02/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS | |
| 16305 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS | |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 16305 | 16A CABLE 10M | 20/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 16306 | 16A CABLE 10M | 20/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 16306 | 16A CABLE 10M | 20/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 16307 | 16A CABLE 10M | 20/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 16307 | 16A CABLE 10M | 20/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.10 | PASS |
| 16308 | 15A TO 16A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16308 | 15A TO 16A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16309 | 16A TO 15A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16309 | 16A TO 15A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16310 | 16A TO 15A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16310 | 16A TO 15A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16311 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16311 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16311 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16311 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16311 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16311 | 16A TRELCO | 02/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16312 | 16A TLINE TO 16A | 25/01/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 16312 | 16A TLINE TO 16A | 25/01/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 16313 | 16A TLINE - 16A LONG | 24/02/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 16313 | 16A TLINE - 16A LONG | 24/02/23 | P | P | P 0.10 | P >99.9 | S | P 0.10 | PASS |
| 16313 | 16A TLINE - 16A LONG | 24/02/23 | P | P | P 0.10 | P >99.9 | S | P 0.10 | PASS |
| 16313 | 16A TLINE - 16A LONG | 24/02/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 16351 | 16A IEC | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16351 | 16A IEC | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16352 | 16A 3PH CABLE 10M | 03/03/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 16353 | 16A 3PH CABLE 10M | 06/03/23 | P | P | P 0.35 | P >99.9 | S | P 0.10 | PASS |
| 16354 | 16A 3PH CABLE 10M | 03/03/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 16355 | 16A 3PH CABLE 20M | 06/03/23 | P | P | P 0.54 | P >99.9 | S | P 0.11 | PASS |
| 16356 | 16A CABLE 5M | 19/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16356 | 16A CABLE 5M | 19/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16357 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 16357 | 32A 1PH TO 63A 1PH | 02/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 16359 | LV MOTOR CABLE 5M | 06/03/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 16359 | LV MOTOR CABLE 5M | 06/03/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 16361 | MOTOR CABLE 10M | 03/03/23 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS |
| 16361 | MOTOR CABLE 10M | 06/03/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16362 | LV MOTOR CABLE 10M | 06/03/23 | P | P | P 1.04 | P >99.9 | S | P 0.10 | PASS |
| 16362 | LV MOTOR CABLE 10M | 06/03/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 16365 | LV MOTOR CABLE 10M | 06/03/23 | P | P | P 0.33 | P >99.9 | S | P 0.10 | PASS |
| 16365 | LV MOTOR CABLE 10M | 06/03/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 16368 | 13A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 16368 | 13A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 16369 | LV MOTOR CABLE 25M | 06/03/23 | P | P | P 0.35 | P >99.9 | S | P 0.11 | PASS |
| 16369 | LV MOTOR CABLE 25M | 06/03/23 | P | P | P 0.44 | P >99.9 | S | P 0.10 | PASS |
| 16370 | LV MOTOR CABLE 10M | 03/03/23 | P | P | P 0.40 | P >99.9 | S | P 0.10 | PASS |
| 16370 | LV MOTOR CABLE 10M | 06/03/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 16373 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 16373 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 16376 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16376 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16381 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16381 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16381 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16381 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16381 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16381 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16382 | 16A 3PH CABLE 20M | 03/03/23 | P | P | P 0.62 | P >99.9 | S | P 0.11 | PASS |
| 16383 | 16A 3PH CABLE 20M | 06/03/23 | P | P | P 0.78 | P >99.9 | S | P 0.11 | PASS |
| 16384 | 16A 3PH CABLE 20M | 03/03/23 | P | P | P 0.65 | P >99.9 | S | P 0.11 | PASS |
| 16385 | 16A 3PH CABLE 10M | 03/03/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 16387 | 16A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 16387 | 16A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 16390 | 16A IEC | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16390 | 16A IEC | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16393 | 15A TO 16A | 20/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 16393 | 15A TO 16A | 20/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 16394 | 15A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16394 | 15A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16396 | TRELCO | 22/03/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 16397 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16397 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16399 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16399 | 15A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16400 | 13A 4WAY | 17/01/23 | P | P | P 0.40 | S | S | P 0.10 | PASS |
| 16400 | 13A 4WAY | 17/01/23 | P | P | P 0.40 | S | S | P 0.10 | PASS |
| 16402 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16402 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16404 | 16A 3PH CABLE 20M | 06/03/23 | P | P | P 0.65 | P >99.9 | S | P 0.18 | PASS |
| 16405 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16405 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16405 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16405 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16405 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16405 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16405 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16405 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16408 | 13A CABLE 10M | 17/01/23 | P | P | P 0.40 | P >99.9 | S | P 0.19 | PASS |
| 16408 | 13A CABLE 10M | 17/01/23 | P | P | P 0.40 | P >99.9 | S | P 0.19 | PASS |
| 16410 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16410 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16410 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16410 | 16A TRELCO | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16410 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16410 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16412 | 16A TO 15A | 20/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 16452 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16452 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16453 | 16A IEC | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 16453 | 16A IEC | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 16457 | 13A IEC | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 16457 | 13A IEC | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 16458 | 13A TO 15A | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16458 | 13A TO 15A | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16460 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 16460 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 16461 | 13A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16461 | 13A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16462 | 15A GRELCO | 01/03/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 16462 | 15A GRELCO | 01/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 16462 | 15A GRELCO | 01/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 16462 | 15A GRELCO | 01/03/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 16463 | 16A IEC | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16463 | 16A IEC | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16464 | 13A - 15A ADAPTOR | 18/05/22 | P | P | P 0.51 | S | S | P 0.10 | PASS |
| 16464 | 13A TO 15A | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16464 | 13A TO 15A | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16465 | 13A IEC | 21/02/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 16465 | 13A IEC | 21/02/23 | P | P | P 0.28 | S | S | P 0.10 | PASS |
| 16466 | 13A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16466 | 13A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16467 | IEC - POWERCON LOOM | 06/03/23 | P | P | P 0.39 | S | S | P 0.10 | PASS |
| 16468 | IEC - POWERCON LOOM | 06/03/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 16469 | IEC - POWERCON LOMO | 06/03/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 16470 | - | 06/03/23 | P | P | P 0.38 | S | S | P 0.10 | PASS |
| 16472 | 16A IEC | 21/02/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 16472 | 16A IEC | 21/02/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 16488 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 16488 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 16492 | 16A TLINE TO PC | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16492 | 16A TLINE TO PC | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16494 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 16494 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 16497 | 16A TO 15A | 20/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 16497 | 16A TO 15A | 20/02/23 | P | P | P 0.20 | S | S | P 0.10 | PASS |
| 16502 | TP LINK POWER SUPPLY | 06/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 16533 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16533 | 16A CABLE BLACK | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16534 | 16A CABLE 1M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16534 | 16A CABLE BLACK | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16535 | 16A CABLE BLACK | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16535 | 16A CABLE 3M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16536 | 16A CABLE BLACK | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (KVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 16536 | 16A CABLE 3M | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 16537 | 16A CABLE BLACK | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 16537 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 16538 | 16A CABLE BLACK | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16538 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16541 | 16A CABLE BLACK | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 16541 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 16542 | 16A CABLE BLACK | 23/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 16542 | 16A CABLE 3M | 23/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 16543 | 16A CABLE 1M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16543 | 16A CABLE BLACK | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16544 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16544 | 16A CABLE BLACK | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16545 | 16A CABLE BLACK | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16545 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16546 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16546 | 16A CABLE BLACK | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16547 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 16547 | 16A CABLE BLACK | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 16548 | 16A CABLE BLACK | 19/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16548 | 16A CABLE 3M | 19/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16549 | 16A CABLE BLACK | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16549 | 16A CABLE 1M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16550 | 16A CABLE BLACK | 23/01/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 16550 | 16A CABLE 3M | 23/01/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 16551 | 16A CABLE BLACK | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16551 | 16A CABLE 3M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16552 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16552 | 16A CABLE BLACK | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16553 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16553 | 16A CABLE BLACK | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16554 | 16A CABLE 3M | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 16554 | 16A CABLE BLACK | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 16555 | 16A CABLE BLACK | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 16555 | 16A CABLE 3M | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 16556 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16556 | 16A CABLE BLACK | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16557 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16557 | 16A CABLE BLACK | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16558 | 16A CABLE BLACK | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 16558 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 16559 | 16A CABLE BLACK | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 16559 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 16560 | 16A CABLE BLACK | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16560 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 16562 | 16A CABLE 1M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16562 | 16A CABLE 1M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 16574 | 16A CABLE GRELCO | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16574 | 16A CABLE GRELCO | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16574 | 16A CABLE GRELCO | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16574 | 16A CABLE GRELCO | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16577 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16577 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16577 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16577 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16577 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16611 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 16611 | 16A TLINE TRUECON | 28/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 16637 | 13A IEC | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16637 | 13A IEC | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16639 | 13A IEC 5M | 07/03/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 16641 | 13A IEC 5M | 07/03/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 16642 | 13A IEC 5M | 07/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16643 | 13A IEC 5M | 07/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16645 | 13A IEC 5M | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 16645 | 13A IEC 5M | 07/03/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 16647 | 13A IEC 5M | 06/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16648 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.10 | PASS |
| 16648 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.10 | PASS |
| 16649 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 16649 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 16650 | 16A CABLE 20M | 24/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.11 | PASS |
| 16650 | 16A CABLE 20M | 24/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.11 | PASS |
| 16651 | 16A TLINE IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16651 | 16A TLINE IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16652 | 16A TLINE IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16652 | 16A TLINE IEC | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16653 | 16A TLINE IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 16653 | 16A TLINE IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 16655 | 16A IEC | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16655 | 16A IEC | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16656 | 16A TLINE IEC | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 16656 | 16A TLINE IEC | 21/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 16693 | 16A TLINE PC | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16693 | 16A TLINE PC | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16701 | 16A CABLE 5M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16701 | 16A CABLE 5M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16702 | 16A CABLE 1M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16702 | 16A CABLE 1M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 16703 | 16A CABLE 10M | 23/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16703 | 16A CABLE 10M | 23/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16704 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16704 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 16705 | 16A CABLE 10M | 23/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 16705 | 16A CABLE 10M | 23/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 16706 | 16A CABLE 10M | 23/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16706 | 16A CABLE 10M | 23/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 16708 | 16A CABLE 20M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.11 | PASS |
| 16708 | 16A CABLE 20M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.11 | PASS |
| 16709 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 16709 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 16710 | 16A CABLE 20M | 23/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |
| 16710 | 16A CABLE 20M | 23/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS |
| 16712 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 16712 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 16728 | 16A CABLE 30M | 24/01/23 | P | P | P 0.42 | P >99.9 | S | P 0.21 | PASS |
| 16728 | 16A CABLE 30M | 24/01/23 | P | P | P 0.42 | P >99.9 | S | P 0.21 | PASS |
| 16729 | 16A CABLE 30M | 28/02/23 | P | P | P 0.34 | P >99.9 | S | P 0.16 | PASS |
| 16729 | 16A CABLE 30M | 28/02/23 | P | P | P 0.34 | P >99.9 | S | P 0.16 | PASS |
| 16731 | 13A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16731 | 13A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16732 | 13A 16A | 30/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16733 | 13A 6WAY | 17/01/23 | P | P | P 0.38 | S | S | P 0.10 | PASS |
| 16733 | 13A 6WAY | 17/01/23 | P | P | P 0.38 | S | S | P 0.10 | PASS |
| 16736 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16736 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16737 | 13A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 16737 | 13A IEC | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 16738 | 13A IEC | 21/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 16738 | 13A IEC | 21/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 16739 | 13A IEC | 06/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 16740 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16740 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16742 | 13A TO 16A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16742 | 13A TO 16A | 20/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16743 | 15A TO 13A | 01/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 16743 | 15A TO 13A | 01/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 16744 | 15A TO 13A | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16744 | 15A TO 13A | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16745 | 15A TO 13A | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16745 | 15A TO 13A | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16746 | 15A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16746 | 15A TO 16A | 20/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16747 | 16A TRLECO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16747 | 16A TRLECO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16747 | 16A TRLECO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16747 | 16A TRLECO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16747 | 16A TRLECO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16747 | 16A TRLECO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16748 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|---------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 16748 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 16749 | 16A CABLE 20M | 03/03/23 | P | P | P 0.40 | P >99.9 | S | P 0.10 | PASS |
| 16750 | 16A CABLE 5M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 16750 | 16A CABLE 5M | 23/01/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 16770 | 15A TO 16A | 20/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 16770 | 15A TO 16A | 20/02/23 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 16771 | | 07/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16772 | | 07/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16778 | POWERCON LOOM 2M | 22/03/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 16780 | 16A - POWERCON | 06/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16782 | | 07/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16790 | 13A IEC | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16790 | 13A IEC | 21/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16792 | 13A IEC | 06/03/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 16793 | 13A IEC | 06/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 16794 | 13A IEC | 06/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 16795 | DBX GRAPHIC EQ | 06/03/23 | P | S | P 0.11 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 17011 | 13A IEC | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 17011 | 13A IEC | 21/02/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 17012 | YAMAHA MG124 CX | 06/03/23 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 17013 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 17013 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 17021 | 32A 1PH AND DUAL XLR LOOM | 06/03/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17073 | 16A TLINE TO 13A 4WAY | 25/01/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 17073 | 16A TLINE TO 13A 4WAY | 25/01/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 17074 | 16A TLINE TO 13A 4WAY | 25/01/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17074 | 16A TLINE TO 13A4WAY | 25/01/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17075 | 16A TLINE TO 13A 4WAY | 25/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17075 | 16A TLINE TO 13A4WAY | 25/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17076 | 16A TLINE TO 13A 4WAY | 25/01/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 17076 | 16A TLINE TO 13A 4WAY | 25/01/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 17079 | 16A TLINE TO TRUECON | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17079 | 16A TLINE TRUECON | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17083 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17083 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17084 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17084 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17085 | 16A CABLE 1M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17085 | 16A CABLE 1M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17086 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17086 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17087 | 16A TRUECON | 28/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17087 | 16A TRUECON | 28/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17088 | 16A CABLE 1M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17088 | 16A CABLE 1M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17089 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17089 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (KVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 17090 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17090 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17091 | AURA XB | 28/02/23 | P | S | P 0.09 | P >99.9 | P 0.06 | P 0.38 | PASS |
| 17091 | AURA XB | 28/02/23 | P | S | P 0.09 | P >99.9 | P 0.06 | P 0.38 | PASS |
| 17092 | AURA XB | 28/02/23 | P | S | P 0.08 | P >99.9 | P 0.06 | P 0.37 | PASS |
| 17092 | AURA XB | 28/02/23 | P | S | P 0.08 | P >99.9 | P 0.06 | P 0.37 | PASS |
| 17093 | AURA XB | 28/02/23 | P | S | P 0.13 | P >99.9 | P 0.06 | P 0.38 | PASS |
| 17093 | AURA XB | 28/02/23 | P | S | P 0.13 | P >99.9 | P 0.06 | P 0.38 | PASS |
| 17094 | AURA XB | 28/02/23 | P | S | P 0.09 | P >99.9 | P 0.06 | P 0.37 | PASS |
| 17094 | AURA XB | 28/02/23 | P | S | P 0.09 | P >99.9 | P 0.06 | P 0.37 | PASS |
| 17095 | AURA XB | 28/02/23 | P | S | P 0.11 | P >99.9 | P 0.06 | P 0.37 | PASS |
| 17095 | AURA XB | 28/02/23 | P | S | P 0.11 | P >99.9 | P 0.06 | P 0.37 | PASS |
| 17096 | AURA XB | 28/02/23 | P | S | P 0.12 | P >99.9 | P 0.06 | P 0.38 | PASS |
| 17096 | AURA XB | 28/02/23 | P | S | P 0.12 | P >99.9 | P 0.06 | P 0.38 | PASS |
| 17097 | AURA XB | 28/02/23 | P | S | P 0.11 | P >99.9 | P 0.06 | P 0.40 | PASS |
| 17097 | AURA XB | 28/02/23 | P | S | P 0.11 | P >99.9 | P 0.06 | P 0.40 | PASS |
| 17098 | AURA XB | 28/02/23 | P | S | P 0.08 | P >99.9 | P 0.06 | P 0.37 | PASS |
| 17098 | AURA XB | 28/02/23 | P | S | P 0.08 | P >99.9 | P 0.06 | P 0.37 | PASS |
| 17099 | AURA XB | 28/02/23 | P | S | P 0.08 | P >99.9 | P 0.06 | P 0.37 | PASS |
| 17099 | AURAXB | 28/02/23 | P | S | P 0.08 | P >99.9 | P 0.06 | P 0.37 | PASS |
| 17100 | AURA XB | 28/02/23 | P | S | P 0.14 | P >99.9 | P 0.06 | P 0.38 | PASS |
| 17100 | AURA XB | 28/02/23 | P | S | P 0.14 | P >99.9 | P 0.06 | P 0.38 | PASS |
| 17167 | 16A CABLE 10M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 17167 | 16A CABLE 10M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 17168 | 16A CABLE 5M | 18/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17168 | 16A CABLE 5M | 18/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17169 | 16A CABLE 3M | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17169 | 16A CABLE 3M | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17171 | 13A TO 16A | 25/01/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 17171 | 13A TO 16A | 25/01/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 17181 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 17181 | 13A CABLE 10M | 17/01/23 | P | P | P 0.36 | P >99.9 | S | P 0.10 | PASS |
| 17183 | | 07/03/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 17184 | | 07/03/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 17188 | | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 17199 | 13A PC | 07/03/23 | P | P | P 0.09 | P >99.9 | S | P 0.10 | PASS |
| 17205 | 13A TO 16A | 25/01/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 17205 | 13A TO 16A | 25/01/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 17207 | 16A CABLE 3M | 19/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17207 | 16A CABLE 3M | 19/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17208 | 13A TO 16A | 25/01/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 17208 | 13A TO 16A | 25/01/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 17209 | 16A TO TRUCON | 16/03/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 17212 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17212 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17212 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17212 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (KVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 17213 | 16A CABLE 10M | 23/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17213 | 16A CABLE 10M | 23/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17217 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 17217 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 17219 | 16A TO 13A 4WAY | 25/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 17219 | 16A TO 13A 4WAY BLACK | 25/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 17222 | 16A CABLE 3M | 28/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 17222 | 16A CABLE 3M | 28/02/23 | P | P | P 0.12 | P >99.9 | S | P 0.10 | PASS |
| 17223 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P 80.58 | S | P 0.10 | PASS |
| 17223 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P 80.58 | S | P 0.10 | PASS |
| 17224 | 32A 3PH 3M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 17224 | 32A 1PH CABLE 3M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 17225 | LV MOTOR CABLE 15M | 06/03/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 17225 | LV MOTOR CABLE 15M | 06/03/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 17226 | 16A CABLE 5M | 18/01/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 17226 | 16A CABLE 5M | 18/01/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 17227 | 16A CABLE 10M | 23/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17227 | 16A CABLE 10M | 23/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17228 | 16A TO 13 BLACK | 25/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 17228 | 16A TO 13A 4WAY | 25/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 17229 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.10 | PASS |
| 17229 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.10 | PASS |
| 17230 | LV MOTOR CABLE 10M | 06/03/23 | P | P | P 0.50 | P >99.9 | S | P 0.10 | PASS |
| 17230 | LV MOTOR CABLE 10M | 06/03/23 | P | P | P 0.33 | P >99.9 | S | P 0.10 | PASS |
| 17231 | 16A CABLE 50M | 25/01/23 | P | P | P 0.58 | P >99.9 | S | P 0.30 | PASS |
| 17231 | 16A CABLE 50M | 25/01/23 | P | P | P 0.58 | P >99.9 | S | P 0.30 | PASS |
| 17233 | 16A CABLE 10M | 23/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17233 | 16A CABLE 10M | 23/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17236 | 16A TO TRUCON | 16/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 17237 | 16A TO TRUCON | 16/03/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17238 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17238 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17239 | 16A CABLE 10M | 23/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17239 | 16A CABLE 10M | 23/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17241 | 13A IEC 5M | 07/03/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 17249 | 16A TO 13A | 26/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 17249 | 16A TO 13A 1WAY | 26/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 17252 | 16A CABLE 50M | 25/01/23 | P | P | P 0.58 | P >99.9 | S | P 0.28 | PASS |
| 17252 | 16A CABLE 50M | 25/01/23 | P | P | P 0.58 | P >99.9 | S | P 0.28 | PASS |
| 17257 | 16A TO 13A 2WAY | 25/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17257 | 16A TO 13A 2WAY BLACK | 25/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17258 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.11 | PASS |
| 17258 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.11 | PASS |
| 17259 | 16A TLINE TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17259 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17262 | 13A TO 16A | 25/01/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 17262 | 13A TO 16A | 25/01/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (KVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 17263 | 16A CABLE 5M | 18/01/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 17263 | 16A CABLE 5M | 18/01/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 17264 | 16A CABLE 5M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17264 | 16A CABLE 5M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17265 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17265 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17267 | 16A CABLE 10M | 20/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17267 | 16A CABLE 10M | 20/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17268 | 16A CABLE 1M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17268 | 16A CABLE 1M | 18/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17269 | 16A CABLE 5M | 18/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17269 | 16A CABLE 5M | 18/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17270 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 17270 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 17271 | 16A CABLE 10M | 23/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.22 | PASS |
| 17271 | 16A CABLE 10M | 23/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.22 | PASS |
| 17272 | 16A CABLE 10M | 19/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 17272 | 16A CABLE 10M | 19/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 17273 | 16A CABLE 10M | 23/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17273 | 16A CABLE 10M | 23/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17274 | 16A CABLE 10M | 23/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17274 | 16A CABLE 10M | 23/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17275 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17275 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17276 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17276 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17277 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17277 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17279 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17279 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17280 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 17280 | 16A CABLE 5M | 18/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 17281 | 16A CABLE 3M | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17281 | 16A CABLE 3M | 19/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17282 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17282 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17283 | 16A CABLE 3M | 19/01/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 17283 | 16A CABLE 3M | 19/01/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 17284 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17284 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17285 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17285 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17286 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17286 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17287 | 16A CABLE 3M | 19/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17287 | 16A CABLE 3M | 19/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17288 | 16A CABLE 3M | 28/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (KVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 17288 | 16A CABLE 3M | 28/02/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 17289 | 16A CABLE 3M | 19/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17289 | 16A CABLE 3M | 19/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17290 | 16A CABLE 3M | 19/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17290 | 16A CABLE 3M | 19/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17291 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17291 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17292 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17292 | 16A CABLE 3M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17293 | 16A CABLE 3M | 19/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17293 | 16A CABLE 3M | 19/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 17296 | 16A CABLE 10M | 23/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17296 | 16A CABLE 10M | 23/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17298 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17298 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17299 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17299 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17300 | 16A CABLE 40M | 25/01/23 | P | P | P 0.52 | P >99.9 | S | P 0.34 | PASS |
| 17300 | 16A CABLE 40M | 25/01/23 | P | P | P 0.52 | P >99.9 | S | P 0.34 | PASS |
| 17301 | 16A CABLE 40M | 25/01/23 | P | P | P 0.48 | P >99.9 | S | P 0.34 | PASS |
| 17301 | 16A CABLE 40M | 25/01/23 | P | P | P 0.48 | P >99.9 | S | P 0.34 | PASS |
| 17302 | 16A CABLE 40M | 25/01/23 | P | P | P 0.48 | P >99.9 | S | P 0.34 | PASS |
| 17302 | 16A CABLE 40M | 25/01/23 | P | P | P 0.48 | P >99.9 | S | P 0.34 | PASS |
| 17303 | 16A CABLE 50M | 25/01/23 | P | P | P 0.55 | P >99.9 | S | P 0.43 | PASS |
| 17303 | 16A CABLE 50M | 25/01/23 | P | P | P 0.55 | P >99.9 | S | P 0.43 | PASS |
| 17304 | 16A CABLE 50M | 25/01/23 | P | P | P 0.57 | P >99.9 | S | P 0.43 | PASS |
| 17304 | 16A CABLE 50M | 25/01/23 | P | P | P 0.57 | P >99.9 | S | P 0.43 | PASS |
| 17305 | 16A CABLE 50M | 25/01/23 | P | P | P 0.56 | P >99.9 | S | P 0.40 | PASS |
| 17305 | 16A CABLE 50M | 25/01/23 | P | P | P 0.56 | P >99.9 | S | P 0.40 | PASS |
| 17306 | 16A CABLE 50M | 25/01/23 | P | P | P 0.58 | P >99.9 | S | P 0.43 | PASS |
| 17306 | 16A CABLE 50M | 25/01/23 | P | P | P 0.58 | P >99.9 | S | P 0.43 | PASS |
| 17307 | 16A CABLE 50M | 25/01/23 | P | P | P 0.60 | P >99.9 | S | P 0.44 | PASS |
| 17307 | 16A CABLE 50M | 25/01/23 | P | P | P 0.60 | P >99.9 | S | P 0.44 | PASS |
| 17309 | 16A CABLE 40M | 25/01/23 | P | P | P 0.48 | P >99.9 | S | P 0.34 | PASS |
| 17309 | 16A CABLE 40M | 25/01/23 | P | P | P 0.48 | P >99.9 | S | P 0.34 | PASS |
| 17310 | 16A CABLE 50M | 25/01/23 | P | P | P 0.57 | P >99.9 | S | P 0.44 | PASS |
| 17310 | 16A CABLE 50M | 25/01/23 | P | P | P 0.57 | P >99.9 | S | P 0.44 | PASS |
| 17312 | 16A CABLE 50M | 25/01/23 | P | P | P 0.57 | P >99.9 | S | P 0.44 | PASS |
| 17312 | 16A CABLE 50M | 25/01/23 | P | P | P 0.57 | P >99.9 | S | P 0.44 | PASS |
| 17313 | 16A CABLE 50M | 25/01/23 | P | P | P 0.56 | P >99.9 | S | P 0.42 | PASS |
| 17313 | 16A CABLE 50M | 25/01/23 | P | P | P 0.56 | P >99.9 | S | P 0.42 | PASS |
| 17316 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.14 | PASS |
| 17316 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.14 | PASS |
| 17317 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.14 | PASS |
| 17317 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.14 | PASS |
| 17318 | 16A CABLE 20M | 28/02/23 | P | P | P 0.25 | P >99.9 | S | P 0.13 | PASS |
| 17318 | 16A CABLE 20M | 28/02/23 | P | P | P 0.25 | P >99.9 | S | P 0.13 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (KVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 17319 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.16 | PASS |
| 17319 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.16 | PASS |
| 17320 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.13 | PASS |
| 17320 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.13 | PASS |
| 17321 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.14 | PASS |
| 17321 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.14 | PASS |
| 17322 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.13 | PASS |
| 17322 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.13 | PASS |
| 17323 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.13 | PASS |
| 17323 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.13 | PASS |
| 17324 | 16A CABLE 30M | 24/01/23 | P | P | P 0.41 | P >99.9 | S | P 0.26 | PASS |
| 17324 | 16A CABLE 30M | 24/01/23 | P | P | P 0.41 | P >99.9 | S | P 0.26 | PASS |
| 17325 | 16A CABLE 30M | 24/01/23 | P | P | P 0.41 | P >99.9 | S | P 0.23 | PASS |
| 17325 | 16A CABLE 30M | 24/01/23 | P | P | P 0.41 | P >99.9 | S | P 0.23 | PASS |
| 17326 | 16A CABLE 30M | 24/01/23 | P | P | P 0.42 | P >99.9 | S | P 0.26 | PASS |
| 17326 | 16A CABLE 30M | 24/01/23 | P | P | P 0.42 | P >99.9 | S | P 0.26 | PASS |
| 17328 | 16A CABLE 30M | 24/01/23 | P | P | P 0.43 | P >99.9 | S | P 0.27 | PASS |
| 17328 | 16A CABLE 30M | 24/01/23 | P | P | P 0.43 | P >99.9 | S | P 0.27 | PASS |
| 17330 | 16A CABLE 30M | 24/01/23 | P | P | P 0.42 | P >99.9 | S | P 0.26 | PASS |
| 17330 | 16A CABLE 30M | 24/01/23 | P | P | P 0.42 | P >99.9 | S | P 0.26 | PASS |
| 17331 | 16A CABLE 30M | 24/01/23 | P | P | P 0.42 | P >99.9 | S | P 0.27 | PASS |
| 17331 | 16A CABLE 30M | 24/01/23 | P | P | P 0.42 | P >99.9 | S | P 0.27 | PASS |
| 17332 | 16A CABLE 30M | 24/01/23 | P | P | P 0.41 | P >99.9 | S | P 0.24 | PASS |
| 17332 | 16A CABLE 30M | 24/01/23 | P | P | P 0.41 | P >99.9 | S | P 0.24 | PASS |
| 17333 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.15 | PASS |
| 17333 | 16A CABLE 20M | 24/01/23 | P | P | P 0.34 | P >99.9 | S | P 0.15 | PASS |
| 17334 | 16A CABLE 20M | 24/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.14 | PASS |
| 17334 | 16A CABLE 20M | 24/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.14 | PASS |
| 17335 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.16 | PASS |
| 17335 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.16 | PASS |
| 17337 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.15 | PASS |
| 17337 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.15 | PASS |
| 17338 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.14 | PASS |
| 17338 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.14 | PASS |
| 17339 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.15 | PASS |
| 17339 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.15 | PASS |
| 17340 | 16A CABLE 20M | 28/02/23 | P | P | P 0.26 | P >99.9 | S | P 0.20 | PASS |
| 17340 | 16A CABLE 20M | 28/02/23 | P | P | P 0.26 | P >99.9 | S | P 0.20 | PASS |
| 17341 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.14 | PASS |
| 17341 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.14 | PASS |
| 17342 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.13 | PASS |
| 17342 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.13 | PASS |
| 17343 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.14 | PASS |
| 17343 | 16A CABLE 20M | 23/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.14 | PASS |
| 17344 | 16A CABLE 20M | 24/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.14 | PASS |
| 17344 | 16A CABLE 20M | 24/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.14 | PASS |
| 17345 | 16A CABLE 20M | 01/03/23 | P | P | P 0.24 | P >99.9 | S | P 0.15 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (KVA) | Leakage (mA) | Overall Status |
|--------------|------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 17345 | 16A CABLE 20M | 01/03/23 | P | P | P 0.24 | P >99.9 | S | P 0.15 | PASS |
| 17346 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.15 | PASS |
| 17346 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.15 | PASS |
| 17348 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.14 | PASS |
| 17348 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.14 | PASS |
| 17349 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.14 | PASS |
| 17349 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.14 | PASS |
| 17350 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.14 | PASS |
| 17350 | 16A CABLE 20M | 24/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.14 | PASS |
| 17351 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.13 | PASS |
| 17351 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.13 | PASS |
| 17352 | 16A CABLE 20M | 24/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.13 | PASS |
| 17352 | 16A CABLE 20M | 24/01/23 | P | P | P 0.32 | P >99.9 | S | P 0.13 | PASS |
| 17353 | 16A CABLE 20M | 28/02/23 | P | P | P 0.26 | P >99.9 | S | P 0.15 | PASS |
| 17353 | 16A CABLE 20M | 28/02/23 | P | P | P 0.26 | P >99.9 | S | P 0.15 | PASS |
| 17354 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.14 | PASS |
| 17354 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.14 | PASS |
| 17356 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.15 | PASS |
| 17356 | 16A CABLE 20M | 24/01/23 | P | P | P 0.31 | P >99.9 | S | P 0.15 | PASS |
| 17357 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.15 | PASS |
| 17357 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.15 | PASS |
| 17358 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.14 | PASS |
| 17358 | 16A CABLE 20M | 23/01/23 | P | P | P 0.30 | P >99.9 | S | P 0.14 | PASS |
| 17359 | 16A CABLE 20M | 24/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.16 | PASS |
| 17359 | 16A CABLE 20M | 24/01/23 | P | P | P 0.35 | P >99.9 | S | P 0.16 | PASS |
| 17360 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 17360 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17360 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17360 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 17361 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17361 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17361 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17361 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17362 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17362 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 17362 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 17362 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17363 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17363 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17363 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17363 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17364 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17364 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17365 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17365 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17366 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17366 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (KVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 17367 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17367 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17368 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17368 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17369 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17369 | 16A CABLE 10M | 20/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17370 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17370 | 16A CABLE 10M | 20/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 17380 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17380 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17390 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 17390 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 17391 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.42 | S | S | P 0.10 | PASS |
| 17391 | 16A TO 13A 2WAY | 26/01/23 | P | P | P 0.42 | S | S | P 0.10 | PASS |
| 17392 | 13A TO 16A | 25/01/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 17392 | 13A TO 16A | 25/01/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 17393 | 13A TO 16A | 25/01/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 17393 | 13A TO 16A | 25/01/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 17394 | 16A CABLE 10M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17394 | 16A CABLE 10M | 19/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17406 | 16A CABLE 3M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17406 | 16A CABLE 3M | 19/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 17408 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17408 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17408 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17408 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17409 | 16A CABLE GRELCO | 03/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 17409 | 16A CABLE GRELCO | 03/03/23 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 17410 | 16A CABLE 3M | 03/03/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 17416 | 16A CABLE GRELCO | 03/03/23 | P | P | P 0.26 | S | S | P 0.10 | PASS |
| 17416 | 16A CABLE GRELCO | 03/03/23 | P | P | P 0.27 | S | S | P 0.10 | PASS |
| 17417 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17417 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17417 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17417 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17418 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17418 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17419 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17419 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 17419 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 17419 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17420 | 16A CABLE 1M | 23/01/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 17420 | 16A CABLE 1M | 23/01/23 | P | P | P 0.16 | P >99.9 | S | P 0.10 | PASS |
| 17421 | 13A CABLE 10M | 17/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.10 | PASS |
| 17421 | 13A CABLE 10M | 17/01/23 | P | P | P 0.33 | P >99.9 | S | P 0.10 | PASS |
| 17422 | 16A TLINE TRUECON | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 17422 | 16A TLINE TO TRUECON | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 17423 | | 07/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 17424 | 13A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17424 | 13A TO 16A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17426 | 16A TRUECON | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 17426 | 16A TRUECON | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 17427 | 13A TO 16A | 20/02/23 | P | P | P 0.29 | S | S | P 0.10 | PASS |
| 17427 | 13A TO 16A | 20/02/23 | P | P | P 0.29 | S | S | P 0.10 | PASS |
| 17428 | 16A CABLE 10M | 23/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17428 | 16A CABLE 10M | 23/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17521 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17521 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17522 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17522 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17524 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17524 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17524 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17524 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17524 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17525 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17525 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17526 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17526 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17527 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17527 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17528 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17528 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17529 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17529 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17530 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17530 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17531 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17531 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17532 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17532 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17533 | 16A CABLE 1M | 18/01/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 17533 | 16A CABLE 1M | 18/01/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 17534 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17534 | 16A CABLE 1M | 18/01/23 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS |
| 17535 | 16A CABLE 1M | 18/01/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 17535 | 16A CABLE 1M | 18/01/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 17536 | 16A CABLE 1M | 18/01/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 17536 | 16A CABLE 1M | 18/01/23 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS |
| 17537 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17537 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 17559 | 16A CABLE 10M | 19/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 17559 | 16A CABLE 10M | 19/01/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 17573 | 16A CABLE 5M | 23/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 17573 | 16A CABLE 5M | 23/01/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 17574 | 16A CABLE 30M | 24/01/23 | P | P | P 0.41 | P >99.9 | S | P 0.17 | PASS |
| 17574 | 16A CABLE 30M | 24/01/23 | P | P | P 0.41 | P >99.9 | S | P 0.17 | PASS |
| 17575 | 16A TO TRUCON | 16/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17576 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17576 | 16A GRELCO CABLE | 21/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17577 | 13A IEC | 21/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 17577 | 13A IEC | 21/02/23 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 17579 | 13A IEC | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 17579 | 13A IEC | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 17581 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17581 | 16A TO 15A | 20/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17582 | 16A TLINE IEC | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17582 | 16A TLINE IEC | 21/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17583 | 16A IEC | 21/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 17583 | 16A IEC | 21/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 17584 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17584 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17585 | 13A IEC | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17585 | 13A IEC | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17586 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 17586 | 13A IEC | 21/02/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 17587 | 13A IEC | 24/02/23 | P | P | P 0.29 | S | S | P 0.10 | PASS |
| 17587 | 13A IEC | 24/02/23 | P | P | P 0.29 | S | S | P 0.10 | PASS |
| 17588 | 13A IEC | 24/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17588 | 13A IEC | 24/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17589 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17589 | 13A IEC | 21/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17590 | 16A IEC | 21/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 17590 | 16A IEC | 21/02/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 17598 | 13A 5M CABLE | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 17598 | 13A CABLE 5M | 24/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 17599 | 13A CABLE 5M | 28/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 17599 | 13A CABLE 5M | 28/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 17600 | 13A CABLE 5M | 28/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 17600 | 13A CABLE 5M | 28/02/23 | P | P | P 0.15 | P >99.9 | S | P 0.10 | PASS |
| 17603 | 17603 | 24/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17604 | 16A TO 13A 4WAY | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17604 | 16A TO 13A 4WAY | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17605 | 13A TO 16A | 28/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 17605 | 13A TO 16A | 28/02/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 17606 | 16A CABLE 3M | 28/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 17606 | 16A CABLE 3M | 28/02/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 17609 | 13A - 16A BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17609 | 13A - 16A BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 17610 | 13A CABLE 10M | 28/02/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 17610 | 13A CABLE 10M | 28/02/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 17611 | 16A TO 15A | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 17611 | 16A TO 15A | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17612 | 16A IEC | 28/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 17612 | 16A IEC | 28/02/23 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 17613 | 13A IEC | 28/02/23 | P | P | P 0.07 | S | S | P 0.10 | PASS |
| 17613 | 13A IEC | 28/02/23 | P | P | P 0.07 | S | S | P 0.10 | PASS |
| 17617 | 13A IEC | 28/02/23 | P | P | P 1.61 | S | S | P 0.10 | PASS |
| 17617 | 13A IEC | 28/02/23 | P | P | P 1.61 | S | S | P 0.10 | PASS |
| 17619 | 16A TLINE TRUECON | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17619 | 16ATLINE TRUECON | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17620 | 13A TRUECON | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17620 | 13A TRUECON | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17621 | 13A TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17621 | 13A TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 17622 | 16A TLINE PC | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17622 | 16A TLINE PC | 01/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17623 | 15A GRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 17623 | 15A GRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 17626 | 13A CABLE REEL 25M RED | 02/03/23 | P | P | P 0.47 | S | S | P 0.14 | PASS |
| 17626 | 13A CABLE REEL 25M RED | 02/03/23 | P | P | P 0.47 | S | S | P 0.14 | PASS |
| 17627 | 13A CABLE REEL 25M BLUE | 02/03/23 | P | P | P 0.45 | S | S | P 0.10 | PASS |
| 17627 | 13A CABLE REEL 25M BLUE | 02/03/23 | P | P | P 0.45 | S | S | P 0.10 | PASS |
| 17629 | TAILS TO 63A 3PH | 03/03/23 | P | S | S | S | S | S | PASS |
| 17629 | TAILS TO 63A 3PH | 03/03/23 | P | S | S | S | S | S | PASS |
| 17631 | 125A 3PH TO 63A 3PH | 03/03/23 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 17632 | TAILS TO 125A 3PH | 03/03/23 | P | S | S | S | S | S | PASS |
| 17633 | POWERLOCKS TO 125A | 03/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 17634 | 16A CABLE 20M | 03/03/23 | P | P | P 0.45 | P >99.9 | S | P 0.10 | PASS |
| 17635 | 32A 3PH TO 2X 16A 3PH | 03/03/23 | P | S | S | S | S | S | PASS |
| 17636 | | 07/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 17637 | | 07/03/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 17639 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.08 | S | S | P 0.10 | PASS |
| 17639 | 16A TLINE - POWERCON | 06/03/23 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 17640 | 13A IEC | 07/03/23 | P | P | P 0.11 | P >99.9 | S | P 0.10 | PASS |
| 17642 | 13A IEC | 07/03/23 | P | P | P 0.18 | P >99.9 | S | P 0.10 | PASS |
| 17643 | 13A IEC | 07/03/23 | P | P | P 0.11 | P >99.9 | S | P 0.10 | PASS |
| 17644 | 13A IEC | 07/03/23 | P | P | P 0.10 | P >99.9 | S | P 0.10 | PASS |
| 17645 | 13A IEC | 07/03/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 17646 | 15A 13A | 07/03/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 17647 | 13A 15A | 07/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 17650 | 16A TO TRUON | 16/03/23 | P | P | P 2.72 | S | S | P 0.10 | PASS |
| 17651 | 16A TO TRUON | 16/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 17654 | 13A 10M | 22/03/23 | P | P | P 0.34 | P >99.9 | S | P 0.10 | PASS |
| 17655 | 13A TO PC | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 17656 | 16A CABLE GRELCO BLACK | 22/03/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 17657 | 16A CABLE GRELCO BLACK | 22/03/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |
| 17658 | 16A CABLE GRELCO BLACK | 22/03/23 | P | P | P 0.13 | P >99.9 | S | P 0.10 | PASS |
| 17659 | 16A CABLE GRELCO BLACK | 22/03/23 | P | P | P 0.14 | P >99.9 | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 17660 | 16A TO 13A | 22/03/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 17661 | 16A GRELCO | 22/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17661 | 16A GRELCO | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 17662 | 13A TO 16A BLACK | 22/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 17665 | 200W FLOOD | 23/03/23 | P | S | P 0.11 | P >99.9 | P 0.19 | P 0.21 | PASS |
| 17666 | 200W FLOOD | 23/03/23 | P | S | P 0.11 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17667 | 200W FLOOD | 23/03/23 | P | S | P 0.11 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17669 | 200W FLOOD | 23/03/23 | P | S | P 0.12 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17670 | 200W FLOOD | 23/03/23 | P | S | P 0.11 | P >99.9 | P 0.18 | P 0.19 | PASS |
| 17671 | 200W FLOOD | 23/03/23 | P | S | P 0.11 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17672 | 200W FLOOD | 23/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.21 | PASS |
| 17673 | 200W FLOOD | 23/03/23 | P | S | P 0.11 | P >99.9 | P 0.18 | P 0.20 | PASS |
| 17674 | 200W FLOOD | 23/03/23 | P | S | P 0.11 | P >99.9 | P 0.19 | P 0.21 | PASS |
| 17675 | 200W FLOOD | 23/03/23 | P | S | P 0.11 | P >99.9 | P 0.19 | P 0.22 | PASS |
| 17676 | 200W FLOOD | 23/03/23 | P | S | P 0.11 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17677 | 200W FLOOD | 23/03/23 | P | S | P 0.09 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17678 | 200W FLOOD | 23/03/23 | P | S | P 0.11 | P >99.9 | P 0.19 | P 0.19 | PASS |
| 17679 | 200W FLOOD | 23/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.19 | PASS |
| 17680 | 200W FLOOD | 23/03/23 | P | S | P 0.11 | P >99.9 | P 0.19 | P 0.23 | PASS |
| 17681 | 200W FLOOD | 23/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17682 | 200W FLOOD | 23/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.21 | PASS |
| 17683 | 200W FLOOD | 23/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.19 | PASS |
| 17684 | 200W FLOOD | 23/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.19 | PASS |
| 17685 | 200W FLOOD | 23/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.21 | PASS |
| 17686 | 200W FLOOD | 23/03/23 | P | S | P 0.11 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17687 | 200W FLOOD | 24/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.21 | PASS |
| 17688 | 200W FLOOD | 24/03/23 | P | S | P 0.12 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17689 | 200W FLOOD | 24/03/23 | P | S | P 0.09 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17690 | 200W FLOOD | 24/03/23 | P | S | P 0.09 | P >99.9 | P 0.19 | P 0.24 | PASS |
| 17691 | 200W FLOOD | 24/03/23 | P | S | P 0.13 | P >99.9 | P 0.19 | P 0.22 | PASS |
| 17692 | 200W FLOOD | 24/03/23 | P | S | P 0.11 | P >99.9 | P 0.19 | P 0.21 | PASS |
| 17693 | 200W FLOOD | 24/03/23 | P | S | P 0.14 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17694 | 200W FLOOD | 24/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.19 | PASS |
| 17695 | 200W FLOOD | 24/03/23 | P | S | P 0.11 | P >99.9 | P <0.05 | P 0.43 | PASS |
| 17696 | 200W FLOOD | 24/03/23 | P | S | P 0.16 | P >99.9 | P <0.05 | P 0.40 | PASS |
| 17697 | 200W FLOOD | 24/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17698 | 200W FLOOD | 24/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17699 | 200W FLOOD | 24/03/23 | P | S | P 0.11 | P >99.9 | P 0.19 | P 0.21 | PASS |
| 17701 | 200W FLOOD | 24/03/23 | P | S | P 0.11 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 17702 | 200W FLOOD | 24/03/23 | P | S | P 0.11 | P >99.9 | P <0.05 | P 0.41 | PASS |
| 17703 | 200W FLOOD | 24/03/23 | P | S | P 0.11 | P >99.9 | P 0.19 | P 0.23 | PASS |
| 17704 | 200W FLOOD | 24/03/23 | P | S | P 0.09 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17705 | 200W FLOOD | 24/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17706 | 200W FLOOD | 24/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17707 | 200W FLOOD | 24/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.23 | PASS |
| 17708 | 200W FLOOD | 24/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17709 | 200W FLOOD | 24/03/23 | P | S | P 0.10 | P >99.9 | P 0.20 | P 0.20 | PASS |

APPLIANCE DETAILS AND TEST RESULTS
Key
 P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-------------------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 17710 | 200W FLOOD | 24/03/23 | P | S | P 0.09 | P >99.9 | P 0.19 | P 0.22 | PASS |
| 17711 | 200W FLOOD | 23/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.20 | PASS |
| 17712 | 200W FLOOD | 23/03/23 | P | S | P 0.10 | P >99.9 | P 0.19 | P 0.19 | PASS |
| 17713 | 200W FLOOD | 23/03/23 | P | S | P 0.11 | P >99.9 | P 0.19 | P 0.19 | PASS |
| 17716 | 13A TO 16A | 24/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 17717 | 13A TO 16A | 24/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30001 | 32 3P - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 30001 | 32 3P - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 30001 | 32 3P - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30002 | 32 3P - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 30002 | 32 3P - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 30002 | 32 3P - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30003 | 32 3P - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 30003 | 32 3P - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30003 | 32 3P - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30004 | 32 3P - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30004 | 32 3P - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 30004 | 32 3P - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30005 | 32 3P THRU - 3 X16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30005 | 32 3P THRU - 3 X16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30005 | 32 3P THRU - 3 X16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30006 | 32 3P THRU - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30006 | 32 3P THRU - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30006 | 32 3P THRU - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 30007 | 32 3P THRU - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 30007 | 32 3P THRU - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 30007 | 32 3P THRU - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30008 | 32 3P THRU - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 30008 | 32 3P THRU - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 30008 | 32 3P THRU - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 30009 | 32 3P THRU - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 30009 | 32 3P THRU - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 30009 | 32 3P THRU - 3 X 16 RCBO RUBBER BOX | 09/05/22 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 30011 | 16A TO 13A 2WAY BLACK | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30011 | 16A - 13A 2 WAY | 18/05/22 | P | P | P 0.35 | S | S | P 0.10 | PASS |
| 30011 | 16A TO 13A 2WAY | 20/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30012 | 16A TO 13A 2WAY BLACK | 25/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 30012 | 16A - 13A 2 WAY | 18/05/22 | P | P | P 0.33 | S | S | P 0.10 | PASS |
| 30012 | 16A TO 13A 2WAY | 25/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 30013 | 16A - 13A 2 WAY | 18/05/22 | P | P | P 0.24 | S | S | P 0.10 | PASS |
| 30013 | 16A TO 13A 2WAY | 25/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 30013 | 16A TO 13A 2WAY BLACK | 25/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 30014 | 16A - 13A 2 WAY | 18/05/22 | P | P | P 0.34 | S | S | P 0.10 | PASS |
| 30014 | 16A TO 13A 2WAY | 25/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 30014 | 16A TO 13A 2WAY BLACK | 25/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 30015 | SAMSUNG 32`` HD TV | 18/05/22 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30017 | SAMSUNG 23`` HD TV | 18/05/22 | P | S | S | P >99.9 | P <0.05 | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|----------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 30019 | 16A - 16A DISTRO (C10 MCB) | 19/05/22 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 30021 | 125A 20M | 19/05/22 | P | P | P 0.27 | P >99.9 | S | P 0.32 | PASS |
| 30022 | 16A - 16A DISTRO (C10 MCB) | 18/05/22 | P | P | P 0.18 | S | S | P 0.10 | PASS |
| 30023 | 16A - 16A DISTRO (C10 MCB) | 18/05/22 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30024 | 16A - 16A DISTRO (C10 MCB) | 18/05/22 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 30025 | 16A - 16A DISTRO (C6 MCB) | 18/05/22 | P | P | P 0.17 | S | S | P 0.10 | PASS |
| 30027 | 16A CABLE 1M | 18/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 30027 | 16A CABLE 1M | 18/01/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 30033 | 16A CABLE 1M | 23/01/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 30033 | 16A CABLE 1M | 23/01/23 | P | P | P 0.17 | P >99.9 | S | P 0.10 | PASS |
| 30035 | 16A CABLE 1M | 18/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 30035 | 16A CABLE 1M | 18/01/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 30036 | 16A TO TRUCON | 16/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30037 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 30037 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 30046 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 30046 | 16A CABLE 1M | 18/01/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 30049 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 30049 | 16A CABLE 1M | 18/01/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 30050 | 16A TRELCO | 01/03/23 | P | P | P 0.31 | S | S | P 0.10 | PASS |
| 30050 | 16A TRELCO | 01/03/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 30050 | 16A TRELCO | 01/03/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 30050 | 16A TRELCO | 01/03/23 | P | P | P 0.22 | S | S | P 0.10 | PASS |
| 30050 | 16A TRELCO | 01/03/23 | P | P | P 0.31 | S | S | P 0.10 | PASS |
| 30050 | 16A TRELCO | 01/03/23 | P | P | P 0.30 | S | S | P 0.10 | PASS |
| 30051 | | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30051 | 16A GRELECO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30073 | 16A TRLECO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30073 | 16A TRLECO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30073 | 16A TRLECO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30073 | 16A TRLECO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30073 | 16A TRLECO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30078 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30078 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30078 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30078 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30078 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30078 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30078 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30084 | 16A TLINE TO TRU CON | 16/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 30084 | 16A TLINE TO TRU CON | 16/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 30085 | 16A TO 13A 4WAY BLACK | 25/01/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 30085 | 16A TO 13A 4WAY | 25/01/23 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 30091 | 16A TO 13A 4WAY | 25/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 30091 | 16A TO 13A 4WAY BLACK | 25/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 30092 | 16A TLINE TO 13A 4WAY | 25/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 30092 | 16A TLINE TO 13A 4WAY | 25/01/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 30099 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30099 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 30099 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30099 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30099 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30099 | 16A TRELCO | 02/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30102 | 16A T LINE TO POWERCON | 16/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 30109 | 13A TO 16A | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 30109 | 13A TO 16A | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 30111 | 16A TO 13A 4WAY BLACK | 25/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 30111 | 16A TO 13A 4WAY | 25/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 30112 | 16A TO 13A 4WAY | 25/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30112 | 16A TO 13A 4WAY BLACK | 25/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30121 | 16A TO 13A 4WAY | 25/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 30121 | 16A TO 13A 4WAY BLACK | 25/01/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 30124 | 16A TO 13A 4WAY BLACK | 25/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30124 | 16A TO 13A 4WAY | 25/01/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30128 | PA 12 | 06/03/23 | P | S | P 0.08 | P >99.9 | P <0.05 | P 0.42 | PASS |
| 30135 | ROBE POINTE | 28/02/23 | P | S | P 0.18 | P >99.9 | P 0.14 | P 0.25 | PASS |
| 30135 | ROBE POINTE | 28/02/23 | P | S | P 0.18 | P >99.9 | P 0.14 | P 0.25 | PASS |
| 30140 | 16A TLINE PC | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 30140 | 16A TLINE PC | 01/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 30144 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 30144 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 30144 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 30144 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 30148 | RAPID QB1 | 28/02/23 | P | S | P 0.05 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30148 | RAPID QB1 | 28/02/23 | P | S | P 0.05 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30158 | RAPID QB1 | 28/02/23 | P | S | P 0.05 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30158 | RAPID QB1 | 28/02/23 | P | S | P 0.05 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30161 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30161 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30162 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30162 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30163 | RAPID QB1 | 28/02/23 | P | S | P 0.05 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30163 | RAPID QB1 | 28/02/23 | P | S | P 0.05 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30164 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30164 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30166 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30166 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30170 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30170 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30171 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30171 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30172 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30172 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30178 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30178 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30179 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|-----------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 30179 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30183 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30183 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30184 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30184 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30185 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30185 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30188 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30188 | RAPID QB1 | 28/02/23 | P | S | P 0.06 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30208 | 13A 6WAY | 17/01/23 | P | P | P 0.43 | S | S | P 0.10 | PASS |
| 30208 | 13A 6WAY | 17/01/23 | P | P | P 0.43 | S | S | P 0.10 | PASS |
| 30222 | VOX GUTJAR AMP | 06/03/23 | P | S | P 0.24 | P >99.9 | P <0.05 | P 0.10 | PASS |
| 30234 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30234 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30234 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30234 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30234 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30234 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30234 | 16A TRELCO | 02/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30246 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 30246 | 16A TO 13A 4WAY | 20/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 30247 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30247 | 16A TRELCO | 01/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30254 | 13A CABLE 10M | 28/02/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 30254 | 13A CABLE 10M | 28/02/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 30261 | ADJ HEX32 | 28/02/23 | P | S | P 0.08 | P >99.9 | P <0.05 | P 0.34 | PASS |
| 30261 | ADJ HEX32 | 28/02/23 | P | S | P 0.08 | P >99.9 | P <0.05 | P 0.34 | PASS |
| 30262 | ADJ HEX32 | 28/02/23 | P | S | P 0.08 | P >99.9 | P <0.05 | P 0.35 | PASS |
| 30262 | ADJ HEX32 | 28/02/23 | P | S | P 0.08 | P >99.9 | P <0.05 | P 0.35 | PASS |
| 30263 | ADJ HEX32 | 28/02/23 | P | S | P 0.08 | P >99.9 | P <0.05 | P 0.42 | PASS |
| 30263 | ADJ HEX32 | 28/02/23 | P | S | P 0.08 | P >99.9 | P <0.05 | P 0.42 | PASS |
| 30264 | ADJ HEX32 | 28/02/23 | P | S | P 0.08 | P >99.9 | P <0.05 | P 0.42 | PASS |
| 30264 | ADJ HEX32 | 28/02/23 | P | S | P 0.08 | P >99.9 | P <0.05 | P 0.42 | PASS |
| 30265 | ADJ HEX32 | 01/03/23 | P | S | P 0.07 | P >99.9 | P <0.05 | P 0.41 | PASS |
| 30265 | ADJ HEX32 | 01/03/23 | P | S | P 0.07 | P >99.9 | P <0.05 | P 0.41 | PASS |
| 30266 | ADJ HEX32 | 01/03/23 | P | S | P 0.07 | P >99.9 | P <0.05 | P 0.40 | PASS |
| 30266 | ADJ HEX32 | 01/03/23 | P | S | P 0.07 | P >99.9 | P <0.05 | P 0.40 | PASS |
| 30267 | ADJ HEX32 | 01/03/23 | P | S | P 0.07 | P >99.9 | P <0.05 | P 0.34 | PASS |
| 30267 | ADJ HEX32 | 01/03/23 | P | S | P 0.07 | P >99.9 | P <0.05 | P 0.34 | PASS |
| 30269 | ADJ HEX32 | 01/03/23 | P | S | P 0.07 | P >99.9 | P <0.05 | P 0.42 | PASS |
| 30269 | ADJ HEX32 | 01/03/23 | P | S | P 0.07 | P >99.9 | P <0.05 | P 0.42 | PASS |
| 30325 | S32 STAGE BOX | 06/03/23 | P | S | P 0.10 | P >99.9 | P <0.05 | P 0.17 | PASS |
| 30326 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30327 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30327 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30328 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30329 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30330 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|---------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 30331 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30332 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30333 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30334 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30335 | 16A TO 13A WAY | 22/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30336 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30337 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30338 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30339 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30340 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30341 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 30342 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30343 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 30344 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.16 | S | S | P 0.10 | PASS |
| 30345 | 16A TO 13A 4WAY | 22/03/23 | P | P | P 0.15 | S | S | P 0.10 | PASS |
| 30347 | 16A TO 13A 4WAY | 24/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30348 | 16A TO 13A 4WAY | 24/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30349 | 16A TO 13A 4WAY | 24/03/23 | P | P | P 0.09 | S | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.37 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.24 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.29 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS |
| 30350 | SOCAPEX SOCKET BOX 6X 16A | 23/03/23 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS |
| 30352 | 16A TO 13A 4WAY | 24/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30353 | 16A TO 13A 4WAY | 24/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30354 | 16A TO 13A 4WAY | 24/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30355 | 16A TO 13A 4WAY | 24/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30363 | 16A TO 13A 4WAY | 24/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 30365 | 16A TO 13A 4WAY | 24/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 30376 | 16A TO 13A 4WAY | 24/03/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |

Total Appliances > **3,909**

HI-LIGHTS - DISTRO

| | | | | | | | | | |
|-------|--------------------------------|----------|---|---|--------|---|---|--------|------|
| 00164 | 63A 3P - 6 X 32A 1P RUBBER BOX | 09/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 00164 | 63A 3P - 6 X 32A 1P RUBBER BOX | 09/05/22 | P | P | P 0.25 | S | S | P 0.10 | PASS |

APPLIANCE DETAILS AND TEST RESULTS

| Key P = PASS / F = FAIL / S = SKIP (or test not applicable) | | | | | | | | | | |
|---|---|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|--|
| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status | |
| 04717 | 16A (THRU) - 14 X 13 RCD `TOBLERONEÃ´ | 18/05/22 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS | |
| 04717 | 16A (THRU) - 14 X 13 RCD `TOBLERONEÃ´ | 18/05/22 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS | |
| 04717 | 16A (THRU) - 14 X 13 RCD `TOBLERONEÃ´ | 18/05/22 | P | P | P 0.25 | P >99.9 | S | P 0.10 | PASS | |
| 04717 | 16A (THRU) - 14 X 13 RCD `TOBLERONEÃ´ | 18/05/22 | P | P | P 0.28 | P >99.9 | S | P 0.10 | PASS | |
| 04724 | 16A (THRU)- 14 X 13 RCD | 12/04/23 | P | P | P 0.17 | S | S | P 0.10 | PASS | |
| 04724 | 16A (THRU)- 14 X 13 RCD | 12/04/23 | P | P | P 0.18 | S | S | P 0.10 | PASS | |
| 04724 | 16A (THRU)- 14 X 13 RCD | 12/04/23 | P | P | P 0.16 | S | S | P 0.10 | PASS | |
| 04724 | 16A (THRU)- 14 X 13 RCD | 12/04/23 | P | P | P 0.16 | S | S | P 0.10 | PASS | |
| 04724 | 16A (THRU)- 14 X 13 RCD | 12/04/23 | P | P | P 0.17 | S | S | P 0.10 | PASS | |
| 04724 | 16A (THRU)- 14 X 13 RCD | 12/04/23 | P | P | P 0.15 | S | S | P 0.10 | PASS | |
| 04724 | 16A (THRU)- 14 X 13 RCD | 12/04/23 | P | P | P 0.18 | S | S | P 0.10 | PASS | |
| 04724 | 16A (THRU)- 14 X 13 RCD | 12/04/23 | P | P | P 0.24 | S | S | P 0.10 | PASS | |
| 04724 | 16A (THRU)- 14 X 13 RCD | 12/04/23 | P | P | P 0.20 | S | S | P 0.10 | PASS | |
| 04724 | 16A (THRU)- 14 X 13 RCD | 12/04/23 | P | P | P 0.17 | S | S | P 0.10 | PASS | |
| 04724 | 16A (THRU)- 14 X 13 RCD | 12/04/23 | P | P | P 0.23 | S | S | P 0.10 | PASS | |
| 04724 | 16A (THRU)- 14 X 13 RCD | 12/04/23 | P | P | P 0.16 | S | S | P 0.10 | PASS | |
| 04724 | 16A (THRU)- 14 X 13 RCD | 12/04/23 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 04724 | 16A (THRU)- 14 X 13 RCD | 12/04/23 | P | P | P 0.17 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.17 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.15 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.15 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.15 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.15 | S | S | P 0.10 | PASS | |
| 07980 | 16A (THRU) - 14 X 13 RCD | 12/04/23 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 12391 | 125A 3P - 4 X 32A 3P + (3 X 32A 1P + 1X 16A) RCBO | 09/05/22 | P | P | P 0.28 | S | S | P 0.10 | PASS | |
| 12391 | 125A 3P - 4 X 32A 3P + (3 X 32A 1P + 1X 16A) RCBO | 09/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS | |
| 12391 | 125A 3P - 4 X 32A 3P + (3 X 32A 1P + 1X 16A) RCBO | 09/05/22 | P | P | P 0.22 | S | S | P 0.10 | PASS | |
| 12391 | 125A 3P - 4 X 32A 3P + (3 X 32A 1P + 1X 16A) RCBO | 09/05/22 | P | P | P 0.22 | S | S | P 0.10 | PASS | |
| 13395 | 32A 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS | |
| 13395 | 32A 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 13395 | 32A 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.18 | S | S | P 0.10 | PASS | |
| 13395 | 32A 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.14 | S | S | P 0.10 | PASS | |
| 13396 | 32 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.11 | S | S | P 0.10 | PASS | |
| 13396 | 32 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 13396 | 32 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.17 | S | S | P 0.10 | PASS | |

APPLIANCE DETAILS AND TEST RESULTS

| Key P = PASS / F = FAIL / S = SKIP (or test not applicable) | | | | | | | | | | |
|---|---|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|--|
| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status | |
| 13396 | 32 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.25 | S | S | P 0.10 | PASS | |
| 13397 | 32A 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.28 | S | S | P 0.10 | PASS | |
| 13397 | 32A 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.16 | S | S | P 0.10 | PASS | |
| 13397 | 32A 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS | |
| 13397 | 32A 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.16 | S | S | P 0.10 | PASS | |
| 13398 | 32A 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.29 | S | S | P 0.10 | PASS | |
| 13398 | 32A 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.27 | S | S | P 0.10 | PASS | |
| 13398 | 32A 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.29 | S | S | P 0.10 | PASS | |
| 13398 | 32A 1P - 4 X 16 MCB RUBBER BOX TAIL | 18/05/22 | P | P | P 0.29 | S | S | P 0.10 | PASS | |
| 13411 | 32 3P - 3 X 32 1P + 6 X 16 RCBO THRU | 18/05/22 | P | P | P 0.27 | S | S | P 0.36 | PASS | |
| 13411 | 32 3P - 3 X 32 1P + 6 X 16 RCBO THRU | 18/05/22 | P | P | P 0.19 | S | S | P 0.18 | PASS | |
| 13411 | 32 3P - 3 X 32 1P + 6 X 16 RCBO THRU | 18/05/22 | P | P | P 0.20 | S | S | P 0.30 | PASS | |
| 13411 | 32 3P - 3 X 32 1P + 6 X 16 RCBO THRU | 18/05/22 | P | P | P 0.16 | S | S | P 0.10 | PASS | |
| 13411 | 32 3P - 3 X 32 1P + 6 X 16 RCBO THRU | 18/05/22 | P | P | P 0.16 | S | S | P 0.12 | PASS | |
| 13411 | 32 3P - 3 X 32 1P + 6 X 16 RCBO THRU | 18/05/22 | P | P | P 0.24 | S | S | P 0.38 | PASS | |
| 13411 | 32 3P - 3 X 32 1P + 6 X 16 RCBO THRU | 18/05/22 | P | P | P 0.28 | S | S | P 0.34 | PASS | |
| 13411 | 32 3P - 3 X 32 1P + 6 X 16 RCBO THRU | 18/05/22 | P | P | P 0.29 | S | S | P 0.31 | PASS | |
| 13411 | 32 3P - 3 X 32 1P + 6 X 16 RCBO THRU | 18/05/22 | P | P | P 0.30 | S | S | P 0.40 | PASS | |
| 13800 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 13/05/22 | P | P | P 0.32 | P >99.9 | S | P 0.10 | PASS | |
| 13800 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 13/05/22 | P | P | P 0.21 | P >99.9 | S | P 0.10 | PASS | |
| 13800 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 12/04/23 | P | P | P 0.11 | S | S | P 0.10 | PASS | |
| 13800 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 12/04/23 | P | P | P 0.11 | S | S | P 0.10 | PASS | |
| 13800 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 13/05/22 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS | |
| 13800 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 12/04/23 | P | P | P 0.11 | S | S | P 0.10 | PASS | |
| 13800 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 12/04/23 | P | P | P 0.11 | S | S | P 0.10 | PASS | |
| 13800 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 12/04/23 | P | P | P 0.11 | S | S | P 0.10 | PASS | |
| 13800 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 13/05/22 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS | |
| 13802 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 18/05/22 | P | P | P 0.22 | P >99.9 | S | P 0.10 | PASS | |
| 13802 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 18/05/22 | P | P | P 0.20 | P >99.9 | S | P 0.10 | PASS | |
| 13802 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 12/04/23 | P | P | P 0.11 | S | S | P 0.10 | PASS | |
| 13802 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 18/05/22 | P | P | P 0.27 | P >99.9 | S | P 0.10 | PASS | |
| 13802 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 12/04/23 | P | P | P 0.11 | S | S | P 0.10 | PASS | |
| 13802 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 12/04/23 | P | P | P 0.11 | S | S | P 0.10 | PASS | |
| 13802 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 12/04/23 | P | P | P 0.11 | S | S | P 0.10 | PASS | |
| 13802 | 32A 1P (THRU) - 4 X 16 RCD / MCB TEA COSY | 18/05/22 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS | |
| 15782 | 32A 1P - 4 X16 + 1 X 13 MCB TEA COSY | 13/05/22 | P | P | P 0.35 | S | S | P 0.10 | PASS | |
| 15782 | 32A 1P - 4 X16 + 1 X 13 MCB TEA COSY | 13/05/22 | P | P | P 0.41 | S | S | P 0.10 | PASS | |
| 15782 | 32A 1P - 4 X16 + 1 X 13 MCB TEA COSY | 13/05/22 | P | P | P 0.46 | S | S | P 0.10 | PASS | |
| 15782 | 32A 1P - 4 X16 + 1 X 13 MCB TEA COSY | 13/05/22 | P | P | P 0.42 | S | S | P 0.10 | PASS | |

APPLIANCE DETAILS AND TEST RESULTS

| Key P = PASS / F = FAIL / S = SKIP (or test not applicable) | | | | | | | | | | |
|---|--|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|--|
| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status | |
| 15782 | 32A 1P - 4 X 16 + 1 X 13 MCB TEA COSY | 13/05/22 | P | P | P 0.27 | S | S | P 0.10 | PASS | |
| 15783 | 32A 1P (THRU) - 4 X 16A RCD / MCB TEA COSY | 18/05/22 | P | P | P 0.23 | P >99.9 | S | P 0.10 | PASS | |
| 15783 | 32A 1P (THRU) - 4 X 16A RCD / MCB TEA COSY | 18/05/22 | P | P | P 0.19 | P >99.9 | S | P 0.10 | PASS | |
| 15783 | 32A 1P (THRU) - 4 X 16A RCD / MCB TEA COSY | 18/05/22 | P | P | P 0.26 | P >99.9 | S | P 0.10 | PASS | |
| 15783 | 32A 1P (THRU) - 4 X 16A RCD / MCB TEA COSY | 18/05/22 | P | P | P 0.30 | P >99.9 | S | P 0.10 | PASS | |
| 15784 | 32 1P - 4 X 16 THRU TEA COSY | 12/04/23 | P | P | P 0.13 | S | S | P 0.10 | PASS | |
| 15784 | 32 1P - 4 X 16 THRU TEA COSY | 12/04/23 | P | P | P 0.13 | S | S | P 0.10 | PASS | |
| 15784 | 32 1P - 4 X 16 THRU TEA COSY | 12/04/23 | P | P | P 0.12 | S | S | P 0.10 | PASS | |
| 15784 | 32 1P - 4 X 16 THRU TEA COSY | 12/04/23 | P | P | P 0.13 | S | S | P 0.10 | PASS | |
| 15793 | 32 3P - 3 X 32 1P + 6 X 16 RCBO | 13/05/22 | P | P | P 0.21 | S | S | P 0.10 | PASS | |
| 15793 | 32 3P - 3 X 32 1P + 6 X 16 RCBO | 13/05/22 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 15793 | 32 3P - 3 X 32 1P + 6 X 16 RCBO | 13/05/22 | P | P | P 0.18 | S | S | P 0.36 | PASS | |
| 15793 | 32 3P - 3 X 32 1P + 6 X 16 RCBO | 13/05/22 | P | P | P 0.19 | S | S | P 0.10 | PASS | |
| 15793 | 32 3P - 3 X 32 1P + 6 X 16 RCBO | 13/05/22 | P | P | P 0.22 | S | S | P 0.10 | PASS | |
| 15793 | 32 3P - 3 X 32 1P + 6 X 16 RCBO | 13/05/22 | P | P | P 0.15 | S | S | P 0.10 | PASS | |
| 15793 | 32 3P - 3 X 32 1P + 6 X 16 RCBO | 13/05/22 | P | P | P 0.17 | S | S | P 0.10 | PASS | |
| 15793 | 32 3P - 3 X 32 1P + 6 X 16 RCBO | 13/05/22 | P | P | P 0.18 | S | S | P 0.10 | PASS | |
| 15793 | 32 3P - 3 X 32 1P + 6 X 16 RCBO | 13/05/22 | P | P | P 0.21 | S | S | P 0.10 | PASS | |
| 15795 | 32 3P - 6 X 16 RCBO SLEDGE | 13/05/22 | P | P | P 0.20 | S | S | P 0.35 | PASS | |
| 15795 | 32 3P - 6 X 16 RCBO SLEDGE | 13/05/22 | P | P | P 0.21 | S | S | P 0.37 | PASS | |
| 15795 | 32 3P - 6 X 16 RCBO SLEDGE | 13/05/22 | P | P | P 0.18 | S | S | P 0.35 | PASS | |
| 15795 | 32 3P - 6 X 16 RCBO SLEDGE | 13/05/22 | P | P | P 0.25 | S | S | P 0.34 | PASS | |
| 15795 | 32 3P - 6 X 16 RCBO SLEDGE | 13/05/22 | P | P | P 0.22 | S | S | P 0.33 | PASS | |
| 15795 | 32 3P - 6 X 16 RCBO SLEDGE | 13/05/22 | P | P | P 0.31 | S | S | P 0.39 | PASS | |
| 15796 | 32 3P - 6 X 16 RCBO SLEDGE | 11/04/23 | P | P | P 0.18 | S | S | P 0.67 | PASS | |
| 15796 | 32 3P - 6 X 16 RCBO SLEDGE | 11/04/23 | P | P | P 0.15 | S | S | P 0.68 | PASS | |
| 15796 | 32 3P - 6 X 16 RCBO SLEDGE | 11/04/23 | P | P | P 0.14 | S | S | P 0.71 | PASS | |
| 15796 | 32 3P - 6 X 16 RCBO SLEDGE | 11/04/23 | P | P | P 0.13 | S | S | P 0.69 | PASS | |
| 15796 | 32 3P - 6 X 16 RCBO SLEDGE | 11/04/23 | P | P | P 0.13 | S | S | P 0.69 | PASS | |
| 15796 | 32 3P - 6 X 16 RCBO SLEDGE | 11/04/23 | P | P | P 0.16 | S | S | P 0.68 | PASS | |
| 15796 | 32 3P - 6 X 16 RCBO SLEDGE | 13/05/22 | P | P | P 0.19 | S | S | P 0.41 | PASS | |
| 15796 | 32 3P - 6 X 16 RCBO SLEDGE | 13/05/22 | P | P | P 0.25 | S | S | P 0.44 | PASS | |
| 15796 | 32 3P - 6 X 16 RCBO SLEDGE | 13/05/22 | P | P | P 0.18 | S | S | P 0.44 | PASS | |
| 15796 | 32 3P - 6 X 16 RCBO SLEDGE | 13/05/22 | P | P | P 0.21 | S | S | P 0.43 | PASS | |
| 15796 | 32 3P - 6 X 16 RCBO SLEDGE | 13/05/22 | P | P | P 0.23 | S | S | P 0.41 | PASS | |
| 15796 | 32 3P - 6 X 16 RCBO SLEDGE | 13/05/22 | P | P | P 0.18 | S | S | P 0.41 | PASS | |
| 15798 | 32 3P - 6 X 16 RCBO SLEDGE | 11/04/23 | P | P | P 0.13 | S | S | P 0.67 | PASS | |
| 15798 | 32 3P - 6 X 16 RCBO SLEDGE | 11/04/23 | P | P | P 0.13 | S | S | P 0.69 | PASS | |
| 15798 | 32 3P - 6 X 16 RCBO SLEDGE | 11/04/23 | P | P | P 0.13 | S | S | P 0.67 | PASS | |
| 15798 | 32 3P - 6 X 16 RCBO SLEDGE | 11/04/23 | P | P | P 0.13 | S | S | P 0.60 | PASS | |
| 15798 | 32 3P - 6 X 16 RCBO SLEDGE | 11/04/23 | P | P | P 0.13 | S | S | P 0.60 | PASS | |
| 15798 | 32 3P - 6 X 16 RCBO SLEDGE | 11/04/23 | P | P | P 0.13 | S | S | P 0.63 | PASS | |
| 15799 | 32 3P - 3 X 32 1P + 6 X 16 THRU | 13/05/22 | P | P | P 0.20 | S | S | P 0.10 | PASS | |
| 15799 | 32 3P - 3 X 32 1P + 6 X 16 THRU | 13/05/22 | P | P | P 0.18 | S | S | P 0.10 | PASS | |
| 15799 | 32 3P - 3 X 32 1P + 6 X 16 THRU | 13/05/22 | P | P | P 0.18 | S | S | P 0.10 | PASS | |

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|---------------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 15799 | 32 3P - 3 X 32 1P + 6 X 16 THRU | 13/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 15799 | 32 3P - 3 X 32 1P + 6 X 16 THRU | 13/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS |
| 15799 | 32 3P - 3 X 32 1P + 6 X 16 THRU | 13/05/22 | P | P | P 0.21 | S | S | P 0.10 | PASS |
| 15799 | 32 3P - 3 X 32 1P + 6 X 16 THRU | 13/05/22 | P | P | P 0.25 | S | S | P 0.10 | PASS |
| 15799 | 32 3P - 3 X 32 1P + 6 X 16 THRU | 13/05/22 | P | P | P 0.19 | S | S | P 0.10 | PASS |
| 15799 | 32 3P - 3 X 32 1P + 6 X 16 THRU | 13/05/22 | P | P | P 0.23 | S | S | P 0.10 | PASS |

Total Appliances > 177

HI-LIGHTS - LIGHTING

| | | | | | | | | | |
|-------|------------------------|----------|---|---|--------|---|---|--------|------|
| 12574 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 12574 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16601 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16601 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16601 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16601 | 16A CABLE GRELCO BLACK | 24/02/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16604 | 16A CABLE GRELCO BLACK | 21/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16604 | 16A CABLE GRELCO BLACK | 21/02/23 | P | P | P 0.10 | S | S | P 0.10 | PASS |
| 16612 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16612 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16613 | 16A TLINE TO TRUECON | 16/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16614 | 16A TLINE TO TRUECON | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16614 | 16A TLINE TO TRUECON | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16615 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16615 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16618 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16618 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16620 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16620 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16621 | 16A TLINE TO TRUECON | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16621 | 16A TLINE TO TRUECON | 01/03/23 | P | P | P 0.12 | S | S | P 0.10 | PASS |
| 16623 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16623 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16624 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16624 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16628 | | 16/03/23 | P | P | P 0.11 | S | S | P 0.10 | PASS |
| 16630 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16630 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16632 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16632 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16633 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16633 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.13 | S | S | P 0.10 | PASS |
| 16634 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |
| 16634 | 16A TLINE TO TRUECON | 28/02/23 | P | P | P 0.14 | S | S | P 0.10 | PASS |

Total Appliances > 34

Total Appliances For Report: 4,132