

PAT Report Passes For all Sites and Locations

CLIENT DETAILS	
Company Name:	<input type="text"/>
Address:	<input type="text"/>



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	Hi-Lights Theatre Services Ltd
Address:	18E White Rose Way Gateshead NE108YX
Telephone:	01914950608
Mobile:	<input type="text"/>
Email:	info@hi-lights.tv
Cert Number:	<input type="text"/>
Order Number:	<input type="text"/>
File Name:	Download 11 March 2026 12-56
Signature:	

APPLIANCE DETAILS AND TEST RESULTS										
Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
HI-LIGHTS - CLEAN WORKSHOP										
31660	DB 16A TRU X14 13A	30/10/25	P	P	P 0.33	S	S	P 0.10	PASS	
15543	32A 1PH 10M	30/10/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS	
31661	DB 16A THRU X14 16A	30/10/25	P	P	P 0.29	S	S	P 0.10	PASS	
14744	16A TO 13A	03/11/25	P	P	P 0.28	S	S	P 0.10	PASS	
16105	10M	06/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS	
15802	32A 1PH TAILS - X4 13A	07/11/25	P	P	P 0.16	S	S	S	PASS	
15805	32A 1PH TAILS - X4 13A	07/11/25	P	P	P 0.31	S	S	S	PASS	
18948	32A 1PH 10M	07/11/25	P	P	P 0.14	P >99.9	S	P 0.10	PASS	
18949	32A 1PH 10M	07/11/25	P	P	P 0.14	P >99.9	S	P 0.10	PASS	
18962	32A 1PH 20M	07/11/25	P	P	P 0.18	P >99.9	S	P 0.10	PASS	
02905	32A - X4 13A	07/11/25	P	P	P 0.42	S	S	S	PASS	
15804	32A 1PH TAILS - X4 13A	07/11/25	P	P	P 0.14	S	S	S	PASS	
02906	32A - X6 13A	07/11/25	P	P	P 0.33	S	S	S	PASS	
18950	32A 1PH 10M	07/11/25	P	P	P 0.17	P >99.9	S	P 0.10	PASS	
15806	32A 1PH TAILS - X4 13A	07/11/25	P	P	P 0.25	S	S	S	PASS	
15803	32A 1PH TAILS - X4 13A	07/11/25	P	P	P 0.18	S	S	S	PASS	
18946	32A 1PH 10M	07/11/25	P	P	P 0.15	P >99.9	S	P 0.10	PASS	
15808	32A 1PH TAILS - X4 13A	07/11/25	P	P	P 0.16	S	S	S	PASS	
09609	32A TAIL TO 4-WAY 13A	07/11/25	P	P	P 0.22	S	S	S	PASS	
15809	32A 1PH TAILS - X4 13A	07/11/25	P	P	P 0.18	S	S	S	PASS	
18969	32A 1PH 10M	07/11/25	P	P	P 0.14	P >99.9	S	P 0.10	PASS	
15800	32A 1PH TAILS - X4 13A	07/11/25	P	P	P 0.20	S	S	S	PASS	
18951	32A 1PH 10M	07/11/25	P	P	P 0.16	P >99.9	S	P 0.10	PASS	

APPLIANCE DETAILS AND TEST RESULTS
Key
 P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
18952	32A 1PH 10M	07/11/25	P	P	P 0.18	P >99.9	S	P 0.10	PASS
18945	32A 1PH 10M	07/11/25	P	P	P 0.14	P >99.9	S	P 0.10	PASS
18953	32A 1PH 10M	07/11/25	P	P	P 0.14	P >99.9	S	P 0.10	PASS
18955	32A 1PH 10M	07/11/25	P	P	P 0.14	P >99.9	S	P 0.10	PASS
18957	32A 1PH 20M	07/11/25	P	P	P 0.17	P >99.9	S	P 0.10	PASS
31526	32A 3PH 6X 16A DB	07/11/25	P	P	P 0.23	S	S	S	PASS
18958	20M	07/11/25	P	P	P 0.17	P >99.9	S	P 0.10	PASS
18956	32A 1PH 20M	07/11/25	P	P	P 0.17	P >99.9	S	P 0.10	PASS
18970	32A 1PH 20M	07/11/25	P	P	P 0.17	P >99.9	S	P 0.10	PASS
31526	32A 3PH 6X 16A DB	07/11/25	P	P	P 0.23	S	S	S	PASS
31526	32A 3PH 6X 16A DB	07/11/25	P	P	P 0.19	S	S	S	PASS
31526	32A 3PH 6X 16A DB	07/11/25	P	P	P 0.25	S	S	S	PASS
31526	32A 3PH 6X 16A DB	07/11/25	P	P	P 0.23	S	S	S	PASS
31526	32A 3PH 6X 16A DB	07/11/25	P	P	P 0.21	S	S	S	PASS
18947	32A 1PH 10M	07/11/25	P	P	P 0.15	P >99.9	S	P 0.10	PASS
18960	32A 1PH 20M	07/11/25	P	P	P 0.17	P >99.9	S	P 0.10	PASS
18967	32A 1PH 20M	07/11/25	P	P	P 0.17	P >99.9	S	P 0.10	PASS
18968	32A 1PH 20M	07/11/25	P	P	P 0.17	P >99.9	S	P 0.10	PASS
18963	32A 1PH 20M	07/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS
18961	32A 1PH 20M	07/11/25	P	P	P 0.18	P >99.9	S	P 0.10	PASS
18964	32A 1PH 20M	07/11/25	P	P	P 0.17	P >99.9	S	P 0.10	PASS
18966	32A 1PH 20M	07/11/25	P	P	P 0.17	P >99.9	S	P 0.10	PASS
18954	32A 1PH 20M	07/11/25	P	P	P 0.17	P >99.9	S	P 0.10	PASS
14556	16A TO IEC	07/11/25	P	P	P 0.14	S	S	P 0.10	PASS
18959	32A 1PH 20M	07/11/25	P	P	P 0.17	P >99.9	S	P 0.10	PASS
18965	32A 1PH 20M	07/11/25	P	P	P 0.17	P >99.9	S	P 0.10	PASS
31539	63A 3PH - X3 32 1PH X6 16A DB	10/11/25	P	P	P 0.39	S	S	S	PASS
31541	125A 3PH DB 2X63 3PH	10/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
31541	125A 3PH DB 2X63 3PH	10/11/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
31539	63A 3PH - X3 32 1PH X6 16A DB	10/11/25	P	P	P 0.29	S	S	S	PASS
31539	63A 3PH - X3 32 1PH X6 16A DB	10/11/25	P	P	P 0.31	S	S	S	PASS
31539	63A 3PH - X3 32 1PH X6 16A DB	10/11/25	P	P	P 0.28	S	S	S	PASS
31539	63A 3PH - X3 32 1PH X6 16A DB	10/11/25	P	P	P 0.41	S	S	S	PASS
31539	63A 3PH - X3 32 1PH X6 16A DB	10/11/25	P	P	P 0.37	S	S	S	PASS
31539	63A 3PH - X3 32 1PH X6 16A DB	10/11/25	P	P	P 0.36	S	S	S	PASS
31539	63A 3PH - X3 32 1PH X6 16A DB	10/11/25	P	P	P 0.34	S	S	S	PASS
31539	63A 3PH - X3 32 1PH X6 16A DB	10/11/25	P	P	P 0.36	S	S	S	PASS
17880	32A 3PH 20M	11/11/25	P	P	P 0.16	P >99.9	S	P 0.27	PASS
15798	32A 3PH - 6X 15A	11/11/25	P	P	P 0.33	S	S	S	PASS
15252	20M	11/11/25	P	P	P 0.16	P >99.9	S	P 0.23	PASS
15798	32A 3PH - 6X 15A	11/11/25	P	P	P 0.25	S	S	S	PASS
15798	32A 3PH - 6X 15A	11/11/25	P	P	P 0.29	S	S	S	PASS
15798	32A 3PH - 6X 15A	11/11/25	P	P	P 0.25	S	S	S	PASS
15798	32A 3PH - 6X 15A	11/11/25	P	P	P 0.30	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.26	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.27	S	S	S	PASS
15798	32A 3PH - 6X 15A	11/11/25	P	P	P 0.31	S	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
15798	32A 3PH - 6X 15A	11/11/25	P	P	P 0.30	S	S	S	PASS
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	11/11/25	P	P	P 0.20	S	S	S	PASS
31557	63A 3PH 3X32A 9X 16A	11/11/25	P	P	P 0.31	S	S	S	PASS
32012	25M	11/11/25	P	P	P 0.28	P 12.60	S	P 0.27	PASS
31557	63A 3PH 3X32A 9X 16A	11/11/25	P	P	P 0.34	S	S	S	PASS
31557	63A 3PH 3X32A 9X 16A	11/11/25	P	P	P 0.30	S	S	S	PASS
31557	63A 3PH 3X32A 9X 16A	11/11/25	P	P	P 0.26	S	S	S	PASS
15798	32A 3PH - 6X 15A	11/11/25	P	P	P 0.26	S	S	S	PASS
15798	32A 3PH - 6X 15A	11/11/25	P	P	P 0.28	S	S	S	PASS
15798	32A 3PH - 6X 15A	11/11/25	P	P	P 0.29	S	S	S	PASS
31557	63A 3PH 3X32A 9X 16A	11/11/25	P	P	P 0.35	S	S	S	PASS
15798	32A 3PH - 6X 15A	11/11/25	P	P	P 0.27	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.23	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.16	S	S	S	PASS
31557	63A 3PH 3X32A 9X 16A	11/11/25	P	P	P 0.47	S	S	S	PASS
31557	63A 3PH 3X32A 9X 16A	11/11/25	P	P	P 0.36	S	S	S	PASS
31557	63A 3PH 3X32A 9X 16A	11/11/25	P	P	P 0.41	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.18	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.20	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.28	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.28	S	S	S	PASS
30005	32A THRU 3X16A	11/11/25	P	P	P 0.30	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.24	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.25	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.24	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.16	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.26	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.17	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.29	S	S	S	PASS
30005	32A THRU 3X16A	11/11/25	P	P	P 0.25	S	S	S	PASS
30005	32A THRU 3X16A	11/11/25	P	P	P 0.29	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.18	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.37	S	S	S	PASS
30807	125A 12X 16A 6X 32A 1PH	11/11/25	P	P	P 0.40	S	S	S	PASS
31557	63A 3PH 3X32A 9X 16A	11/11/25	P	P	P 0.31	S	S	S	PASS
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	11/11/25	P	P	P 0.25	S	S	S	PASS
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	11/11/25	P	P	P 0.21	S	S	S	PASS
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	11/11/25	P	P	P 0.24	S	S	S	PASS
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	11/11/25	P	P	P 0.27	S	S	S	PASS
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	11/11/25	P	P	P 0.23	S	S	S	PASS
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	11/11/25	P	P	P 0.28	S	S	S	PASS
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	11/11/25	P	P	P 0.24	S	S	S	PASS
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	11/11/25	P	P	P 0.25	S	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
31557	63A 3PH 3X32A 9X 16A	11/11/25	P	P	P 0.34	S	S	S	PASS	
31557	63A 3PH 3X32A 9X 16A	11/11/25	P	P	P 0.42	S	S	S	PASS	
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	11/11/25	P	P	P 0.22	S	S	S	PASS	
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	11/11/25	P	P	P 0.21	S	S	S	PASS	
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	11/11/25	P	P	P 0.26	S	S	S	PASS	
06968	5M BLUE	12/11/25	P	P	P 2.77	P >99.9	S	P 0.10	PASS	
15511	3M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS	
14832	3M BLUE	12/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS	
16118	10M BLUE	12/11/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS	
07686	3M BLUE	12/11/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS	
08033	3M BLUE	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS	
16147	3M BLUE	12/11/25	P	P	P 0.70	P >99.9	S	P 0.10	PASS	
10660	5M BLUE	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS	
10944	5M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS	
06964	5M BLUE	12/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS	
31527	32A3PH DB 6X16A	12/11/25	P	P	P 0.33	S	S	S	PASS	
12119	5M BLUE	12/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS	
32019	3M BLUE	12/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS	
15679	20M BLUE	12/11/25	P	P	P 0.37	P >99.9	S	P 0.11	PASS	
31554	32A 3PH DB 6X16A	12/11/25	P	P	P 0.28	S	S	S	PASS	
08075	1M BLUE	12/11/25	P	P	P 0.19	P >99.9	S	P 0.10	PASS	
31554	32A 3PH DB 6X16A	12/11/25	P	P	P 0.31	S	S	S	PASS	
31554	32A 3PH DB 6X16A	12/11/25	P	P	P 0.28	S	S	S	PASS	
31554	32A 3PH DB 6X16A	12/11/25	P	P	P 0.31	S	S	S	PASS	
12118	10M BLUE	12/11/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS	
31521A	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.20	P >99.9	S	P 0.10	PASS	
31521A	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS	
31521	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.19	S	S	S	PASS	
16270	30M BLUE	12/11/25	P	P	P 0.35	P >99.9	S	P 0.34	PASS	
15837	30M BLUE	12/11/25	P	P	P 0.44	P >99.9	S	P 0.17	PASS	
31521A	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS	
31544	32A1PH DB 6X16A	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS	
31544	32A1PH DB 6X16A	12/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS	
31544	32A1PH DB 6X16A	12/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS	
31521A	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS	
31544	32A1PH DB 6X16A	12/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS	
31544	32A1PH DB 6X16A	12/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS	
07683	3M BLUE	12/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS	
14213	20M BLUE	12/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS	
16720	30M BLUE	12/11/25	P	P	P 0.47	P >99.9	S	P 0.19	PASS	
16120	10M BLUE	12/11/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS	
16145	3M BLUE	12/11/25	P	P	P 0.40	P >99.9	S	P 0.10	PASS	
16117	10M BLUE	12/11/25	P	P	P 0.37	P >99.9	S	P 0.10	PASS	
07861	10M BLUE	12/11/25	P	P	P 0.43	P >99.9	S	P 0.10	PASS	
10652	3M BLUE	12/11/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS	
12056	10M BLUE	12/11/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS	

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
14119	20M BLUE	12/11/25	P	P	P 0.35	P >99.9	S	P 0.10	PASS
15661	20M BLUE	12/11/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS
32018	5M BLUE	12/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
14590	16A CABLE 20M	12/11/25	P	P	P 0.28	S	S	S	PASS
08071	5M BLUE	12/11/25	P	P	P 0.30	P >99.9	S	P 0.24	PASS
10726	5M BLUE	12/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
16148	3M BLUE	12/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
09664	5M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
07637	5M BLUE	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
14789	5M BLUE	12/11/25	P	P	P 0.46	P >99.9	S	P 0.10	PASS
08070	3M BLUE	12/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
09665	5M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
07210	5M BLUE	12/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
16146	3M BLUE	12/11/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS
16472	3M BLUE	12/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
11522	20M BLUE	12/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
07391	5M BLUE	12/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
08058	3M BLUE	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
10669	20M BLUE	12/11/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS
05985	1M BLUE	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
07564	1M BLUE	12/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
16722	3M BLUE	12/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
16721	3M BUE	12/11/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
07212	3M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
07689	3M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
14129	30M BLUE	12/11/25	P	P	P 0.46	P >99.9	S	P 0.17	PASS
16717	20M BLUE	12/11/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS
16719	20M BLUE	12/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
19870	5M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
32023	13A IEC ADAPTER	12/11/25	P	P	P 0.19	S	S	P 0.10	PASS
31533	32A 3PH DB 6X16A	12/11/25	P	P	P 0.25	S	S	S	PASS
31533	32A 3PH DB 6X16A	12/11/25	P	P	P 0.24	S	S	S	PASS
31533	32A 3PH DB 6X16A	12/11/25	P	P	P 0.28	S	S	S	PASS
15660	5M BLUE	12/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
10655	3M BLUE	12/11/25	P	P	P 0.52	P >99.9	S	P 0.10	PASS
08064	3M BLUE	12/11/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS
16715	5M BLUE	12/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
31527	32A3PH DB 6X16A	12/11/25	P	P	P 0.32	S	S	S	PASS
31554	32A 3PH DB 6X16A	12/11/25	P	P	P 0.28	S	S	S	PASS
31527	32A3PH DB 6X16A	12/11/25	P	P	P 0.29	S	S	S	PASS
31527	32A3PH DB 6X16A	12/11/25	P	P	P 0.24	S	S	S	PASS
14122	3M BLUE	12/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
19869	3M BLUE	12/11/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
07681	3M BLUE	12/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
08043	3M BLUE	12/11/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS
16268	50M BLUE	12/11/25	P	P	P 0.56	P >99.9	S	P 0.28	PASS
16532	30M BLUE	12/11/25	P	P	P 0.43	P >99.9	S	P 0.17	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
31533	32A 3PH DB 6X16A	12/11/25	P	P	P 0.25	S	S	S	PASS
31533	32A 3PH DB 6X16A	12/11/25	P	P	P 0.26	S	S	S	PASS
31554	32A 3PH DB 6X16A	12/11/25	P	P	P 0.27	S	S	S	PASS
16142	3M BLUE	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
12108	3M BLUE	12/11/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
31533	32A 3PH DB 6X16A	12/11/25	P	P	P 0.24	S	S	S	PASS
1494	10M BLUE	12/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
1495	10M BLUE	12/11/25	P	P	P 0.35	P >99.9	S	P 0.10	PASS
1488	5M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
1496	10M BLUE	12/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
1490	10M BLUE	12/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
1497	20M BLUE	12/11/25	P	P	P 0.43	P >99.9	S	P 0.10	PASS
1498	10M BLUE	12/11/25	P	P	P 0.59	P >99.9	S	P 0.10	PASS
1481		12/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
1486	5M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
1487	5M BLUE	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
1485	5M BLUE	12/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
1479	3M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
1482	5M BLUE	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
1480	3M BLUE	12/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
1478	3M BLUE	12/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
31544	32A1PH DB 6X16A	12/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
31519	32A1PH DB 6X16A	12/11/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
31543	32A1PH DB 6X16A	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
31519	32A1PH DB 6X16A	12/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
31543	32A1PH DB 6X16A	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
31519	32A1PH DB 6X16A	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
31519	32A1PH DB 6X16A	12/11/25	P	P	P 0.20	P >99.9	S	P 0.10	PASS
31543	32A1PH DB 6X16A	12/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
1493	10M BLUE	12/11/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
1491	10M BLUE	12/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
1489	10M BLUE	12/11/25	P	P	P 0.31	P >99.9	S	P 0.14	PASS
1492	10M BLUE	12/11/25	P	P	P 0.47	P >99.9	S	P 0.10	PASS
31543	32A1PH DB 6X16A	12/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
31519	32A1PH DB 6X16A	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
31519	32A1PH DB 6X16A	12/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
1483	5M BLUE	12/11/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS
32015	5M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
16529	5M BLUE	12/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
14442	3M BLUE	12/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
12811	5M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
1499	10M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
1500	10M BLUE	12/11/25	P	P	P 0.80	P >99.9	S	P 0.10	PASS
14791	5M BLUE	12/11/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
1472	1M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
1475	3M BLUE	12/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
1473	1M BLUE	12/11/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
1474	1M BLUE	12/11/25	P	P	P 0.65	P >99.9	S	P 0.10	PASS
1477	3M BLUE	12/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
1472	1M BLUE	12/11/25	P	P	P 0.37	P >99.9	S	P 0.10	PASS
1471	16A 1M BLUE	12/11/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
1476	3M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
07200	5M BLUE	12/11/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
14793	5M BLUE	12/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
14792	5M BLUE	12/11/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS
19871	3M BLUE	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
1484	5M BLUE	12/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
32017	5M BLUE	12/11/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
14775	5M BLUE	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
10665	5M BLUE	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
07201	5M BLUE	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
14117	5M BLUE	12/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
06494	10M BLUE	12/11/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
32016	5M BLUE	12/11/25	P	P	P 0.27	P >99.9	S	P 0.36	PASS
06876	5M BLUE	12/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18240	5M BLUE	12/11/25	P	P	P 0.41	P >99.9	S	P 0.10	PASS
14762	5M BLUE	12/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
31520A	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
31522	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.18	S	S	S	PASS
31527	32A3PH DB 6X16A	12/11/25	P	P	P 0.31	S	S	S	PASS
31520	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.17	S	S	S	PASS
31522A	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
31520A	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
31520A	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
31522A	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
31522A	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
31520A	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS
31543	32A1PH DB 6X16A	12/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
31543	32A1PH DB 6X16A	12/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS
31522A	32A1PH DB 4X16A THRU	12/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS
32056	16A 10M BLUE	13/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
32063	16A 5M BLUE	13/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
32055	16A 10M BLUE	13/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32059	16A 10M BLUE	13/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
32057	16A 10M BLUE	13/11/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
32061	16A 5M BLUE	13/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
32054	16A 10M BLUE	13/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32060	16A 10M BLUE	13/11/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
32064	16A 5M	13/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
32062	16A 5M BLUE	13/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
16718	16A 10M BLUE	13/11/25	P	P	P 0.35	P >99.9	S	P 0.10	PASS
11516	16A 10M BLUE	13/11/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS
16716	16A 5M BLUE	13/11/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
14767	16A 10M BLUE	13/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
10929	16A 5M BLUE	13/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
16124	16A 10M BLUE	13/11/25	P	P	P 0.44	P >99.9	S	P 0.10	PASS
32058	16A 10M BLUE	13/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
15835	16A 5M BLUE	13/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
32064	16A 5M	13/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
32079	16A 5M BLUE	13/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
32047	16A 10M BLUE	13/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32069	16A 5M BLUE	13/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
31538	125A 3PH - X6 32A 3PH DB	13/11/25	P	P	P 0.13	S	S	P 0.10	PASS
31538	125A 3PH - X6 32A 3PH DB	13/11/25	P	P	P 0.15	S	S	P 0.10	PASS
32076	16A 5M BLUE	13/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
11315	16A 10M BLUE	13/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
32077	16A 5M BLUE	13/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
32075	16A 5M BLUE	13/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
31538	125A 3PH - X6 32A 3PH DB	13/11/25	P	P	P 0.13	S	S	P 0.10	PASS
32066	16A 5M BLUE	13/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
31538	125A 3PH - X6 32A 3PH DB	13/11/25	P	P	P 0.13	S	S	P 0.10	PASS
31538	125A 3PH - X6 32A 3PH DB	13/11/25	P	P	P 0.16	S	S	P 0.10	PASS
32068	16A 5M BLUE	13/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
32065	16A 5M	13/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
31538	125A 3PH - X6 32A 3PH DB	13/11/25	P	P	P 0.12	S	S	P 0.10	PASS
32067	16A 5M	13/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
32052	16A 10M BLUE	13/11/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
32053	16A 10M BLUE	13/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
32051	16A 10M BLUE	13/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32045	16A 20M BLUE	13/11/25	P	P	P 0.37	P >99.9	S	P 0.11	PASS
32048	16A 10M BLUE	13/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
32046	16A 10M BLUE	13/11/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
32044	16A 10M BLUE	13/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
32049	16A 10M BLUE	13/11/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
32070	16A 5M BLUE	13/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32071	16A 5M BLUE	13/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
32078	16A 5M	13/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
32072	16A 5M BLUE	13/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
32050	16A 10M BLUE	13/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
32073	16A 5M BLUE	13/11/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS
32074	16A 5M BLUE	13/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
12974	16A 10M BLUE	13/11/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
16130	16A 10M BLUE	13/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
14831	16A 10M BLUE	13/11/25	P	P	P 0.53	P >99.9	S	P 0.10	PASS
32038	16A 5M BLUE	13/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS
32037	16A 5M BLUE	13/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
14120	16A 50M BLUE	13/11/25	P	P	P 0.65	P >99.9	S	P 0.34	PASS
14121	16A 50M BLUE	13/11/25	P	P	P 0.55	P >99.9	S	P 0.28	PASS
11320	16A 20M BLUE	13/11/25	P	P	P 0.36	P >99.9	S	P 0.10	PASS
16137	16A 10M BLUE	13/11/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
12388	16A 10M BLUE	13/11/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
32039	16A 10M BLUE	13/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32041	16A 20M BLUE	13/11/25	P	P	P 0.32	P >99.9	S	P 0.12	PASS
32040	16A 5M BLUE	13/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
16126	16A 10M BLUE	13/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
32033	16A 10M BLUE	13/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
32034	16A 5M BLUE	13/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS
32036	16A 10M BLUE	13/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32035	16A 10M BLUE	13/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32043	16A 20M BLUE	13/11/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
32042	16A 10M BLUE	13/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
32026	16A 20M BLUE	13/11/25	P	P	P 0.36	P >99.9	S	P 0.15	PASS
14760	16A 20M BLUE	13/11/25	P	P	P 0.54	P >99.9	S	P 0.12	PASS
11537	16A 20M	13/11/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS
16713	16A 20M BLUE	13/11/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
32027	16A 20M BLUE	13/11/25	P	P	P 0.40	P >99.9	S	P 0.15	PASS
14784	16A 50M BLUE	13/11/25	P	P	P 0.62	P >99.9	S	P 0.29	PASS
14824	16A 20M BLUE	13/11/25	P	P	P 0.34	P >99.9	S	P 0.12	PASS
14118	16A 20M BLUE	13/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
14824	16A 20M BLUE	13/11/25	P	P	P 0.36	P >99.9	S	P 0.12	PASS
32025	13A IEC	13/11/25	P	P	P 0.12	S	S	P 0.10	PASS
16531	16A 50M BLUE	13/11/25	P	P	P 0.93	P >99.9	S	P 0.29	PASS
15836	16A 10M BLUE	13/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
12559	16A 10M BLUE	13/11/25	P	P	P 0.36	P >99.9	S	P 0.10	PASS
16136	16A 10M BLUE	13/11/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
10965	16A 20M BLUE	13/11/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS
16128	16A 10M BLUE	13/11/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
16115	16A 10M BLUE	13/11/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
14497	16A 10M BLUE	13/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
14115	16A 10M BLUE	13/11/25	P	P	P 0.36	P >99.9	S	P 0.10	PASS
16135	16A 10M BLUE	13/11/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
14496	16A 10M BLUE	13/11/25	P	P	P 0.44	P >99.9	S	P 0.10	PASS
12409	16A 10M BLUE	13/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
14197	16A 10M BLUE	13/11/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS
32031	16A 5M BLUE	13/11/25	P	P	P 0.20	P >99.9	S	P 0.10	PASS
09659	16A 10M BLUE	13/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
16116	16A 10M BLUE	13/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
12534	16A 10M BLUE	13/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
32029	16A 10M BLUE	13/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32032	16A 5M BLUE	13/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS
32030	16A 10M BLUE	13/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
10662	16A 5M BLUE	14/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
07203	16A 5M BLUE	14/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
07660	16A 5M BLUE	14/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
07666	16A 5M BLUE	14/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
11533	16A 5M BLUE	14/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
08045	16A 3M BLUE	14/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
12112	16A 3M BLUE	14/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
14441	16A 5M BLUE	14/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
07678	16A 3M BLUE	14/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
07565	16A 1M BLUE	14/11/25	P	P	P 0.19	P >99.9	S	P 0.10	PASS
07537	16A 1M BLUE	14/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
07543	16A 1M BLUE	14/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
15349	16A SPLIT BLUE	14/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
10666	16A 5M BLUE	14/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
11314	16A 5M BLUE	14/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
09733	16A 3M BLUE	14/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
07646	16A 5M BLUE	14/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
14827	16A 5M BLUE	14/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
08049	16A 3M BLUE	14/11/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
15512	16A 3M BLUE	14/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
14765	16A 3M BLUE	14/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
10664	16A 5M BLUE	14/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
10670	16A 3M BLUE	14/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
14470	16A 5M BLUE	14/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
08030	16A 3M BLUE	14/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS
12113	16A 3M BLUE	14/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
18239	16A 5M BLUE	14/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
05002	16A 5M BLUE	14/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
07650	16A 5M BLUE	14/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
07649	16A 5M BLUE	14/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
08068	16A 3M BLUE	14/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32080	16A 5M BLUE	14/11/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
11530	16A 5M BLUE	14/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
16726	16A 3M BLUE	14/11/25	P	P	P 0.20	P >99.9	S	P 0.10	PASS
11528	16A 5M BLUE	14/11/25	P	P	P 0.46	P >99.9	S	P 0.10	PASS
32081	16A 3M BLUE	14/11/25	P	P	P 0.76	P >99.9	S	P 0.10	PASS
16138	16A 10M BLUE	14/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
10629	16A 1M BLUE	14/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
08040	16A 3M BLUE	14/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
07552	16A 1M BLUE	14/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
16527	16A 5M BLUE	14/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
07541	16A 1M BLUE	14/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS
08074	16A 1M BLUE	14/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
07562	16A 1M BLUE	14/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
07548	16A 1M BLUE	14/11/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS
07546	16A 1M BLUE	14/11/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
17382	16A 1M BLUE	14/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS
07559	16A 1M BLUE	14/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32082	16A 3M BLUE	14/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
14826	16A 5M BLUE	14/11/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
07561	16A 1M BLUE	14/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
07394	16A 5M BLUE	14/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18156	16A 20M	17/11/25	P	P	P 0.35	P >99.9	S	P 0.11	PASS
16748	16A 20M	17/11/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
17316	16A 20M	17/11/25	P	P	P 0.34	P >99.9	S	P 0.16	PASS	
18146	16A 20M	17/11/25	P	P	P 0.34	P >99.9	S	P 0.11	PASS	
16648	16A 20M	17/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS	
18092	16A 20M	17/11/25	P	P	P 0.33	P >99.9	S	P 0.11	PASS	
18184	16A 20M	17/11/25	P	P	P 0.35	P >99.9	S	P 0.11	PASS	
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	17/11/25	P	P	P 0.22	S	S	S	PASS	
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	17/11/25	P	P	P 0.28	S	S	S	PASS	
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	17/11/25	P	P	P 0.23	S	S	S	PASS	
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	17/11/25	P	P	P 0.25	S	S	S	PASS	
32085		17/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS	
32085		17/11/25	P	P	P 0.18	P >99.9	S	P 0.10	PASS	
32085		17/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS	
32084	32A1PH DB 4X16A	17/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS	
14608	16A 20M	17/11/25	P	P	P 0.31	P >99.9	S	P 0.15	PASS	
14835	16A 20M	17/11/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS	
17634	16A 20M	17/11/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS	
18148	16A 20M	17/11/25	P	P	P 0.37	P >99.9	S	P 0.11	PASS	
17352	16A 20M	17/11/25	P	P	P 0.35	P >99.9	S	P 0.15	PASS	
18096	16A 20M	17/11/25	P	P	P 0.32	P >99.9	S	P 0.11	PASS	
17340	16A 20M	17/11/25	P	P	P 0.33	P >99.9	S	P 0.16	PASS	
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	17/11/25	P	P	P 0.19	S	S	S	PASS	
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	17/11/25	P	P	P 0.16	S	S	S	PASS	
15844	16A 20M	17/11/25	P	P	P 0.36	P >99.9	S	P 0.11	PASS	
31674A		17/11/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS	
30124	16A - X4 13A	17/11/25	P	P	P 0.23	S	S	P 0.10	PASS	
31674A		17/11/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS	
31674B	63A 3PH TO 6X32A1PH,6X16A	17/11/25	P	P	P 0.36	P >99.9	S	P 0.10	PASS	
30378	125A DB 6X 16A 12X 32A 1PH 2X 32A 3PH THRU	17/11/25	P	P	P 0.19	S	S	S	PASS	
32001	63A 1PH - X2 13A - X4 32A 1PH - X11 16A	17/11/25	P	P	P 0.28	S	S	P 2.81	PASS	
32001	63A 1PH - X2 13A - X4 32A 1PH - X11 16A	17/11/25	P	P	P 0.22	S	S	P 2.82	PASS	
32001	63A 1PH - X2 13A - X4 32A 1PH - X11 16A	17/11/25	P	P	P 0.24	S	S	P 2.80	PASS	
32001	63A 1PH - X2 13A - X4 32A 1PH - X11 16A	17/11/25	P	P	P 0.33	S	S	P 2.81	PASS	
31674B	63A 3PH TO 6X32A1PH,6X16A	17/11/25	P	P	P 0.41	P >99.9	S	P 0.10	PASS	
31674B	63A 3PH TO 6X32A1PH,6X16A	17/11/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS	
18710	16A 20M	17/11/25	P	P	P 0.35	P >99.9	S	P 0.10	PASS	
17323	16A 20M	17/11/25	P	P	P 0.34	P >99.9	S	P 0.16	PASS	
31674B	63A 3PH TO 6X32A1PH,6X16A	17/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS	
31674A		17/11/25	P	P	P 0.41	P >99.9	S	P 0.10	PASS	
31674A		17/11/25	P	P	P 0.35	P >99.9	S	P 0.10	PASS	
31674B	63A 3PH TO 6X32A1PH,6X16A	17/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS	
31674B	63A 3PH TO 6X32A1PH,6X16A	17/11/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS	
18160	16A 20M	17/11/25	P	P	P 0.34	P >99.9	S	P 0.11	PASS	
09473	16A 20M	17/11/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS	
18501	16A T-LINE - TRUCON	17/11/25	P	P	P 0.13	S	S	P 0.10	PASS	

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
32094	32A 1PH - X4 16A	17/11/25	P	P	P 0.26	S	S	P 0.10	PASS
14589	16A 20M	17/11/25	P	P	P 0.34	P >99.9	S	P 0.15	PASS
18182	16A 20M	17/11/25	P	P	P 0.33	P >99.9	S	P 0.11	PASS
18360	16A 20M	17/11/25	P	P	P 0.35	P >99.9	S	P 0.10	PASS
18091	16A 20M	17/11/25	P	P	P 0.33	P >99.9	S	P 0.11	PASS
14576	16A 20M	17/11/25	P	P	P 0.34	P >99.9	S	P 0.16	PASS
15988	32A 1PH INLINE 13A	17/11/25	P	P	P 0.30	S	S	P 0.10	PASS
18371	16A 5M	17/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
32096	13A - TRUCON	17/11/25	P	P	P 0.20	S	S	P 0.10	PASS
31985	16A - X4 13A	17/11/25	P	P	P 0.22	S	S	P 0.10	PASS
16709	16A 20M	17/11/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
32094	32A 1PH - X4 16A	17/11/25	P	P	P 0.36	S	S	P 0.10	PASS
32094	32A 1PH - X4 16A	17/11/25	P	P	P 0.21	S	S	P 0.10	PASS
18190	16A 20M	17/11/25	P	P	P 0.35	P >99.9	S	P 0.11	PASS
32094	32A 1PH - X4 16A	17/11/25	P	P	P 0.31	S	S	P 0.10	PASS
32093	32A 1PH TAILS - X6 16A	17/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32093	32A 1PH TAILS - X6 16A	17/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32093	32A 1PH TAILS - X6 16A	17/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
32092	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
31674A		17/11/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
31674A		17/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
32093	32A 1PH TAILS - X6 16A	17/11/25	P	P	P 0.20	P >99.9	S	P 0.10	PASS
31697	32A 3PH DB 9X16A THUR MCB	17/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32089	32A3PH DB 9X16A RCBO	17/11/25	P	P	P 0.31	S	S	S	PASS
32089	32A3PH DB 9X16A RCBO	17/11/25	P	P	P 0.34	S	S	S	PASS
32089	32A3PH DB 9X16A RCBO	17/11/25	P	P	P 0.35	S	S	S	PASS
31697A	32A 3PH DB 9X16 THRU	17/11/25	P	P	P 0.29	S	S	S	PASS
32089	32A3PH DB 9X16A RCBO	17/11/25	P	P	P 0.26	S	S	S	PASS
31697A	32A 3PH DB 9X16 THRU	17/11/25	P	P	P 0.27	S	S	S	PASS
31697A	32A 3PH DB 9X16 THRU	17/11/25	P	P	P 0.30	S	S	S	PASS
31674	63A 3PH - X6 32A 1PH, X6 16A	17/11/25	P	P	P 0.30	S	S	S	PASS
32091	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32092	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.19	P >99.9	S	P 0.10	PASS
32092	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS
32091	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32083	32A1PH DB 4X16A	17/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
32083	32A1PH DB 4X16A	17/11/25	P	P	P 0.20	P >99.9	S	P 0.10	PASS
32091	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
32090	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.21	P >99.9	S	P 0.10	PASS
32092	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32093	32A 1PH TAILS - X6 16A	17/11/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
32093	32A 1PH TAILS - X6 16A	17/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32090	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
32090	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.19	P >99.9	S	P 0.10	PASS
32090	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
32091	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
32089	32A3PH DB 9X16A RCBO	17/11/25	P	P	P 0.29	S	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
32089	32A3PH DB 9X16A RCBO	17/11/25	P	P	P 0.31	S	S	S	PASS
32087	32A1PH 4X16A	17/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
32089	32A3PH DB 9X16A RCBO	17/11/25	P	P	P 0.31	S	S	S	PASS
32089	32A3PH DB 9X16A RCBO	17/11/25	P	P	P 0.35	S	S	S	PASS
32087	32A1PH 4X16A	17/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
32088	32A1PH DB 4X16A	17/11/25	P	P	P 0.23	P >99.9	S	P 0.10	PASS
31697A	32A 3PH DB 9X16 THRU	17/11/25	P	P	P 0.28	S	S	S	PASS
32087	32A1PH 4X16A	17/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32088	32A1PH DB 4X16A	17/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32083	32A1PH DB 4X16A	17/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
32084	32A1PH DB 4X16A	17/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32085		17/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32083	32A1PH DB 4X16A	17/11/25	P	P	P 0.20	P >99.9	S	P 0.10	PASS
32084	32A1PH DB 4X16A	17/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
32088	32A1PH DB 4X16A	17/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32088	32A1PH DB 4X16A	17/11/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
32084	32A1PH DB 4X16A	17/11/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
32087	32A1PH 4X16A	17/11/25	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32086	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32086	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
31697A	32A 3PH DB 9X16 THRU	17/11/25	P	P	P 0.26	S	S	S	PASS
31697A	32A 3PH DB 9X16 THRU	17/11/25	P	P	P 0.28	S	S	S	PASS
32086	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.22	P >99.9	S	P 0.10	PASS
31697A	32A 3PH DB 9X16 THRU	17/11/25	P	P	P 0.29	S	S	S	PASS
32089	32A3PH DB 9X16A RCBO	17/11/25	P	P	P 0.40	S	S	S	PASS
15791	63A 3PH TO 125A 3PH	17/11/25	P	P	P 0.45	S	S	P 0.10	PASS
32086	32A 1PH TAILS - X4 16A	17/11/25	P	P	P 0.18	P >99.9	S	P 0.10	PASS
31697A	32A 3PH DB 9X16 THRU	17/11/25	P	P	P 0.30	S	S	S	PASS
31697A	32A 3PH DB 9X16 THRU	17/11/25	P	P	P 0.26	S	S	S	PASS
10821	16A TO 32A 1PH	19/11/25	P	P	P 0.22	S	S	P 0.10	PASS
17951	13A TO 16A	19/11/25	P	P	P 0.20	S	S	P 0.10	PASS
18005	10M	19/11/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
19005	16A TO TRUEONE	24/11/25	P	P	P 0.15	S	S	P 0.10	PASS
19006	16A TO TRUCON	24/11/25	P	P	P 0.24	S	S	P 0.10	PASS
17867	13A TO IEC	26/11/25	P	P	P 0.17	S	S	P 0.10	PASS
18131	20M 13A CABLE	26/11/25	P	P	P 0.56	P >99.9	S	P 0.10	PASS
31516	13A TO 16A WHITE	27/11/25	P	P	P 0.23	S	S	P 0.10	PASS
10647		28/11/25	P	P	P 1.23	P >99.9	S	P 0.10	PASS
15263		28/11/25	P	P	P 1.86	P >99.9	S	P 0.10	PASS
15324		28/11/25	P	P	P 0.94	P >99.9	S	P 0.10	PASS
14722		28/11/25	P	P	P 1.29	P >99.9	S	P 0.10	PASS
15277		28/11/25	P	P	P 2.19	P >99.9	S	P 0.10	PASS
15251		28/11/25	P	P	P 1.77	P >99.9	S	P 0.10	PASS
07810		28/11/25	P	P	P 1.67	P >99.9	S	P 0.10	PASS
10777		28/11/25	P	P	P 1.10	P >99.9	S	P 0.10	PASS
15241		28/11/25	P	P	P 1.05	P >99.9	S	P 0.10	PASS
15296		28/11/25	P	P	P 2.61	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
15259		28/11/25	P	P	P 1.10	P >99.9	S	P 0.10	PASS	
05179		28/11/25	P	P	P 0.95	P >99.9	S	P 0.10	PASS	
10616	15A CABLE 10M	04/12/25	P	P	P 0.47	P >99.9	S	P 0.10	PASS	
15269	15A CABLE 10M	04/12/25	P	P	P 0.47	P >99.9	S	P 0.10	PASS	
15284	15A CABLE 10M	04/12/25	P	P	P 0.41	P >99.9	S	P 0.10	PASS	
15273	15A CABLE 10M	04/12/25	P	P	P 0.55	P >99.9	S	P 0.10	PASS	
15316	15A CABLE 10M	04/12/25	P	P	P 0.43	P >99.9	S	P 0.10	PASS	
15245	15A CABLE 10M	04/12/25	P	P	P 0.53	P >99.9	S	P 0.10	PASS	
15330	15A CABLE 10M	04/12/25	P	P	P 0.54	P >99.9	S	P 0.10	PASS	
15244	15A CABLE 10M	04/12/25	P	P	P 0.52	P >99.9	S	P 0.10	PASS	
15318	15A CABLE 10M	04/12/25	P	P	P 0.48	P >99.9	S	P 0.10	PASS	
15262	15A CABLE 10M	04/12/25	P	P	P 0.54	P >99.9	S	P 0.10	PASS	
15331	15A CABLE 10M	04/12/25	P	P	P 0.52	P >99.9	S	P 0.10	PASS	
18432	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.11	PASS	
18432	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.11	PASS	
18415	30M	10/12/25	P	P	P 0.45	P >99.9	S	P 0.12	PASS	
18432	30M	10/12/25	P	P	P 0.51	P >99.9	S	P 0.11	PASS	
18417	30M	10/12/25	P	P	P 0.57	P >99.9	S	P 0.12	PASS	
18432	30M	10/12/25	P	P	P 0.47	P >99.9	S	P 0.11	PASS	
18432	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.11	PASS	
18427	30M	10/12/25	P	P	P 0.45	P >99.9	S	P 0.11	PASS	
18427	30M	10/12/25	P	P	P 0.45	P >99.9	S	P 0.11	PASS	
18427	30M	10/12/25	P	P	P 0.51	P >99.9	S	P 0.11	PASS	
18427	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.11	PASS	
18427	30M	10/12/25	P	P	P 0.48	P >99.9	S	P 0.11	PASS	
18415	30M	10/12/25	P	P	P 0.49	P >99.9	S	P 0.11	PASS	
18415	30M	10/12/25	P	P	P 0.53	P >99.9	S	P 0.12	PASS	
18415	30M	10/12/25	P	P	P 0.48	P >99.9	S	P 0.11	PASS	
18414	30M	10/12/25	P	P	P 0.48	P >99.9	S	P 0.12	PASS	
18439	30M	10/12/25	P	P	P 0.55	P >99.9	S	P 0.11	PASS	
18439	30M	10/12/25	P	P	P 0.62	P >99.9	S	P 0.12	PASS	
18414	30M	10/12/25	P	P	P 0.45	P >99.9	S	P 0.12	PASS	
18414	30M	10/12/25	P	P	P 0.51	P >99.9	S	P 0.11	PASS	
18414	30M	10/12/25	P	P	P 0.51	P >99.9	S	P 0.12	PASS	
18414	30M	10/12/25	P	P	P 0.51	P >99.9	S	P 0.12	PASS	
18439	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS	
18417	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS	
18417	30M	10/12/25	P	P	P 0.54	P >99.9	S	P 0.11	PASS	
18417	30M	10/12/25	P	P	P 0.47	P >99.9	S	P 0.12	PASS	
18417	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS	
18414	30M	10/12/25	P	P	P 0.56	P >99.9	S	P 0.12	PASS	
18439	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS	
18432	30M	10/12/25	P	P	P 0.49	P >99.9	S	P 0.11	PASS	
18427	30M	10/12/25	P	P	P 0.47	P >99.9	S	P 0.11	PASS	
18469	40M	10/12/25	P	P	P 0.53	P >99.9	S	P 0.16	PASS	
18468	40	10/12/25	P	P	P 0.52	P >99.9	S	P 0.16	PASS	
18469	40M	10/12/25	P	P	P 0.53	P >99.9	S	P 0.16	PASS	

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
18468	40	10/12/25	P	P	P 0.56	P >99.9	S	P 0.17	PASS
18469	40M	10/12/25	P	P	P 0.59	P >99.9	S	P 0.16	PASS
18469	40M	10/12/25	P	P	P 0.52	P >99.9	S	P 0.16	PASS
18471	40	10/12/25	P	P	P 0.56	P >99.9	S	P 0.16	PASS
18459	40	10/12/25	P	P	P 0.56	P >99.9	S	P 0.16	PASS
18471	40	10/12/25	P	P	P 0.51	P >99.9	S	P 0.17	PASS
18469	40M	10/12/25	P	P	P 0.54	P >99.9	S	P 0.16	PASS
18459	40	10/12/25	P	P	P 0.54	P >99.9	S	P 0.16	PASS
18468	40	10/12/25	P	P	P 0.56	P >99.9	S	P 0.16	PASS
18440		10/12/25	P	P	P 0.45	P >99.9	S	P 0.11	PASS
18438	30M	10/12/25	P	P	P 0.49	P >99.9	S	P 0.11	PASS
18440		10/12/25	P	P	P 0.47	P >99.9	S	P 0.11	PASS
18438	30M	10/12/25	P	P	P 0.47	P >99.9	S	P 0.12	PASS
18438	30M	10/12/25	P	P	P 0.45	P >99.9	S	P 0.12	PASS
18438	30M	10/12/25	P	P	P 0.47	P >99.9	S	P 0.12	PASS
18469	40M	10/12/25	P	P	P 0.54	P >99.9	S	P 0.16	PASS
18468	40	10/12/25	P	P	P 0.62	P >99.9	S	P 0.17	PASS
18468	40	10/12/25	P	P	P 0.53	P >99.9	S	P 0.16	PASS
18438	30M	10/12/25	P	P	P 0.45	P >99.9	S	P 0.12	PASS
18468	40	10/12/25	P	P	P 0.52	P >99.9	S	P 0.17	PASS
18459	40	10/12/25	P	P	P 0.56	P >99.9	S	P 0.15	PASS
18437		10/12/25	P	P	P 0.47	P >99.9	S	P 0.12	PASS
18437		10/12/25	P	P	P 0.49	P >99.9	S	P 0.11	PASS
18437		10/12/25	P	P	P 0.47	P >99.9	S	P 0.12	PASS
18437		10/12/25	P	P	P 0.47	P >99.9	S	P 0.12	PASS
32123		10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS
18421	30M	10/12/25	P	P	P 0.48	P >99.9	S	P 0.11	PASS
18417	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS
18429	30M	10/12/25	P	P	P 0.48	P >99.9	S	P 0.11	PASS
18421	30M	10/12/25	P	P	P 0.48	P >99.9	S	P 0.11	PASS
18421	30M	10/12/25	P	P	P 0.45	P >99.9	S	P 0.11	PASS
18421	30M	10/12/25	P	P	P 0.51	P >99.9	S	P 0.11	PASS
18421	30M	10/12/25	P	P	P 0.43	P >99.9	S	P 0.12	PASS
18468	40	10/12/25	P	P	P 0.53	P >99.9	S	P 0.17	PASS
18471	40	10/12/25	P	P	P 0.74	P >99.9	S	P 0.16	PASS
18468	40	10/12/25	P	P	P 0.56	P >99.9	S	P 0.17	PASS
18459	40	10/12/25	P	P	P 0.53	P >99.9	S	P 0.16	PASS
18471	40	10/12/25	P	P	P 0.54	P >99.9	S	P 0.17	PASS
18471	40	10/12/25	P	P	P 0.56	P >99.9	S	P 0.17	PASS
18421	30M	10/12/25	P	P	P 0.45	P >99.9	S	P 0.12	PASS
18421	30M	10/12/25	P	P	P 0.50	P >99.9	S	P 0.12	PASS
18437		10/12/25	P	P	P 0.44	P >99.9	S	P 0.12	PASS
18471	40	10/12/25	P	P	P 0.53	P >99.9	S	P 0.17	PASS
18437		10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS
18470	40M	10/12/25	P	P	P 0.54	P >99.9	S	P 0.16	PASS
18470	40M	10/12/25	P	P	P 0.54	P >99.9	S	P 0.16	PASS
18470	40M	10/12/25	P	P	P 0.55	P >99.9	S	P 0.16	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
18470	40M	10/12/25	P	P	P 0.55	P >99.9	S	P 0.16	PASS
18470	40M	10/12/25	P	P	P 0.56	P >99.9	S	P 0.16	PASS
18470	40M	10/12/25	P	P	P 0.83	P >99.9	S	P 0.15	PASS
17384	20M	10/12/25	P	P	P 0.37	P >99.9	S	P 0.10	PASS
17384	20M	10/12/25	P	P	P 0.37	P >99.9	S	P 0.10	PASS
17384	20M	10/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
17384	20M	10/12/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
17384	20M	10/12/25	P	P	P 0.37	P >99.9	S	P 0.10	PASS
17594	20M	10/12/25	P	P	P 0.56	P >99.9	S	P 0.10	PASS
17597	20M	10/12/25	P	P	P 0.59	P >99.9	S	P 0.10	PASS
17597	20M	10/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
17597	20M	10/12/25	P	P	P 0.37	P >99.9	S	P 0.10	PASS
17597	20M	10/12/25	P	P	P 0.49	P >99.9	S	P 0.10	PASS
17597	20M	10/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
17597	20M	10/12/25	P	P	P 0.41	P >99.9	S	P 0.10	PASS
17594	20M	10/12/25	P	P	P 0.37	P >99.9	S	P 0.10	PASS
17594	20M	10/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
17594	20M	10/12/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
17594	20M	10/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
17594	20M	10/12/25	P	P	P 0.36	P >99.9	S	P 0.10	PASS
17384	20M	10/12/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
18430	30M	10/12/25	P	P	P 0.55	P >99.9	S	P 0.11	PASS
18430	30M	10/12/25	P	P	P 0.53	P >99.9	S	P 0.12	PASS
18459	40	10/12/25	P	P	P 0.59	P >99.9	S	P 0.16	PASS
18430	30M	10/12/25	P	P	P 0.49	P >99.9	S	P 0.12	PASS
18459	40	10/12/25	P	P	P 0.58	P >99.9	S	P 0.16	PASS
18430	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS
18427	30M	10/12/25	P	P	P 0.47	P >99.9	S	P 0.11	PASS
18438	30M	10/12/25	P	P	P 0.48	P >99.9	S	P 0.12	PASS
18438	30M	10/12/25	P	P	P 0.44	P >99.9	S	P 0.12	PASS
18434		10/12/25	P	P	P 0.50	P >99.9	S	P 0.12	PASS
18438	30M	10/12/25	P	P	P 0.54	P >99.9	S	P 0.11	PASS
18440		10/12/25	P	P	P 0.50	P >99.9	S	P 0.11	PASS
17595		10/12/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
17595		10/12/25	P	P	P 0.37	P >99.9	S	P 0.10	PASS
17595		10/12/25	P	P	P 0.37	P >99.9	S	P 0.15	PASS
17595		10/12/25	P	P	P 0.41	P >99.9	S	P 0.10	PASS
17595		10/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
17595		10/12/25	P	P	P 0.42	P >99.9	S	P 0.10	PASS
18440		10/12/25	P	P	P 0.47	P >99.9	S	P 0.11	PASS
18440		10/12/25	P	P	P 0.51	P >99.9	S	P 0.11	PASS
18430	30M	10/12/25	P	P	P 0.48	P >99.9	S	P 0.12	PASS
18440		10/12/25	P	P	P 0.51	P >99.9	S	P 0.11	PASS
18430	30M	10/12/25	P	P	P 0.56	P >99.9	S	P 0.12	PASS
18421	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS
18411	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS
18411	30M	10/12/25	P	P	P 0.45	P >99.9	S	P 0.12	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
18415	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS
18411	30M	10/12/25	P	P	P 0.45	P >99.9	S	P 0.12	PASS
32123		10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS
18439	30M	10/12/25	P	P	P 0.47	P >99.9	S	P 0.11	PASS
18411	30M	10/12/25	P	P	P 0.48	P >99.9	S	P 0.11	PASS
32123		10/12/25	P	P	P 0.46	P >99.9	S	P 0.11	PASS
18431	30M	10/12/25	P	P	P 0.61	P >99.9	S	P 0.11	PASS
18431	30M	10/12/25	P	P	P 0.47	P >99.9	S	P 0.11	PASS
18411	30M	10/12/25	P	P	P 0.45	P >99.9	S	P 0.12	PASS
18431	30M	10/12/25	P	P	P 0.47	P >99.9	S	P 0.11	PASS
18439	30M	10/12/25	P	P	P 0.47	P >99.9	S	P 0.12	PASS
18431	30M	10/12/25	P	P	P 0.45	P >99.9	S	P 0.11	PASS
18415	30M	10/12/25	P	P	P 0.45	P >99.9	S	P 0.12	PASS
18431	30M	10/12/25	P	P	P 0.47	P >99.9	S	P 0.11	PASS
18419	CH 1	10/12/25	P	P	P 0.43	P >99.9	S	P 0.11	PASS
18419	CH 1	10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS
18419	CH 1	10/12/25	P	P	P 0.45	P >99.9	S	P 0.11	PASS
18419	CH 1	10/12/25	P	P	P 0.47	P >99.9	S	P 0.11	PASS
18429	30M	10/12/25	P	P	P 0.45	P >99.9	S	P 0.11	PASS
18421	30M	10/12/25	P	P	P 0.48	P >99.9	S	P 0.12	PASS
18429	30M	10/12/25	P	P	P 0.51	P >99.9	S	P 0.11	PASS
18429	30M	10/12/25	P	P	P 0.59	P >99.9	S	P 0.11	PASS
32123		10/12/25	P	P	P 0.44	P >99.9	S	P 0.12	PASS
18411	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS
32123		10/12/25	P	P	P 0.45	P >99.9	S	P 0.13	PASS
32123		10/12/25	P	P	P 0.47	P >99.9	S	P 0.12	PASS
18431	30M	10/12/25	P	P	P 0.55	P >99.9	S	P 0.11	PASS
18419	CH 1	10/12/25	P	P	P 0.43	P >99.9	S	P 0.11	PASS
18419	CH 1	10/12/25	P	P	P 0.45	P >99.9	S	P 0.11	PASS
18439	30M	10/12/25	P	P	P 0.46	P >99.9	S	P 0.12	PASS
32129	20M	11/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
32129	20M	11/12/25	P	P	P 0.36	P >99.9	S	P 0.10	PASS
18399	10M	11/12/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
32129	20M	11/12/25	P	P	P 0.55	P >99.9	S	P 0.10	PASS
32129	20M	11/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
19231	30M	11/12/25	P	P	P 0.60	P >99.9	S	P 0.10	PASS
18399	10M	11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
32129	20M	11/12/25	P	P	P 0.37	P >99.9	S	P 0.10	PASS
18388	5M	11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18388	5M	11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18388	5M	11/12/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
18388	5M	11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18388	5M	11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18393		11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18393		11/12/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18393		11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18393		11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
18393		11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18396	10M	11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18400		11/12/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
18396	10M	11/12/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
19231	30M	11/12/25	P	P	P 0.72	P >99.9	S	P 0.11	PASS
19231	30M	11/12/25	P	P	P 0.63	P >99.9	S	P 0.11	PASS
18411	30M	11/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
18388	5M	11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18396	10M	11/12/25	P	P	P 0.41	P >99.9	S	P 0.10	PASS
18392	10M	11/12/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS
18396	10M	11/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
18397	10	11/12/25	P	P	P 0.58	P >99.9	S	P 0.10	PASS
18397	10	11/12/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS
18397	10	11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18397	10	11/12/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
18396	10M	11/12/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
17596	20M	11/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
17596	20M	11/12/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
17596	20M	11/12/25	P	P	P 0.42	P >99.9	S	P 0.10	PASS
18399	10M	11/12/25	P	P	P 0.36	P >99.9	S	P 0.10	PASS
17596	20M	11/12/25	P	P	P 0.40	P >99.9	S	P 0.10	PASS
18398	10M	11/12/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
18398	10M	11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18400		11/12/25	P	P	P 0.40	P >99.9	S	P 0.10	PASS
18400		11/12/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
18400		11/12/25	P	P	P 0.40	P >99.9	S	P 0.10	PASS
18398	10M	11/12/25	P	P	P 0.51	P >99.9	S	P 0.10	PASS
18397	10	11/12/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
18398	10M	11/12/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS
18397	10	11/12/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS
18398	10M	11/12/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
17596	20M	11/12/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
18403	20M	11/12/25	P	P	P 0.41	P >99.9	S	P 0.10	PASS
19231	30M	11/12/25	P	P	P 0.59	P >99.9	S	P 0.11	PASS
18403	20M	11/12/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
18403	20M	11/12/25	P	P	P 0.40	P >99.9	S	P 0.10	PASS
18403	20M	11/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
18398	10M	11/12/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
18399	10M	11/12/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
18399	10M	11/12/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
32129	20M	11/12/25	P	P	P 0.36	P >99.9	S	P 0.10	PASS
18399	10M	11/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
18411	30M	11/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
17596	20M	11/12/25	P	P	P 0.38	P >99.9	S	P 0.15	PASS
18411	30M	11/12/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
17596	20M	11/12/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
18411	30M	11/12/25	P	P	P 0.46	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
18403	20M	11/12/25	P	P	P 0.40	P >99.9	S	P 0.10	PASS
18403	20M	11/12/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
19231	30M	11/12/25	P	P	P 0.62	P >99.9	S	P 0.11	PASS
18411	30M	11/12/25	P	P	P 0.37	P >99.9	S	P 0.10	PASS
18411	30M	11/12/25	P	P	P 0.40	P >99.9	S	P 0.10	PASS
18393		11/12/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
17387	20M	11/12/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
18391	5M	11/12/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS
18391	5M	11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
17387	20M	11/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
17387	20M	11/12/25	P	P	P 0.37	P >99.9	S	P 0.10	PASS
17387	20M	11/12/25	P	P	P 0.37	P >99.9	S	P 0.10	PASS
18391	5M	11/12/25	P	P	P 0.36	P >99.9	S	P 0.10	PASS
18385	5M	11/12/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
18385	5M	11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18391	5M	11/12/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18391	5M	11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18391	5M	11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
17387	20M	11/12/25	P	P	P 0.40	P >99.9	S	P 0.10	PASS
18389	5M	11/12/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18389	5M	11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18378		11/12/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
18389	5M	11/12/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
18389	5M	11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18389	5M	11/12/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18378		11/12/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18378		11/12/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
17387	20M	11/12/25	P	P	P 0.45	P >99.9	S	P 0.10	PASS
18378		11/12/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
18378		11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18378		11/12/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18394	5M	11/12/25	P	P	P 0.41	P >99.9	S	P 0.10	PASS
18394	5M	11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18394	5M	11/12/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
18380		11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18380		11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18380		11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18400		11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18400		11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18392	10M	11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18394	5M	11/12/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18394	5M	11/12/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18394	5M	11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18380		11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18385	5M	11/12/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS
18383	5M	11/12/25	P	P	P 0.32	P >99.9	S	P 0.10	PASS
18383	5M	11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
18385	5M	11/12/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
18385	5M	11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18385	5M	11/12/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18383	5M	11/12/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
18380		11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18380		11/12/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
18383	5M	11/12/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
18383	5M	11/12/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
18383	5M	11/12/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18381	5M	11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18381	5M	11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18392	10M	11/12/25	P	P	P 0.38	P >99.9	S	P 0.10	PASS
18381	5M	11/12/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
18381	5M	11/12/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
18381	5M	11/12/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18392	10M	11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18392	10M	11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18379	5M	11/12/25	P	P	P 0.35	P >99.9	S	P 0.10	PASS
18392	10M	11/12/25	P	P	P 0.36	P >99.9	S	P 0.10	PASS
18392	10M	11/12/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
18381	5M	11/12/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
18381	5M	11/12/25	P	P	P 0.41	P >99.9	S	P 0.10	PASS
18382	5M	11/12/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18382	5M	11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18382	5M	11/12/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
18382	5M	11/12/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS
18382	5M	11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18382	5M	11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18390	5M	11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18390	5M	11/12/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18390	5M	11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18390	5M	11/12/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS
18390	5M	11/12/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
18390	5M	11/12/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
18379	5M	11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18384	5M	11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18384	5M	11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18379	5M	11/12/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS
18384	5M	11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18384	5M	11/12/25	P	P	P 0.34	P >99.9	S	P 0.10	PASS
18389	5M	11/12/25	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18384	5M	11/12/25	P	P	P 0.29	P >99.9	S	P 0.10	PASS
18384	5M	11/12/25	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18379	5M	11/12/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS
18379	5M	11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18379	5M	11/12/25	P	P	P 0.27	P >99.9	S	P 0.10	PASS
32150	63A / 3P CABLE 3M	23/12/25	P	P	P 0.30	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
32145	125 / 3P 3M	23/12/25	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32146	125 / 3P CABLE 3M	23/12/25	P	P	P 0.20	P >99.9	S	P 0.10	PASS
32148	63A 3 3P CABLE 3M	23/12/25	P	P	P 0.41	P >99.9	S	P 0.10	PASS
32149	63A / 3P CABLE 3M	23/12/25	P	P	P 0.33	P >99.9	S	P 0.10	PASS
32147	125 / 3P CABLE 3M	23/12/25	P	P	P 0.18	P >99.9	S	P 0.10	PASS
15795	32 3 DB 6X16A	08/01/26	P	P	P 0.36	S	S	P 0.35	PASS
18145	16A 20M	15/01/26	P	P	P 0.42	P >99.9	S	P 0.12	PASS
32172	TRUECON CABLE 30M	15/01/26	P	P	P 0.46	P >99.9	S	P 0.17	PASS
17985	16A CABLE 20M	15/01/26	P	P	P 0.35	P >99.9	S	P 0.10	PASS
32171	20M TRUCON	15/01/26	P	P	P 0.39	S	S	P 0.10	PASS
16304	16A CABLE 10M	16/01/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
33001	16A TRELCO	16/01/26	P	P	P 0.30	S	S	P 0.10	PASS
14657	16A CABLE 10M	16/01/26	P	P	P 0.38	P >99.9	S	P 0.10	PASS
01987	16A TRELCO	16/01/26	P	P	P 0.26	S	S	P 0.10	PASS
18633	16A CABLE 5M	16/01/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
32175	16A - TRUECON	16/01/26	P	P	P 0.17	S	S	P 0.10	PASS
18264	16A CABLE 10M	16/01/26	P	P	P 0.30	P >99.9	S	P 0.10	PASS
15546	16A CABLE 10M	16/01/26	P	P	P 0.35	P >99.9	S	P 0.10	PASS
17392	13A TO 16A	22/01/26	P	P	P 0.27	S	S	P 0.10	PASS
17901	16A TO 6-WAY 13A	22/01/26	P	P	P 0.52	S	S	P 0.10	PASS
10945	16A TO 4-WAY 13A	22/01/26	P	P	P 0.28	S	S	P 0.10	PASS
16623	16A T-LINE TO TRU	22/01/26	P	P	P 0.20	S	S	P 0.10	PASS
15875	16A TRELCO	22/01/26	P	P	P 0.33	S	S	P 0.10	PASS
31515	16A TO 4-WAY 13A	22/01/26	P	P	P 0.32	S	S	P 0.10	PASS
32188	16A T-LINE TRUECON	22/01/26	P	P	P 0.15	S	S	P 0.10	PASS
18893	16A T-LINE TO PC	22/01/26	P	P	P 0.22	S	S	P 0.10	PASS
32194	16A CABLE 5M	22/01/26	P	P	P 0.38	P >99.9	S	P 0.10	PASS
32192	16A CABLE 10M	22/01/26	P	P	P 0.30	P >99.9	S	P 0.10	PASS
14778	13A TO 15A CABLE 20M	22/01/26	P	P	P 0.55	S	S	P 0.10	PASS
18564	16A T-LINE TO PC	22/01/26	P	P	P 0.20	S	S	P 0.10	PASS
31779	RCF HDL-6	22/01/26	P	S	P 0.12	P >99.9	P <0.05	P 0.63	PASS
32195	13A TO 16A	22/01/26	P	P	P 0.46	S	S	P 0.10	PASS
12580	16A T-LINE TO PC	22/01/26	P	P	P 0.20	S	S	P 0.10	PASS
18298	32A 1PH CABLE 5M	23/01/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
18656	16A CABLE 1M	23/01/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
12264	16A T-LINE TO PC	23/01/26	P	P	P 0.22	S	S	P 0.10	PASS
18519	16A CABLE 1M	23/01/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18560		23/01/26	P	P	P 0.17	S	S	P 0.10	PASS
19874	FIRE EXIT SIGN	23/01/26	P	S	P 0.07	P >99.9	P <0.05	P 0.10	PASS
19796	16A CABLE 5M	23/01/26	P	P	P 0.30	P >99.9	S	P 0.10	PASS
15987	32A 1PH 13A INLINE 10M	26/01/26	P	P	P 0.17	P 63.50	S	P 0.10	PASS
16020	32A 1PH CABLE 10M	26/01/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
18950	32A 1PH 10M	26/01/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS
18948	32A 1PH 10M	26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
18955	32A 1PH 10M	26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
18234	32A 1PH CABLE 10M	26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
18952	32A 1PH 10M	26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
16021	32A 1PH CABLE 10M	26/01/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
16013	32A 1PH CABLE 10M	26/01/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
16019	32A 1PH CABLE 10M	26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
18670	32A 1PH CABLE 10M	26/01/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS
16022	32A 1PH CABLE 10M	26/01/26	P	P	P 0.21	P >99.9	S	P 0.10	PASS
18946	32A 1PH 10M	26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
09261	32A 1PH CABLE 10M	26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
18235	32A 1PH CABLE 10M	26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
16001	32A 1PH 13A INLINE 10M	26/01/26	P	P	P 0.16	S	S	P 0.10	PASS
15991	32A 1PH 13A INLINE 10M	26/01/26	P	P	P 0.24	S	S	P 0.10	PASS
16000	32A 1PH 13A INLINE 10M	26/01/26	P	P	P 0.23	S	S	P 0.10	PASS
16030	32A 5M CABLE	26/01/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
15984	32A 1PH 13A INLINE 10M	26/01/26	P	P	P 0.16	S	S	P 0.10	PASS
15986	32A 1PH 13A INLINE 5M	26/01/26	P	P	P 0.18	S	S	P 0.10	PASS
15997	32A 1PH 13A INLINE 10M	26/01/26	P	P	P 0.20	S	S	P 0.10	PASS
15998	32A 1PH 13A INLINE 5M	26/01/26	P	P	P 0.17	S	S	P 0.10	PASS
15999	32A 1PH 13A INLINE 10M	26/01/26	P	P	P 0.27	S	S	P 0.10	PASS
15993	32A 1PH 13A INLINE 5M	26/01/26	P	P	P 0.25	S	S	P 0.10	PASS
15990	32A 1PH 13A INLINE 10M	26/01/26	P	P	P 0.19	S	S	P 0.10	PASS
16029	32A 1PH CABLE 5M	26/01/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS
18231	32A 1PH CABLE 5M	26/01/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
09815		26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
16026	32A 1PH CABLE 3M	26/01/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
16024	32A 1PH CABLE 3M	26/01/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
16025	32A 1PH CABLE 3M	26/01/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS
16023	32A 1PH CABLE 3M	26/01/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS
19702	32A 1PH CABLE 5M	26/01/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS
16031	32A 1PH CABLE 5M	26/01/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS
18252	32A 1PH CABLE 10M	26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
18232	32A 1PH CABLE 5M	26/01/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS
18949	32A 1PH 10M	26/01/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS
16002	32A 1PH 13A INLINE 10M	26/01/26	P	P	P 0.19	S	S	P 0.10	PASS
15670	32A 1H CABLE 10M	26/01/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
18250		26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
18696	32A 1PH CABLE 10M	26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
16015		26/01/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS
15543	32A 1PH 10M	26/01/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS
18951	32A 1PH 10M	26/01/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
18236	32A 1PH CABLE 10M	26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
18953	32A 1PH 10M	26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
15856	32A 1PH CABLE 10M	26/01/26	P	P	P 1.79	P >99.9	S	P 0.10	PASS
18947	32A 1PH 10M	26/01/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
15996	32A 1PH 13A INLINE 10M	26/01/26	P	P	P 0.21	S	S	P 0.10	PASS
32179	16A T TRUECON	27/01/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
32203	16A T TRUECON	27/01/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
32187	16A T TRUECON	27/01/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
32184	16A T TRUECON	27/01/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
32185	16A T TRUECON	27/01/26	P	P	P 0.21	P >99.9	S	P 0.10	PASS
32177	16A T TRUECON	27/01/26	P	P	P 0.21	P >99.9	S	P 0.10	PASS
32181	16A T TRUECON	27/01/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS
32178	16A T TRUECON	27/01/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS
32183	16A T TRUECON	27/01/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
32186	16A T TRUECON	27/01/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS
32182	16A T TRUECON	27/01/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS
32180	16A T TRUECON	27/01/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS
17076	16A TO 13A 4WAY	03/02/26	P	P	P 0.26	S	S	P 0.10	PASS
17076	16A TO 13A 4WAY	03/02/26	P	P	P 0.21	S	S	P 0.10	PASS
17076	16A TO 13A 4WAY	03/02/26	P	P	P 0.21	S	S	P 0.10	PASS
10206	15A TO 13A 2WAY	03/02/26	P	P	P 0.37	S	S	P 0.10	PASS
17076	16A TO 13A 4WAY	03/02/26	P	P	P 0.29	S	S	P 0.10	PASS
10206	15A TO 13A 2WAY	03/02/26	P	P	P 0.43	S	S	P 0.10	PASS
11481	13A IEC	03/02/26	P	P	P 0.18	S	S	P 0.10	PASS
14680	16A CABLE 10M	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
14666	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
17559	16A CABLE 10M	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
32044	16A 10M BLUE	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
20069	16A CABLE 10M	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
17919	16A CABLE 10M	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
32065	16A 5M	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
16108	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
16110	16A CABLE 10M	05/02/26	P	P	P 0.30	P >99.9	S	P 0.10	PASS
14296	16A CABLE 10M	05/02/26	P	P	P 0.34	P >99.9	S	P 0.10	PASS
32048	16A 10M BLUE	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
14614	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18359	16A CABLE 10M	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
18248	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
32058	16A 10M BLUE	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32192	16A CABLE 10M	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
16301	16A CABLE 10M	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
17428	16A CABLE 10M	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
17428	16A CABLE 10M	05/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
09630	16A CABLE 10M	05/02/26	P	P	P 0.36	P >99.9	S	P 0.10	PASS
16107	16A CABLE 10M	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
14657	16A CABLE 10M	05/02/26	P	P	P 0.38	P >99.9	S	P 0.10	PASS
32046	16A 10M BLUE	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
15551	16A CABLE 10M	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
14648	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18017	16A CABLE 10M	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32056	16A 10M BLUE	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
15193	16A CABLE 10M	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
14682	16A CABLE 10M	05/02/26	P	P	P 0.30	P >99.9	S	P 0.10	PASS
16105	10M	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
14425	16A CABLE 10M	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32035	16A 10M BLUE	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
18226	16A CABLE 10M	05/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
14629	16A CABLE 10M	05/02/26	P	P	P 0.29	P >99.9	S	P 0.10	PASS
14652	16A CABLE 10M	05/02/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
16304	16A CABLE 10M	05/02/26	P	P	P 0.29	P >99.9	S	P 0.10	PASS
14673	16A CABLE 10M	05/02/26	P	P	P 0.29	P >99.9	S	P 0.10	PASS
16705	16A CABLE 10M	05/02/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
17265	16A CABLE 10M	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
15524	16A CABLE 10M	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
14677	16A CABLE 10M	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
17999	16A CABLE 10M	05/02/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
17897	16A CABLE 10M	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
17297	16A CABLE 10M	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32047	16A 10M BLUE	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
12102	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
16299	16A CABLE 10M	05/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
32052	16A 10M BLUE	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18028	16A CABLE 10M	05/02/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
14628	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
16306	16A CABLE 10M	05/02/26	P	P	P 0.36	P >99.9	S	P 0.10	PASS
14663	16A CABLE 10M	05/02/26	P	P	P 0.34	P >99.9	S	P 0.10	PASS
32055	16A 10M BLUE	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32055	16A 10M BLUE	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18003	16A CABLE 10M	05/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
32053	16A 10M BLUE	05/02/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18267	16A CABLE 10M	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
32049	16A 10M BLUE	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
32051	16A 10M BLUE	05/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
32029	16A 10M BLUE	05/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
17273	16A CABLE 10M	05/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
16295	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
16296	16A CABLE 10M	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
17927	16A CABLE 10M	05/02/26	P	P	P 0.29	P >99.9	S	P 0.10	PASS
32042	16A 10M BLUE	05/02/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
32050	16A 10M BLUE	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
14650	16A CABLE 10M	05/02/26	P	P	P 0.37	P >99.9	S	P 0.10	PASS
14655	16A CABLE 10M	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
18264	16A CABLE 10M	05/02/26	P	P	P 0.29	P >99.9	S	P 0.10	PASS
17271	16A CABLE 10M	05/02/26	P	P	P 0.26	P >99.9	S	P 0.17	PASS
32036	16A 10M BLUE	05/02/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
17369	16A CABLE 10M	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
19742	16A CABLE 10M	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18001	16A CABLE 10M	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
16109	16A CABLE 10M	05/02/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
14290	16A CABLE 10M	05/02/26	P	P	P 0.39	P >99.9	S	P 0.10	PASS
14630	16A CABLE 10M	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
17272	16A CABLE 10M	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18021	16A CABLE 10M	05/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
18031	16A CABLE 10M	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
14656	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
14662	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18571	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
19741	16A CABLE 10M	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
14766	16A CABLE 10M	05/02/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
14294	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
16305	16A CABLE 10M	05/02/26	P	P	P 0.31	P 76.66	S	P 0.10	PASS
17922	16A CABLE 10M	05/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
14516	16A CABLE 10M	05/02/26	P	P	P 0.37	P >99.9	S	P 0.10	PASS
09789	16A CABLE 10M	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
14626	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
14667	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
14651	16A CABLE 10M	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
32059	16A 10M BLUE	05/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
15546	16A CABLE 10M	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
32039	16A 10M BLUE	05/02/26	P	P	P 0.29	P >99.9	S	P 0.10	PASS
18020	16A CABLE 10M	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
14674	16A CABLE 10M	05/02/26	P	P	P 0.30	P >99.9	S	P 0.10	PASS
16307	16A CABLE 10M	05/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
17934	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
17167	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
17898	16A CABLE 10M	05/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32033	16A 10M BLUE	05/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
12129	16A CABLE 10M	05/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18344	16A CABLE 20M	09/02/26	P	P	P 0.44	P >99.9	S	P 0.10	PASS
18090	16A CABLE 20M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.14	PASS
18146	16A 20M	09/02/26	P	P	P 0.32	P >99.9	S	P 0.12	PASS
17346	16A CABLE 20M	09/02/26	P	P	P 0.43	P >99.9	S	P 0.18	PASS
17335	16A CABLE 20M	09/02/26	P	P	P 0.32	P >99.9	S	P 0.20	PASS
18150	16A CABLE 20M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.14	PASS
17634	16A 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
15844	16A 20M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.14	PASS
19928	16A CABLE 20M	09/02/26	P	P	P 0.32	P >99.9	S	P 0.17	PASS
18170	16A CABLE 20M	09/02/26	P	P	P 0.35	P >99.9	S	P 0.14	PASS
14611	16A CABLE 20M	09/02/26	P	P	P 0.35	P >99.9	S	P 0.17	PASS
17344	16A CABLE 20M	09/02/26	P	P	P 0.32	P >99.9	S	P 0.19	PASS
14520	16A CABLE 20M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.12	PASS
14520	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.12	PASS
18562	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
18160	16A 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.12	PASS
15849	16A CABLE 20M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.13	PASS
15848	16A CABLE 20M	09/02/26	P	P	P 0.37	P >99.9	S	P 0.12	PASS
18193	16A CABLE 20M	09/02/26	P	P	P 0.32	P >99.9	S	P 0.14	PASS
19598	16A CABLE 20M	09/02/26	P	P	P 0.30	P >99.9	S	P 0.14	PASS
18148	16A 20M	09/02/26	P	P	P 0.35	P >99.9	S	P 0.14	PASS
12756	16A CABLE 5M	09/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
32077	16A 5M BLUE	09/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
17350	16A CABLE 20M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.20	PASS
16748	16A 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
32064	16A 5M	09/02/26	P	P	P 0.23	P >99.9	S	P 0.10	PASS
32045	16A 20M BLUE	09/02/26	P	P	P 0.37	P >99.9	S	P 0.13	PASS
14601	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.17	PASS
15355	16A CABLE 5M	09/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32076	16A 5M BLUE	09/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
18080	16A CABLE 5M	09/02/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32032	16A 5M BLUE	09/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
18849	16A CABLE 5M	09/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
16164	16A CABLE 5M	09/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
15122	16A CABLE 5M	09/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
12752	16A CABLE 5M	09/02/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18848	16A CABLE 5M	09/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
12740	16A CABLE 5M	09/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
17264	16A CABLE 5M	09/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
19314	16A CABLE 5M	09/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
18638	16A CABLE 5M	09/02/26	P	P	P 0.23	P >99.9	S	P 0.10	PASS
15115	16A CABLE 5M	09/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18336	16A CABLE 5M	09/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
32073	16A 5M BLUE	09/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
18075	16A CABLE 5M	09/02/26	P	P	P 0.30	P >99.9	S	P 0.10	PASS
32071	16A 5M BLUE	09/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
18057	16A CABLE 5M	09/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
15123	16A CABLE 5M	09/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32062	16A 5M BLUE	09/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
18331	16A CABLE 5M	09/02/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
18864	16A CABLE 5M	09/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18078	16A CABLE 5M	09/02/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32040	16A 5M BLUE	09/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
17168	16A CABLE 5M	09/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
14620	16A CABLE 5M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.10	PASS
32037	16A 5M BLUE	09/02/26	P	P	P 0.23	P >99.9	S	P 0.10	PASS
32068	16A 5M BLUE	09/02/26	P	P	P 0.23	P >99.9	S	P 0.10	PASS
18192	16A CABLE 20M	09/02/26	P	P	P 0.38	P >99.9	S	P 0.13	PASS
17341	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.18	PASS
09480	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
18158	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.14	PASS
18145	16A 20M	09/02/26	P	P	P 0.32	P >99.9	S	P 0.14	PASS
18182	16A 20M	09/02/26	P	P	P 0.36	P >99.9	S	P 0.13	PASS
17318	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.20	PASS
18179	16A CABLE 20M	09/02/26	P	P	P 0.32	P >99.9	S	P 0.14	PASS
15857	16A CABLE 20M	09/02/26	P	P	P 0.32	P >99.9	S	P 0.12	PASS
18149	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.14	PASS
18338	16A CABLE 5M	09/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
16709	16A 20M	09/02/26	P	P	P 0.37	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
14167	16A CABLE 5M	09/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
15131	16A CABLE 5M	09/02/26	P	P	P 0.30	P >99.9	S	P 0.10	PASS
19899	16A CABLE 20M	09/02/26	P	P	P 0.35	P >99.9	S	P 0.10	PASS
17333	16A CABLE 20M	09/02/26	P	P	P 0.35	P >99.9	S	P 0.19	PASS
18161	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.13	PASS
17316	16A 20M	09/02/26	P	P	P 0.38	P >99.9	S	P 0.18	PASS
18032	16A CABLE 10M	09/02/26	P	P	P 0.45	P >99.9	S	P 0.10	PASS
32031	16A 5M BLUE	09/02/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
19867	16A CABLE 20M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.10	PASS
14612	16A CABLE 20M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.17	PASS
17359	16A CABLE 20M	09/02/26	P	P	P 0.35	P >99.9	S	P 0.18	PASS
14594	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.17	PASS
16047	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
32041	16A 20M BLUE	09/02/26	P	P	P 0.34	P >99.9	S	P 0.13	PASS
18561	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
32151	16A CABLE 20M	09/02/26	P	P	P 0.36	P >99.9	S	P 0.19	PASS
17352	16A 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.17	PASS
32174	16A CABLE 20M	09/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18096	16A 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.13	PASS
17340	16A 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.18	PASS
14582	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.17	PASS
18159	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.13	PASS
14835	16A 20M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.10	PASS
18173	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.14	PASS
17356	16A CABLE 20M	09/02/26	P	P	P 0.39	P >99.9	S	P 0.21	PASS
19979	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.20	PASS
18151	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.13	PASS
15855	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.12	PASS
16708	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.11	PASS
17349	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.19	PASS
14575	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.18	PASS
14799	16A CABLE 20M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.10	PASS
18153	16A CABLE 20M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.14	PASS
16648	16A 20M	09/02/26	P	P	P 0.36	P >99.9	S	P 0.10	PASS
18144	16A CABLE 20M	09/02/26	P	P	P 0.35	P >99.9	S	P 0.15	PASS
17970	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.14	PASS
18186	16A CABLE 20M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.15	PASS
17338	16A CABLE 20M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.18	PASS
15225	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
16294	16A CABLE 20M	09/02/26	P	P	P 0.32	P >99.9	S	P 0.12	PASS
14581	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.17	PASS
18174	16A CABLE 20M	09/02/26	P	P	P 0.35	P >99.9	S	P 0.15	PASS
14590	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.17	PASS
16710	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
14608	16A 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.17	PASS
14603	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.16	PASS
19803	16A CABLE 5M	09/02/26	P	P	P 0.23	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
12743	16A CABLE 5M	09/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
15121	16A CABLE 5M	09/02/26	P	P	P 0.26	P 19.63	S	P 0.10	PASS
32061	16A 5M BLUE	09/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
12124	16A CABLE 5M	09/02/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
18081	16A CABLE 5M	09/02/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32038	16A 5M BLUE	09/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
14685	16A CABLE 5M	09/02/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
16356	16A CABLE 5M	09/02/26	P	P	P 0.26	P 86.02	S	P 0.10	PASS
18851	16A CABLE 5M	09/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
18368	16A CABLE 5M	09/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
19599	16A CABLE 5M	09/02/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
16058		09/02/26	P	P	P 0.26	P >99.9	S	P 0.10	PASS
32034	16A 5M BLUE	09/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
19897	16A CABLE 5M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
18636	16A CABLE 5M	09/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
32072	16A 5M BLUE	09/02/26	P	P	P 0.23	P >99.9	S	P 0.10	PASS
32074	16A 5M BLUE	09/02/26	P	P	P 0.29	P >99.9	S	P 0.10	PASS
15129	16A CABLE 5M	09/02/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
18154	16A CABLE 20M	09/02/26	P	P	P 0.34	P >99.9	S	P 0.14	PASS
32043	16A 20M BLUE	09/02/26	P	P	P 0.29	P >99.9	S	P 0.10	PASS
16649	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
17358	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.20	PASS
32124	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
16650	16A CABLE 20M	09/02/26	P	P	P 0.32	P 44.74	S	P 0.10	PASS
18155	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.13	PASS
17336	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.18	PASS
16094	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
17323	16A 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.20	PASS
14313	16A CABLE 5M	09/02/26	P	P	P 0.29	P >99.9	S	P 0.10	PASS
18163	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.14	PASS
15858	16A CABLE 20M	09/02/26	P	P	P 0.33	P >99.9	S	P 0.12	PASS
32075	16A 5M BLUE	09/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS
32063	16A 5M BLUE	09/02/26	P	P	P 0.42	P >99.9	S	P 0.10	PASS
18064	16A CABLE 5M	09/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
18056	16A CABLE 5M	09/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
32066	16A 5M BLUE	09/02/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
18370	16A CABLE 5M	09/02/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
11015	16A CABLE 5M	16/02/26	P	P	P 0.39	P >99.9	S	P 0.10	PASS
16375	16A CABLE 5M	16/02/26	P	P	P 0.36	P >99.9	S	P 0.10	PASS
14616	16A CABLE 5M	16/02/26	P	P	P 0.38	P >99.9	S	P 0.10	PASS
32194	16A CABLE 5M	16/02/26	P	P	P 0.34	P >99.9	S	P 0.10	PASS
18083	16A CABLE 5M	16/02/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
32070	16A 5M BLUE	16/02/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
16132	16A CABLE 5M	16/02/26	P	P	P 0.45	P >99.9	S	P 0.10	PASS
18635	16A CABLE 5M	16/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18079	16A CABLE 5M	16/02/26	P	P	P 0.29	P >99.9	S	P 0.10	PASS
18087	16A CABLE 5M	16/02/26	P	P	P 0.84	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
18082	16A CABLE 5M	16/02/26	P	P	P 0.55	P >99.9	S	P 0.10	PASS
12738	16A CABLE 5M	16/02/26	P	P	P 0.36	P >99.9	S	P 0.10	PASS
32069	16A 5M BLUE	16/02/26	P	P	P 0.43	P >99.9	S	P 0.10	PASS
18343	16A CABLE 5M	16/02/26	P	P	P 0.35	P >99.9	S	P 0.10	PASS
18371	16A 5M	16/02/26	P	P	P 0.32	P >99.9	S	P 0.10	PASS
32067	16A 5M	16/02/26	P	P	P 0.30	P >99.9	S	P 0.10	PASS
18059	16A CABLE 5M	16/02/26	P	P	P 0.34	P >99.9	S	P 0.10	PASS
14622	16A CABLE 5M	16/02/26	P	P	P 0.27	P >99.9	S	P 0.10	PASS
18374	16A CABLE 5M	16/02/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
12625	16A CABLE 5M	16/02/26	P	P	P 0.28	P >99.9	S	P 0.10	PASS
18086	16A CABLE 5M	16/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
19804	16A CABLE 5M	16/02/26	P	P	P 0.31	P >99.9	S	P 0.10	PASS
18859	16A CABLE 5M	16/02/26	P	P	P 0.35	P >99.9	S	P 0.10	PASS
18098	16A CABLE 5M	16/02/26	P	P	P 0.46	P >99.9	S	P 0.10	PASS
18061	16A CABLE 5M	16/02/26	P	P	P 0.30	P >99.9	S	P 0.10	PASS
18858	16A CABLE 5M	16/02/26	P	P	P 0.33	P >99.9	S	P 0.10	PASS
17958	13A - 16A WHITE	19/02/26	P	P	P 0.17	S	S	P 0.10	PASS
15910	16A - IEC	19/02/26	P	P	P 0.30	S	S	P 0.10	PASS
18097	16A CABLE 5M	19/02/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
12939	16A CABLE 5M	19/02/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
18063	16A CABLE 5M	19/02/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
18067	16A CABLE 5M	19/02/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
15124	16A CABLE 5M	19/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
18846	16A CABLE 5M	19/02/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
18308	16A CABLE 5M	19/02/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
18867	16A CABLE 5M	19/02/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
18843	16A CABLE 5M	19/02/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
18854	16A CABLE 5M	19/02/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
18342	16A CABLE 5M	19/02/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
14927	16A CABLE 5M	19/02/26	P	P	P 0.21	P >99.9	S	P 0.10	PASS
16161	16A CABLE 5M	19/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
18262	16A CABLE 5M	19/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
16163	16A CABLE 5M	19/02/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
18224	16A CABLE 5M	19/02/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
18841	16A CABLE 5M	19/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
18847	16A CABLE 5M	19/02/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
17280	16A CABLE 5M	19/02/26	P	P	P 0.23	P >99.9	S	P 0.10	PASS
18337	16A CABLE 5M	19/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
31516	13A TO 16A WHITE	20/02/26	P	P	P 0.14	S	S	P 0.10	PASS
30598	13A - 16A	20/02/26	P	P	P 0.31	S	S	P 0.10	PASS
07523	13A - 16A	20/02/26	P	P	P 0.25	S	S	P 0.10	PASS
15065	13A - 16A	20/02/26	P	P	P 0.32	S	S	P 0.10	PASS
30580	13A - 16A	20/02/26	P	P	P 0.31	S	S	P 0.10	PASS
17948	13A - 16A	20/02/26	P	P	P 0.18	S	S	P 0.10	PASS
30578	13A - 16A	20/02/26	P	P	P 0.27	S	S	P 0.10	PASS
17955	13A - 16A	20/02/26	P	P	P 0.19	S	S	P 0.10	PASS
05477	13A - 16A	20/02/26	P	P	P 0.31	S	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
18367	13A - 16A	20/02/26	P	P	P 0.19	S	S	P 0.10	PASS	
30592	13A - 16A	20/02/26	P	P	P 0.33	S	S	P 0.10	PASS	
30602	13A - 16A	20/02/26	P	P	P 0.26	S	S	P 0.10	PASS	
30571	13A - 16A	20/02/26	P	P	P 0.19	S	S	P 0.10	PASS	
30601	13A - 16A	20/02/26	P	P	P 0.38	S	S	P 0.10	PASS	
30569	13A - 16A	20/02/26	P	P	P 0.26	S	S	P 0.10	PASS	
17951	13A TO 16A	20/02/26	P	P	P 0.22	S	S	P 0.10	PASS	
11027	13A - 16A	20/02/26	P	P	P 0.29	S	S	P 0.10	PASS	
17957	13A - 16A	20/02/26	P	P	P 0.26	S	S	P 0.10	PASS	
30566	13A - 16A	20/02/26	P	P	P 0.25	S	S	P 0.10	PASS	
18147	16A CABLE 20M	20/02/26	P	P	P 0.40	P >99.9	S	P 0.13	PASS	
16218	13A - 16A	20/02/26	P	P	P 0.19	S	S	P 0.10	PASS	
17392	13A TO 16A	20/02/26	P	P	P 0.18	S	S	P 0.10	PASS	
12832	13A - 16A	20/02/26	P	P	P 0.20	S	S	P 0.10	PASS	
14348	13A - 16A	20/02/26	P	P	P 0.25	S	S	P 0.10	PASS	
18277	13A - 16A	20/02/26	P	P	P 0.24	S	S	P 0.10	PASS	
16045	13A - 16A	20/02/26	P	P	P 0.31	S	S	P 0.10	PASS	
18826	13A - 16A	20/02/26	P	P	P 0.30	S	S	P 0.10	PASS	
18203	16A CABLE 3M	20/02/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS	
14188	16A CABLE 3M	20/02/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS	
17284	16A CABLE 3M	20/02/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS	
17281	16A CABLE 3M	20/02/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS	
14761	16A CABLE 3M	20/02/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS	
18335	16A CABLE 3M	20/02/26	P	P	P 0.19	P 32.73	S	P 0.10	PASS	
18618	16A CABLE 3M	20/02/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS	
17289	16A CABLE 3M	20/02/26	P	P	P 0.25	P >99.9	S	P 0.10	PASS	
16535	16A CABLE 3M	20/02/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS	
17968	16A CABLE 3M	20/02/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS	
18281	13A - 16A	20/02/26	P	P	P 0.31	S	S	P 0.10	PASS	
18341	16A CABLE 3M	20/02/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS	
18339	16A CABLE 3M	20/02/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS	
18275	13A - 16A	20/02/26	P	P	P 0.30	S	S	P 0.10	PASS	
18373	16A CABLE 3M	20/02/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS	
18050	16A CABLE 3M	20/02/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS	
10881	13A - 16A	20/02/26	P	P	P 0.25	S	S	P 0.10	PASS	
14804	16A CABLE 3M	20/02/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS	
11912	16A CABLE 3M	20/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS	
15529	16A CABLE 3M	20/02/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS	
18332		20/02/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS	
18340	16A CABLE 3M	20/02/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS	
14468	16A CABLE 3M	20/02/26	P	P	P 0.21	P >99.9	S	P 0.10	PASS	
18333	16A CABLE 3M	20/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS	
18302	16A CABLE 3M	20/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS	
32226	16A T TRUE	26/02/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS	
32229	16A T TRUE	26/02/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS	
32230	16A T TRUE	26/02/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS	
32228	16A T TRUE	26/02/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS	

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
32232		26/02/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
32227	16A T TRUE	26/02/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS
32225	16A T TRUE	26/02/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
32233	16A T TRUE	26/02/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
32231	16A T TRUE	26/02/26	P	P	P 0.17	P >99.9	S	P 0.15	PASS
32224	16A T TRUE	26/02/26	P	P	P 0.21	P >99.9	S	P 0.10	PASS
32234	16A T TRUE	26/02/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
18654	16A CABLE 3M	06/03/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
19812	16A CABLE 3M	06/03/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS
12838	16A CABLE 3M	06/03/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
18033	16A CABLE 3M	06/03/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS
18204	16A CABLE 3M	06/03/26	P	P	P 0.30	P >99.9	S	P 0.10	PASS
18211	16A CABLE 3M	06/03/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS
14803	16A CABLE 3M	06/03/26	P	P	P 0.53	P >99.9	S	P 0.10	PASS
15169	16A CABLE 3M	06/03/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
12753	16A CABLE 3M	06/03/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
17606	16A CABLE 3M	06/03/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
16545	16A CABLE 3M	06/03/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS
15195	16A CABLE 3M	06/03/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
19813	16A CABLE 3M	06/03/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
18655	16A CABLE 3M	06/03/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
18655	16A CABLE 3M	06/03/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
18664	16A CABLE 3M	06/03/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
18048	16A CABLE 3M	06/03/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS
17998	16A CABLE 3M	06/03/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
18620	16A CABLE 3M	06/03/26	P	P	P 0.16	P >99.9	S	P 0.10	PASS
18209	16A CABLE 3M	06/03/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
18650	16A CABLE 3M	06/03/26	P	P	P 0.15	P >99.9	S	P 0.10	PASS
16548	16A CABLE 3M	06/03/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
17288	16A CABLE 3M	06/03/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
18205	16A CABLE 3M	06/03/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
17292	16A CABLE 3M	06/03/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
15138	16A CABLE 3M	06/03/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
17290	16A CABLE 3M	06/03/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
16150	16A CABLE 3M	06/03/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
17287	16A CABLE 3M	06/03/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS
18024	16A CABLE 3M	06/03/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
18301	16A CABLE 3M	06/03/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
18345	16A CABLE 3M	06/03/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
16544	16A CABLE 3M	06/03/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
18334	16A CABLE 3M	06/03/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
17918	16A CABLE 3M	06/03/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
16552	16A CABLE 3M	06/03/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
18538	16A CABLE 1M	06/03/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
19791	16A CABLE 1M	06/03/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
18516	16A CABLE 1M	06/03/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
17380	16A CABLE 1M	06/03/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
17521	16A CABLE 1M	06/03/26	P	P	P 0.30	P >99.9	S	P 0.10	PASS
16702	16A CABLE 1M	06/03/26	P	P	P 0.21	P >99.9	S	P 0.10	PASS
18838	16A CABLE 1M	06/03/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
17536	16A CABLE 1M	06/03/26	P	P	P 0.22	P >99.9	S	P 0.10	PASS
17268	16A CABLE 1M	06/03/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
17083	16A CABLE 1M	06/03/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
17533	16A CABLE 1M	06/03/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
18840	16A CABLE 1M	06/03/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
10003	16A CABLE 1M	06/03/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
17090	16A CABLE 1M	06/03/26	P	P	P 0.17	P >99.9	S	P 0.10	PASS
17529	16A CABLE 1M	06/03/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS
18541	16A CABLE 1M	06/03/26	P	P	P 0.21	P >99.9	S	P 0.10	PASS
17535	16A CABLE 1M	06/03/26	P	P	P 0.24	P >99.9	S	P 0.10	PASS
18539	16A CABLE 1M	06/03/26	P	P	P 0.23	P >99.9	S	P 0.10	PASS
18268	16A CABLE 1M	06/03/26	P	P	P 0.21	P >99.9	S	P 0.10	PASS
18628	16A CABLE 1M	06/03/26	P	P	P 0.18	P >99.9	S	P 0.10	PASS
18871	16A CABLE 1M	06/03/26	P	P	P 0.21	P >99.9	S	P 0.10	PASS
18361	16A CABLE 1M	06/03/26	P	P	P 0.20	P >99.9	S	P 0.10	PASS
17527	16A CABLE 1M	06/03/26	P	P	P 0.21	P >99.9	S	P 0.10	PASS
18644	16A CABLE 1M	06/03/26	P	P	P 0.19	P >99.9	S	P 0.10	PASS

Total Appliances > **1,445**

HI-LIGHTS - HI-LIGHTS

11	SPIKE LIGHT	03/07/25	P	P	P 0.22	S	S	P 0.10	PASS
12	2222	03/07/25	P	P	P 0.29	S	S	P 0.10	PASS
14	1	03/07/25	P	P	P 0.25	S	S	P 0.10	PASS
123	212121	03/07/25	P	P	P 0.39	S	S	P 0.10	PASS
124	3232	03/07/25	P	P	P 0.39	P >99.9	S	P 0.10	PASS
007	32A 3PH CABLE	07/07/25	P	P	P 0.25	P >99.9	S	P 0.10	PASS
004	63A 3PH CABLE	07/07/25	P	P	P 0.36	P >99.9	S	P 0.10	PASS
003	32A 3PH CABLE	07/07/25	P	P	P 0.14	P >99.9	S	P 0.10	PASS
005 (TES 6)	63A 3PH DB RCD	07/07/25	P	P	P 0.34	S	S	S	PASS
005 (TEST 6)	63A 3PH DB RCD	07/07/25	P	P	P 0.28	S	S	S	PASS
006	32A 3PH CABLE	07/07/25	P	P	P 0.20	P >99.9	S	P 0.10	PASS
005 (TEST 1)	63A 3PH DB RCD	07/07/25	P	P	P 0.24	S	S	S	PASS
001	32A 3PH CABLE	07/07/25	P	P	P 0.18	P >99.9	S	P 0.18	PASS
005 (TEST 4)	63A 3PH DB RCD	07/07/25	P	P	P 0.32	S	S	S	PASS
002	32A 3PH CABLE	07/07/25	P	P	P 0.20	P >99.9	S	P 0.10	PASS
005 (TEST 3)	63A 3PH DB RCD	07/07/25	P	P	P 0.33	S	S	S	PASS
005 (TEST 2)	63A 3PH DB RCD	07/07/25	P	P	P 0.33	S	S	S	PASS
005 (TEST 8)	63A 3PH DB RCD	07/07/25	P	P	P 0.46	S	S	S	PASS
005 (TEST 7)	63A 3PH DB RCD	07/07/25	P	P	P 0.31	S	S	S	PASS
005 (TEST 5)	63A 3PH DB RCD	07/07/25	P	P	P 0.28	S	S	S	PASS
005 (TEST 9)	63A 3PH DB RCD	07/07/25	P	P	P 0.37	S	S	S	PASS
THREE PHASE HEATER 2	CLARKE DEVIL 6015	15/07/25	P	S	P 0.11	P >99.9	P <0.05	P 0.10	PASS
008	32A 3PH CABLE	15/07/25	P	P	P 0.28	S	S	P 0.10	PASS
DB SOCKET 1	63/3 - 32/3 MCB WITH TAIL	15/07/25	P	P	P 0.24	S	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
DB SOCKET 2	63/3 - 2 X 32/3 MCB WITH TAIL	15/07/25	P	P	P 0.25	S	S	P 0.10	PASS
THREE PHASE HEATER 1	CLARKE DEVIL 6015	15/07/25	P	S	P 0.10	P >99.9	P <0.05	P 0.10	PASS
20080	16A TLINE -TRUEONE	08/08/25	P	P	P 0.15	S	S	P 0.10	PASS
20080	16A TLINE -TRUEONE	08/08/25	P	P	P 0.12	S	S	P 0.10	PASS
20081	16A TLINE -TRUEONE	08/08/25	P	P	P 0.14	S	S	P 0.10	PASS
20074	16A TLINE -TRUEONE	08/08/25	P	P	P 0.14	S	S	P 0.10	PASS
20074	16A TLINE -TRUEONE	08/08/25	P	P	P 0.20	S	S	P 0.10	PASS
20077	16A TLINE -TRUEONE	08/08/25	P	P	P 0.25	S	S	P 0.10	PASS
20073	16A TLINE -TRUEONE	08/08/25	P	P	P 0.17	S	S	P 0.10	PASS
20073	16A TLINE -TRUEONE	08/08/25	P	P	P 0.14	S	S	P 0.10	PASS
20081	16A TLINE -TRUEONE	08/08/25	P	P	P 0.18	S	S	P 0.10	PASS
20079	16A TLINE -TRUEONE	08/08/25	P	P	P 0.23	S	S	P 0.10	PASS
20079	16A TLINE -TRUEONE	08/08/25	P	P	P 0.18	S	S	P 0.10	PASS
20077	16A TLINE -TRUEONE	08/08/25	P	P	P 0.23	S	S	P 0.10	PASS
20097	16A-TRUEONE	08/08/25	P	P	P 0.19	S	S	P 0.10	PASS
20094	16A-TRUEONE	08/08/25	P	P	P 0.18	S	S	P 0.10	PASS
20095	16A-TRUEONE	08/08/25	P	P	P 0.15	S	S	P 0.10	PASS
20088	16A TLINE -TRUEONE	08/08/25	P	P	P 0.15	S	S	P 0.10	PASS
20096	16A-TRUEONE	08/08/25	P	P	P 0.13	S	S	P 0.10	PASS
20096	16A-TRUEONE	08/08/25	P	P	P 0.19	S	S	P 0.10	PASS
20097	16A-TRUEONE	08/08/25	P	P	P 0.28	S	S	P 0.10	PASS
20098	16A-TRUEONE	08/08/25	P	P	P 0.12	S	S	P 0.10	PASS
20098	16A-TRUEONE	08/08/25	P	P	P 0.24	S	S	P 0.10	PASS
20099	16A TLINE -TRUEONE	08/08/25	P	P	P 0.25	S	S	P 0.10	PASS
20092	16A TLINE -TRUEONE	08/08/25	P	P	P 0.15	S	S	P 0.10	PASS
20088	16A TLINE -TRUEONE	08/08/25	P	P	P 0.13	S	S	P 0.10	PASS
20087	16A TLINE -TRUEONE	08/08/25	P	P	P 0.22	S	S	P 0.10	PASS
20086	16A TLINE -TRUEONE	08/08/25	P	P	P 0.12	S	S	P 0.10	PASS
20085	16A TLINE -TRUEONE	08/08/25	P	P	P 0.20	S	S	P 0.10	PASS
20087	16A TLINE -TRUEONE	08/08/25	P	P	P 0.14	S	S	P 0.10	PASS
20086	16A TLINE -TRUEONE	08/08/25	P	P	P 0.14	S	S	P 0.10	PASS
20091	16A TLINE -TRUEONE	08/08/25	P	P	P 0.14	S	S	P 0.10	PASS
20091	16A TLINE -TRUEONE	08/08/25	P	P	P 0.12	S	S	P 0.10	PASS
20084	16A TLINE -TRUEONE	08/08/25	P	P	P 0.13	S	S	P 0.10	PASS
20084	16A TLINE -TRUEONE	08/08/25	P	P	P 0.14	S	S	P 0.10	PASS
20085	16A TLINE -TRUEONE	08/08/25	P	P	P 0.14	S	S	P 0.10	PASS
20082	16A TLINE -TRUEONE	08/08/25	P	P	P 0.13	S	S	P 0.10	PASS
20082	16A TLINE -TRUEONE	08/08/25	P	P	P 0.14	S	S	P 0.10	PASS
20083	63/3 50M	11/08/25	P	P	P 0.58	P >99.9	S	P 0.43	PASS
17796	13A - TRUCON	04/09/25	P	P	P 0.29	S	S	P 0.10	PASS
17797	13A - TRUCON	10/09/25	P	P	P 0.32	S	S	P 0.10	PASS
01806	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.32	S	S	P 0.10	PASS
01806	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.21	S	S	P 0.10	PASS
01806	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.31	S	S	P 0.10	PASS
01806	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.27	S	S	P 0.10	PASS
01806	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.25	S	S	P 0.10	PASS
01810	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.33	S	S	P 0.10	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
01810	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.29	S	S	P 0.10	PASS
01810	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.33	S	S	P 0.10	PASS
01806	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.39	S	S	P 0.10	PASS
01810	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.31	S	S	P 0.10	PASS
01810	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.28	S	S	P 0.10	PASS
01810	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.32	S	S	P 0.10	PASS
01807	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.23	S	S	P 0.10	PASS
01807	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.29	S	S	P 0.10	PASS
01807	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.39	S	S	P 0.10	PASS
01807	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.18	S	S	P 0.10	PASS
01807	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.28	S	S	P 0.10	PASS
01807	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.20	S	S	P 0.10	PASS
01808	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.22	S	S	P 0.10	PASS
01808	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.26	S	S	P 0.10	PASS
01808	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.25	S	S	P 0.10	PASS
0808	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.27	S	S	P 0.10	PASS
01808	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.24	S	S	P 0.10	PASS
01808	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.23	S	S	P 0.10	PASS
01811	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.24	S	S	P 0.10	PASS
01811	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.21	S	S	P 0.10	PASS
01811	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.22	S	S	P 0.10	PASS
01811	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.23	S	S	P 0.10	PASS
01811	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.27	S	S	P 0.10	PASS
01811	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.25	S	S	P 0.10	PASS
16485	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.25	S	S	P 0.10	PASS
16485	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.25	S	S	P 0.10	PASS
16485	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.21	S	S	P 0.10	PASS
16485	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.22	S	S	P 0.10	PASS
16485	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.23	S	S	P 0.10	PASS
16485	SOCA BOX 6 X 16 TAIL OUT	25/09/25	P	P	P 0.29	S	S	P 0.10	PASS

Total Appliances > **101**

Total Appliances For Report: 1,546